

On approval of risk assessment criteria and checklists used for carrying out preventive control with a visit to the subject (object) of control and supervision in the field of fire safety and inspections for compliance with permitting requirements for issued permits, preventive control with a visit to the subject (object) of control in the field of civil defence

Unofficial translation

Joint order of the Minister of Internal Affairs of the Republic of Kazakhstan of October 30, 2018 № 758 and Minister of National Economy of the Republic of Kazakhstan of October 30, 2018 № 31. Registered with the Ministry of Justice of the Republic of Kazakhstan on October 31, 2018 № 17647.

Unofficial translation

Footnote. The title - as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall come into effect from 01.01.2023).

In accordance with paragraph 5 of Article 141, paragraph 1 of Article 143 of the Entrepreneurial Code of the Republic of Kazakhstan, **WE HEREBY ORDER:**

Footnote. Preamble - as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall come into effect from 01.01.2023).

1. To approve:

1) criteria for assessing the degree of risk used to conduct preventive control with a visit to the subject (object) of control and supervision in the field of fire safety and inspections for compliance with permitting requirements for issued permits, in accordance with Annex 1 to this joint order;

2) criteria for assessing the degree of risk for carrying out preventive control with a visit to the subject (object) of control in the field of civil defence in accordance with Annex 2 to this joint order;

3) a checklist in the field of state control and supervision in the field of fire safety concerning objects, regardless of category, purpose and type of activity in accordance with Annex 3 to this joint order;

4) a checklist in the field of state control and supervision in the field of fire safety concerning industrial enterprises in accordance with Annex 4 to this joint order;

5) a checklist in the field of state control and supervision in the field of fire safety concerning automobile enterprises, transport service facilities, and parking areas (parking lots) in accordance with Annex 5 to this joint order;

6) a checklist in the field of state control and supervision in the field of fire safety concerning administrative buildings (multifunctional complexes), multi-apartment (individual) residential buildings and dormitories in accordance with Annex 6 to this joint order;

7) a checklist in the field of state control and supervision in the field of fire safety concerning automobile filling and gas filling stations (stationary and mobile) in accordance with Annex 7 to this joint order;

8) a checklist in the field of state control and supervision in the field of fire safety concerning subways in accordance with Annex 8 to this joint order;

9) a checklist in the field of state control and supervision in the field of fire safety concerning tourist centres, guest houses, holiday homes, boarding houses, health camps, and summer vacation spots for children in accordance with Annex 9 to this joint order;

10) a checklist in the field of state control and supervision in the field of fire safety concerning cultural, entertainment, entertainment and sports institutions in accordance with Annex 10 to this joint order;

11) a checklist in the field of state control and supervision in the field of fire safety concerning religious buildings (structures) in accordance with Annex 11 to this joint order;

12) a checklist in the field of state control and supervision in the field of fire safety concerning oil and gas production and oil and gas processing industry facilities in accordance with Annex 12 to this joint order;

13) a checklist in the field of state control and supervision in the field of fire safety concerning medical organizations in accordance with Annex 13 to this joint order;

14) a checklist in the field of state control and supervision in the field of fire safety concerning educational organizations and educational institutions in accordance with Annex 14 to this joint order;

15) checklist in the field of state control and supervision in the field of fire safety concerning medical and social institutions (organizations), boarding schools, children's homes (homes for the elderly and people with disabilities, orphanages, boarding schools, psycho-neurological centres, hospices) according to the Annex 15 to this joint order;

16) a checklist in the field of state control and supervision in the field of fire safety concerning commercial facilities in accordance with Annex 16 to this joint order;

17) a checklist in the field of state control and supervision in the field of fire safety concerning storage facilities in accordance with Annex 17 to this joint order;

18) a checklist in the field of state control and supervision in the field of fire safety concerning agricultural facilities, livestock farming, and poultry farms in accordance with Annex 18 to this joint order;

19) a checklist in the field of state control and supervision in the field of fire safety concerning energy facilities (energy producing and energy transmitting) in accordance with Annex 19 to this joint order;

20) a checklist in the field of state control and supervision in the field of fire safety concerning facilities of the Armed Forces, other troops and military formations, and law enforcement agencies in accordance with Annex 20 to this joint order;

21) a checklist in the field of state control and supervision in the field of fire safety concerning non-state fire service facilities in accordance with Annex 21 to this joint order;

22) a checklist in the field of state control and supervision in the field of fire safety concerning rotational facilities in accordance with Annex 22 to this joint order;

23) a checklist in the field of fire safety concerning legal entities certified for the right to carry out work to prevent and extinguish fires, ensure fire safety and carry out emergency rescue operations in organizations, settlements and facilities in accordance with Annex 23 to this joint order;

24) a checklist in the field of fire safety concerning accredited expert organizations for auditing in the field of fire safety in accordance with Annex 24 to this joint order;

25) a checklist in the field of state control in the field of civil defence concerning organizations classified as civil defence with the largest working shift, in accordance with Annex 25 to this joint order;

26) a checklist in the field of state control in the field of civil defence concerning organizations classified as civil defence, in accordance with Annex 26 to this joint order;

27) a checklist in the field of state control in the field of civil defence concerning organizations on the basis of which civil defence services are created, in accordance with Annex 27 to this joint order;

28) a checklist in the field of state control in the field of civil defence concerning local executive bodies of the Republic of Kazakhstan, in accordance with Annex 28 to this joint order;

29) a checklist in the field of state control in the field of civil defence concerning organizations that are assigned places of public recreation on natural and artificial reservoirs, in accordance with Annex 29 to this joint order;

30) a checklist in the field of state control in the field of civil defence concerning organizations not classified as civil defence, having protective structures and other civil defence property, in accordance with Annex 30 to this joint order;

31) a checklist in the sphere of state control in the field of civil defence concerning organizations not classified as civil defence, based on which evacuation points have been created, in accordance with Appendix 31 to this joint order;

32) a list of requirements from among those included in the checklists, the violation of which entails the application of operational response measures, as well as the determination of a specific type of operational response measure concerning specific violations, indicating

the period of validity of this measure (if necessary), in accordance with Appendix 32 to this joint order.

Footnote. Paragraph 1 - as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated November 28, 2022 № 250 and the acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall come into effect from 01.01.2023); as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and the acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the date of its first official publication)

2. The Committee for emergency situations of the Ministry of Internal Affairs of the Republic of Kazakhstan, in accordance with the procedure established by legislation, shall ensure:

1) state registration of this joint order at the Ministry of Justice of the Republic of Kazakhstan;

2) within ten calendar days from the date of state registration of this joint order at the Ministry of Justice of the Republic of Kazakhstan, its sending to the Republican state enterprise on the right of economic management “Republican Center for Legal Information of the Ministry of Justice of the Republic of Kazakhstan” for official publication and placement in the Standard control bank of regulatory legal acts of the Republic of Kazakhstan;

3) within ten calendar days after the state registration of this joint order, sending its copy for official publication in periodicals;

4) placement of this joint order on the official Internet resource of the Ministry of Internal Affairs of the Republic of Kazakhstan;

5) within ten calendar days after the state registration of this joint order at the Ministry of Justice of the Republic of Kazakhstan, submission of information on implementation of measures provided for in subparagraphs 1), 2) and 3) of this paragraph to the Legal department of the Ministry of Internal Affairs of the Republic of Kazakhstan.

3. To recognize invalid the joint order of the Minister of National Economy of the Republic of Kazakhstan dated June 20, 2017 № 246 and the Minister of Internal Affairs of the Republic of Kazakhstan dated May 2, 2017 № 307 "On approval of risk assessment criteria and checklists in the field of fire safety and civil defense" (registered in the Register of state registration of regulatory legal acts for № 15368, published in the Standard control bank of regulatory legal acts of the Republic of Kazakhstan in electronic form on August 7th, 2017).

4. Control over implementation of this joint order shall be entrusted on the supervising deputy Minister of internal affairs of the Republic of Kazakhstan.

5. This joint order shall be enforced upon expiry of ten calendar days after its first official publication.

Minister of National Economy

of the Republic of Kazakhstan

Minister of Internal Affairs

of the Republic of Kazakhstan

"AGREED"

Committee for legal statistics
and special accountings of
General Prosecutor's office
of the Republic of Kazakhstan
" ____ " _____ 201__ year

_____ T. Suleimenov

_____ K. Kasymov

Appendix 1
to the joint order of the
Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31 and
Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018,
№ 758

Criteria

for assessing the degree of risk used for carrying out preventive control with a visit to the subject (object)

of control and supervision in the field of fire safety and inspections for compliance with permitting requirements for issued permits

Footnote. Annex 1 - as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall come into effect from 01.01.2023); Minister of Emergency Situations of the Republic of Kazakhstan dated 25.06.2024 No. 244 and acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication).

Chapter 1. General provisions

1. These Criteria for assessing the degree of risk used for carrying out preventive control with a visit to the subject (object) of control and supervision and inspections for compliance with permitting requirements for issued permits (hereinafter referred to as the Criteria) have been developed in accordance with the Entrepreneurial Code of the Republic of Kazakhstan, the Law of the Republic of Kazakhstan "On civil protection", Rules for the formation by regulatory state bodies of a risk assessment and management system, approved by order of the Acting Minister of National Economy of the Republic of Kazakhstan dated June 22, 2022 № 48 (registered in the State Register of Normative Legal Acts under № 28577), by order of

the Acting Minister of National Economy of the Republic of Kazakhstan dated July 31, 2018 № 3 "On approval of the form of the checklist" (registered in the State Register of Normative Legal Acts under № 17371).

2. The criteria shall be formed by means of objective and subjective criteria.

Chapter 2. Objective criteria

3. The determination of objective criteria shall be carried out by determining the risk when carrying out activities by subjects (objects) of control and supervision.

4. Objective criteria have been developed to distribute subjects (objects) of control and supervision according to the degree of risk into high, medium and low degrees.

5. The following objects shall belong to a high degree of risk:

1) industrial enterprises with explosion and fire hazard categories of buildings and premises of "A", "B" - regardless of area, "B1"- "B4" with a total building area of 2000 or more square meters;

2) storage facilities with categories of buildings and premises "A", "B", and "B1" - "B4" for explosion and fire hazards - with a total building area of 2500 square meters or more, open warehouses for storing gas cylinders, forest materials, coal, grossage - with an area of 2500 square meters or more;

3) oil depots, petroleum product warehouses, oil terminals, and oil pumping stations;

4) gas storage facilities, gas tanks, gas pumping, gas filling and gas compressor stations;

5) automobile filling and gas filling stations (stationary and mobile);

6) facilities for storage, liquidation (destruction, disposal, burial) and processing of ammunition, explosives, industrial (oil) waste, military equipment and special equipment;

7) retail facilities and entertainment centres (a single building or a complex of buildings and structures of a single facility) - with a total building area of 2000 square meters or more, regardless of the area for one-story and two-story buildings when placing a trading floor on the ground or basement floors, and also regardless of areas for buildings of three floors or more;

8) built-in, built-in and attached retail facilities located in multi-apartment residential buildings (including those united by a single area) - with a total building area of 2000 square meters or more;

9) medical organizations providing inpatient care - regardless of area, providing outpatient care - with a total building area of 2000 square meters or more;

10) medical and social institutions (organizations), boarding schools, children's homes (homes for the elderly and people with disabilities, orphanages, boarding schools, psycho-neurological centres, hospices);

11) educational organizations, educational institutions;

12) dormitories and hotels, hostels, and campsites - with a total building area of 2000 square meters or more;

- 13) rotational facilities with a total building area of 2000 square meters or more;
- 14) multi-apartment residential buildings with a height of more than 28 meters;
- 15) administrative buildings and multifunctional complexes (a single building or a complex of buildings and structures of a single facility) - with a total area of 2500 square meters or more, and also regardless of the area with a height of more than 28 meters;
- 16) airports, railway and automobile terminals (stations), sea and river ports, and subways - with a total building area of 2000 square meters or more;
- 17) public catering organizations - with a total area of buildings of 2000 square meters or more (excluding the area of temporary summer areas);
- 18) facilities of the Armed Forces, other troops and military formations, law enforcement agencies;
- 19) cultural, entertainment, and religious places of worship - with a total building area of 2000 square meters or more;
- 20) sports and physical culture and healthcare complexes - with a total building area of 2000 square meters or more;
- 21) transport service facilities (stations and vehicle maintenance posts) – with a total building area of 1,500 square meters or more;
- 22) automobile enterprises, parking areas (parking lots) – with a total building area of 1,500 square meters or more;
- 23) elevators, granaries (grain receiving and procurement, production, base, transshipment and port);
- 24) agricultural facilities, livestock farming, poultry farms - with a total building area of 2500 square meters or more;
- 25) organizations of consumer services - with a total area of buildings of 2000 square meters or more;
- 26) thermal power plants, gas turbine power plants;
- 27) hydroelectric power plants - with a capacity of 250 megawatts or more;
- 28) electrical substations with a voltage of 220 kV and more;
- 29) boiler houses with a capacity of 50 Gcal/hour or more;
- 30) tourist centres, guest houses, holiday homes, boarding houses, health camps, summer recreation places for children - with a total building area of 1000 square meters or more, children's summer health camps (except for tent camps) - regardless of the area;
- 31) facilities in the field of circulation of medicines and medical devices - with a total building area of 2000 square meters or more;
- 32) communications enterprises, electronic computing centres, and data processing centres - with a total building area of 2,500 square meters or more;
- 33) archives, libraries – with a total building area of 1000 square meters or more;
- 34) organizations carrying out activities for the operation and maintenance of drinking water and fire-fighting water supply systems;

35) buildings of forestry institutions (forestry institutions, environmental and state forest management organizations);

36) non-state fire service of the facility.

6. The following objects shall belong to a medium degree of risk:

1) industrial enterprises with explosion and fire hazard categories of buildings and premises "B1" - "B4" - the total area of buildings is 1999 square meters or less;

2) storage facilities with categories of buildings and premises "A", "B", and "B1"- "B4" for explosion and fire hazards - with a total building area of 2499 to 1000 square meters, open-type warehouses for storing gas cylinders, forestry materials, coal, roughage - with an area of 2499 to 1000 square meters;

3) retail facilities and entertainment centres (a single building or a complex of buildings and structures of a single facility) – with a total building area of 1999 to 1000 square meters;

4) built-in, built-in and attached retail facilities located in multi-apartment residential buildings (including those united by a single area) - with a total building area of 1999 to 1000 square meters;

5) medical organizations providing outpatient care - with a total building area of 1999 to 1000 square meters;

6) dormitories and hotels, hostels, and campsites - with a total building area of 1999 to 1000 square meters;

7) rotational facilities with a total building area of 1999 to 1000 square meters;

8) administrative buildings and multifunctional complexes (a single building or a complex of buildings and structures of a single facility) – with a total building area of 2499 to 1500 square meters;

9) airports, railway and automobile terminals (stations), sea and river ports, and subways - with a total building area of 1999 to 1000 square meters;

10) public catering organizations - with a total area of buildings of 1999 to 1000 square meters (excluding the area of temporary summer areas);

11) cultural, entertainment, and religious places of worship - with a total building area of 1999 to 1000 square meters;

12) sports and physical culture and healthcare complexes - with a total building area of 1999 to 1000 square meters;

13) transport service facilities (stations and vehicle maintenance posts) – with a total building area of 1,499 to 1,000 square meters;

14) automobile enterprises, parking areas (parking lots) - with a total building area of 1499 to 1000 square meters;

15) agricultural facilities, livestock farming, poultry farms - with a total building area of 2499 to 1000 square meters;

16) organizations of consumer services - with a total area of buildings from 1499 to 1000 square meters;

- 17) electrical substations with voltage from 219 to 110 kV;
 - 18) boiler houses with a capacity of less than 50 Gcal/hour;
 - 19) tourist centres, guest houses, holiday homes, boarding houses, health camps, and summer vacation spots for children - with a total building area of 999 square meters or less;
 - 20) facilities in the field of circulation of medicines and medical devices - with a total building area of 1999 to 1000 square meters;
 - 21) communications enterprises, electronic computing centres, and data processing centres - total from 2499 to 1500 square meters;
 - 22) archives, and libraries – with a total building area of 999 to 500 square meters;
 - 23) non-state fire service, which is a member of a self-regulatory organization.
7. The following objects shall belong to a low degree of risk:
- 1) industrial enterprises with explosion and fire hazard categories of buildings and premises "G" and "D";
 - 2) storage facilities with categories of buildings and premises "A", "B", and "B1" - "B4" for explosion and fire hazards, with a total building area of 999 square meters or less, open warehouses for storing gas cylinders, forest materials, coal, roughage - with an area of 999 square meters or less;
 - 3) hydroelectric power plants - with a capacity of less than 250 Megawatts;
 - 4) wind, solar, and gas piston power plants;
 - 5) medical organizations providing outpatient care - with a total building area of 999 square meters or less;
 - 6) children's and teenagers' clubs at the place of residence;
 - 7) dormitories and hotels, hostels, and campsites - with a total building area of 999 square meters or less;
 - 8) airports, railway and automobile terminals (stations), sea and river ports, and subways - with a total building area of 999 square meters or less;
 - 9) retail facilities and entertainment centres (a single building or a complex of buildings and structures of a single facility) – with a total building area of 999 square meters or less;
 - 10) built-in, built-in and attached retail facilities located in multi-apartment residential buildings (including those united by a single area) - with a total building area of 999 square meters or less;
 - 11) cultural, entertainment, and religious places of worship - with a total building area of 999 square meters or less;
 - 12) sports and physical culture and healthcare complexes - with a total building area of 999 square meters or less;
 - 13) archives, libraries – with a total building area of 499 square meters or less;
 - 14) multi-apartment residential buildings with a height of less than 28 meters, individual residential buildings;

15) communications enterprises, electronic computing centres, data processing centres - with a total building area of 1499 square meters or less;

16) agricultural facilities, livestock farming, poultry farms - with a total building area of 999 square meters or less;

17) facilities in the field of circulation of medicines and medical devices - with a total building area of 999 square meters or less;

18) public catering organizations - with a total area of buildings of 999 square meters or less (excluding the area of temporary summer areas);

19) organizations of consumer services - with a total area of buildings of 999 square meters or less;

20) automobile enterprises, parking areas (parking lots) - with a total building area of 999 square meters or less;

21) transport service facilities (stations and vehicle maintenance posts) – with a total building area of 999 square meters or less;

22) administrative buildings and multifunctional complexes (a single building or a complex of buildings and structures of a single facility) - with a total area of 1499 square meters or less;

23) rotational facilities with a total building area of 999 square meters or less;

24) electrical substations with voltage less than 110 kV;

25) expert organizations for auditing in the field of fire safety.

8. Checking for compliance with permitting requirements for issued permits, preventive control with a visit to the subject (object) of control and supervision, concerning subjects (objects) of control and supervision classified as high and medium degree of risk, shall be carried out based on annual schedules, semi-annual lists.

Concerning non-state fire-fighting services, inspections shall be carried out for compliance with permitting requirements for issued permits, preventive control with a visit to the subject (object) of control and supervision and unscheduled inspections in accordance with the Entrepreneurial Code of the Republic of Kazakhstan.

Concerning expert organizations for auditing in the field of fire safety, unscheduled inspections shall be carried out in accordance with the Entrepreneurial Code of the Republic of Kazakhstan.

9. For areas of activity of subjects (objects) of control and supervision classified as high-risk, the frequency of preventive control with visits shall be determined by the criteria for assessing the degree of risk, but not more than once a year.

For areas of activity of subjects (objects) of control and supervision classified as high-risk, the frequency of inspection for compliance with permitting requirements shall be determined by the criteria for assessing the degree of risk, but not more than once a year.

For areas of activity of subjects (objects) of control and supervision classified as medium risk, the frequency of preventive control with visits to the subject (object) of control and

supervision shall be determined by the criteria for assessing the degree of risk, but not more than once every two years.

For areas of activity of subjects (objects) of control and supervision classified as medium-risk, the frequency of inspection for compliance with permitting requirements shall be determined by the criteria for assessing the degree of risk, but not more than once every two years.

For areas of activity of subjects (objects) of control and supervision classified as low risk, preventive control with a visit to the subject (object) of control and supervision for compliance with requirements shall not be carried out, except for unscheduled inspections in accordance with the Entrepreneurial Code of the Republic of Kazakhstan.

Chapter 3. Subjective criteria

10. Concerning subjects (objects) of control and supervision classified as high and medium risk, to conduct preventive control with a visit to the subject (object) of control and supervision, information sources (databases) shall be used to identify subjects (objects) of control and supervision, violating fire safety requirements, as well as subjective criteria.

11. To assess the degree of risk, the following sources of information shall be used:

1) the results of previous inspections and preventive control with visits to subjects (objects) of control and supervision;

2) availability of adverse incidents (fires) that arose through the fault of the subject (object) of state control and supervision in the form of an administrative penalty on a business entity under Article 410 of the Code of the Republic of Kazakhstan on Administrative Offences;

3) excluded by joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication);

4) the results of the analysis of information provided by government bodies and organizations in the form of operation of the facility for 5 years or more, implementation of activities with confirmed information about violations of the load (design capacity).

Footnote. Paragraph 11 as amended by joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).

12. Based on an assessment of information sources and subjective criteria, semi-annual preventive control lists with visits and an annual schedule of inspections of subjects (objects) of control and supervision shall be automatically generated.

When analyzing and assessing, data from subjective criteria that were previously taken into account and used concerning a specific subject (object) of control and supervision or data

for which the statute of limitations has expired in accordance with the Civil Code of the Republic of Kazakhstan shall not be used.

13. Depending on the possible risk and significance of the problem, the singularity or systematic nature of the violation, the analysis of previously made decisions, and subjective criteria shall be determined for the subject (object) of state control and supervision based on sources that correspond to the degree of violation - gross, significant and minor.

Gross violations are violations of fire safety requirements aimed at eliminating the conditions for the occurrence of a fire, its spread, and exposure of people to dangerous fire factors, as well as requirements regulating the activities of the non-state fire service, the safe operation of electrical networks and electrical equipment, availability and condition of evacuation routes.

Significant violations are violations of fire safety requirements aimed at preventing and preventing the occurrence of a fire and creating conditions for its successful extinguishing.

Minor violations are violations of fire safety requirements regulating organizational issues of ensuring fire safety.

Subjective criteria with the distribution of fire safety requirements by degree of violation and sources of information into gross, significant, and minor are given in the Annex to these Criteria.

14. Based on the priority of the information sources used in accordance with the procedure for calculating the overall risk degree indicator according to subjective criteria, the overall risk degree indicator shall be calculated according to subjective criteria on a scale from 0 to 100.

According to risk level indicators, the subject (object) of control and supervision shall include:

- 1) to a high degree of risk - with a risk degree indicator from 71 to 100 inclusive;
- 2) to a medium degree of risk - with a risk degree indicator from 31 to 70 inclusive;
- 3) to a low degree of risk - with a risk degree indicator from 0 to 30 inclusive.

Footnote. Paragraph 14 as amended by joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).

15. When calculating the risk level indicator, the proportion of unfulfilled fire safety requirements shall be determined.

16. If one gross violation is detected, the subject (object) of degree control shall be assigned a risk level of 100 and shall be subject to a check for compliance with permitting requirements for issued permits or preventive control with a visit to the subject (object) of control and supervision.

In the absence of gross violations of fire safety requirements, to determine the risk level indicator, the total indicator for violations of fire safety requirements of a significant and minor degree shall be calculated.

16-1. The calculation of the risk level indicator according to subjective criteria (R) shall be carried out in an automated mode by summing up the risk level indicator for violations based on the results of previous inspections and preventive control with visits to subjects (objects) of control and supervision (SP) and the risk level indicator according to subjective criteria (SC), determined in accordance with paragraph 17-1 of these Criteria, with subsequent normalization of data values in the range from 0 to 100 points.

$$R_{\text{prom}} = SP + SC, \text{ where}$$

R_{prom} is an intermediate indicator of the degree of risk according to subjective criteria,

SP - indicator of the degree of risk for violations,

SC - indicator of the degree of risk according to subjective criteria determined in accordance with paragraph 17-1 of these Criteria.

The calculation shall be made for each subject (object) of control and supervision of a homogeneous group of subjects (objects) of control and supervision of each sphere of state control and supervision. In this case, the list of assessed subjects (objects) of control and supervision, classified as a homogeneous group of subjects (objects) of control and supervision of one area of state control and supervision, forms a sample population (sample) for subsequent data normalization.

Footnote. The criteria were supplemented with Paragraph 16-1 in accordance with the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).

17. When determining the indicator of significant violations, a coefficient of 0.7 shall be applied and this indicator shall be calculated using the following formula:

$$SP_3 = (SP_2 \times 100 / SP_1) \times 0.7, \text{ where:}$$

SP_3 – indicator of significant violations;

SP_1 – required number of significant violations;

SP_2 – number of significant violations identified;

When determining the indicator of minor violations, a coefficient of 0.3 shall be applied and this indicator shall be calculated using the following formula:

$$SP_n = (SP_2 \times 100 / SP_1) \times 0.3, \text{ where:}$$

SP_n – an indicator of minor violations;

SP_1 – required number of minor violations;

SP₂ – number of minor violations identified;

The overall risk score (SP) shall be calculated on a scale from 0 to 100 and shall be determined by summing the indicators of major and minor violations using the following formula:

SP = SP₃ + SP_n, where:

SP – indicator of the degree of risk for violations;

SP₃ – indicator of significant violations;

SP_n – an indicator of minor violations.

Footnote. Paragraph 17 - as amended by the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).

17-1. Based on the priority of the applied sources of information and the significance of the indicators of subjective criteria, in accordance with the procedure for calculating the risk degree indicator according to subjective criteria defined in paragraphs 16-1 and 17 of these Criteria, the risk degree indicator shall be calculated according to subjective criteria on a scale from 0 to 100 points.

The priority of the applied sources of information and the significance of the indicators of subjective criteria shall be determined in accordance with Annex 2 to these Criteria.

Footnote. The criteria were supplemented with Paragraph 17-1 in accordance with the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).

17-2. The calculation of the risk level according to subjective criteria shall be made on a scale from 0 to 100 points and shall be carried out using the following formula:

$$SC = \sum_{i=1}^n x_i * w_i, \text{ где}$$

where

x_i – an indicator of subjective criterion,

w_i – the specific weight of the subjective criterion indicator x_i,

n – number of indicators.

The resulting value of the risk degree indicator according to subjective criteria shall be included in the calculation of the risk degree indicator according to subjective criteria.

Footnote. The criteria were supplemented with Paragraph 17-2 in accordance with the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).

17-3. The R values calculated for subjects (objects) are normalized to a range from 0 to 100 points. Data normalization shall be carried out for each sample population (sample) using the following formula:

$$R = \frac{R_{\text{пром}} - R_{\text{min}}}{R_{\text{max}} - R_{\text{min}}},$$

R – risk degree indicator (final) according to the subjective criteria of an individual subject (object) of control and supervision,

R_{max} – the maximum possible value on the risk degree scale according to subjective criteria for subjects (objects) included in one sample population (sample) (upper limit of the scale),

R_{min} – the minimum possible value on the risk degree scale according to subjective criteria for subjects (objects) included in one sample population (sample) (lower limit of the scale),

$R_{\text{пром}}$ – an intermediate indicator of the degree of risk according to subjective criteria, calculated in accordance with paragraph 16-1 of these Criteria.

Footnote. The criteria were supplemented with Paragraph 17-3 in accordance with the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).

18. Preventive control with a visit to the subject (object) of control and supervision, an unscheduled inspection shall be carried out according to the checklist in the field of state control and supervision in the field of fire safety, given in Annex 3 to this joint order, and depending on the category, purpose and type of activity object, according to the checklists given in Annexes 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21 and 22 to this joint order.

19. Inspections for compliance with permitting requirements for issued permits shall be carried out according to checklists in the field of state control and supervision in the field of fire safety, given in Annexes 23, and 24 to this joint order.

Chapter 4. Risk management

20. A non-state fire service shall be transferred with the use of an information system from a high degree of risk to a medium degree of risk in the field of fire safety if they are members of a self-regulatory organization based on voluntary membership (participation) in accordance with the Law of the Republic of Kazakhstan "On Self-Regulation".

21. If gross violations are identified based on the results of inspections and preventive monitoring with visits to non-state fire services, such services shall be transferred, using an information system, from a medium risk to a high risk in the field of fire safety.

Annex 1
to the Criteria for assessing the degree
of risk used for carrying out preventive
control
with a visit to the subject (object) of
control
and supervision in the field of fire safety
and
inspections for compliance with
permitting
requirements for issued permits

Footnote. Upper right corner - as amended by the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).

The degree of violation of requirements for subjects (objects) of control and supervision in the field of fire safety during preventive monitoring with visits, inspections for compliance with permitting requirements for issued permits and unscheduled inspections

Footnote. Title - as amended by the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).

Footnote. Annex 1 as amended by joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication); Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication).

	Name of sources of information and fire safety requirements (the degree	
--	---	--

№	of severity shall be established if this requirement is not met)	Degree of violations
<i>Footnote. Title excluded by joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).</i>		
1.	<i>Excluded by joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).</i>	
2.	<i>Excluded by joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).</i>	
<i>Footnote. Title excluded by joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).</i>		
3.	<i>Excluded by joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).</i>	
4.	<i>Excluded by joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).</i>	
<i>Footnote. Title excluded by joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).</i>		
5.	<i>Excluded by joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).</i>	
6.	<i>Excluded by joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and the acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall come into effect upon the expiration of ten calendar days after the day of its first official publication).</i>	
Distribution of violations for inspections, preventive control with visits and selection based on the results of previous inspections and preventive control with visits to subjects (objects) of state control and supervision		
Requirements for organizational actions		
7.	Presence of persons responsible for ensuring fire safety at individual work sites	minor

8.	Availability and compliance with instructions establishing a fire regime for the facility corresponding to its fire hazard	minor
9.	Presence of non-state fire service and its compliance with the number of fire trucks, full-time employees, fire-technical inventory and equipment, special uniforms and fire-fighting equipment	gross
10.	Admission to work for workers after completing fire safety briefings and training on fire safety issues	minor
11.	Presence of an official responsible for the operation of fire protection systems, acquisition, repair, safety and readiness for action of primary fire extinguishing means, timely and high-quality maintenance (recharging of hand-held fire extinguishers) and scheduled preventive maintenance	minor
12.	<p>The location of the duty personnel in premises where there is a telephone and a free-form log of people remaining in the building overnight is kept.</p> <p>Presence in the premises of organizations on-duty personnel at telephone locations, evacuation plans, instructions on fire safety measures, signs indicating the telephone numbers of the fire service "101" and the unified duty dispatch service "112". The duty personnel must have a set of keys for all building door locks, in accordance with their assigned functions. Storing a spare set of keys (provided with a tag with an inscription indicating that it belongs to the lock) in the premises of the duty personnel (security) on the ground floor of the building</p>	minor
13.	Availability of a special journal or automated system for recording maintenance and preventative repairs of technical means of fire protection systems, checking availability and condition of primary fire extinguishing equipment	minor
14.	Availability and compliance of evacuation plans in case of fire	minor

15.	Provision of fire safety signs in premises, buildings, structures, and equipment with increased fire hazards, as well as indicators of the locations of fire water supply sources (fire hydrants, fire reservoirs , fire points) in accordance with the requirements of standardization documents, documents in the field of architecture, urban planning and construction	significant
16.	Availability of electric lights for maintenance or duty personnel of buildings for human habitation, facilities with large numbers of people in the event of a power outage	minor
17.	Conducting practical training by the heads of organizations of facilities with large numbers of people at least once every six months, indicating in the training log compiled in free form	minor
18.	Availability in rural settlements, gardening partnerships, dacha cooperatives (partnerships, consumer cooperatives, non-profit partnerships), on the territory of which fire service units are not located, fire motor pumps with a set of fire hoses and nozzles, primary fire extinguishing means, non-mechanized tools and fire equipment, which are used to extinguish fires	significant
19.	Availability of sound alarms in the territory of rural settlements, gardening partnerships, dacha cooperatives, block container buildings to notify people about a fire, storage of a supply of water for fire extinguishing purposes	significant
Requirements for the maintenance of territories		
20.	Maintaining roads, driveways and entrances to buildings, structures, technological installations, open warehouses, external fire escapes and fire-fighting water supply sources in good condition and accessible for firefighting equipment	significant

21.	Availability of a stationary post with round-the-clock personnel on duty, and a barrier equipped with a device for manual opening, if installed at the entrance to the territory of groups of residential buildings united by a common space (yard) of the barrier	minor
22.	Preventing the placement (storage) of any facilities, constructions, or structures within the fire safety distances between buildings and structures, as well as their use for parking vehicles and construction (installation) of buildings and structures	significant
23.	Availability of fire safety distances	gross
24.	Preventing the storage of roughage on the estates of residential buildings at a distance of fewer than 15 meters from buildings and outbuildings (if it is impossible to store roughage at the specified distance, on condition that the storage area is provided with an additional container of water of at least 500 litres, the distances are reduced to 5 meters)	gross
25.	Preventing storing stacks, haystacks, stacks of roughage, flammable substances and materials on the roofs of barns and outbuildings, under power lines, at a distance of less than 3 meters from the external fence of the site. Storing roughage at a height of no more than 4 meters from ground level	gross
26.	Preventing lighting fires, burning waste and containers at a distance of less than 50 meters from buildings and structures	gross
27.	Preventing the installation of special devices for placing burning coal (mangal, barbecue, grill) in places with dry vegetation, under tree canopies, under canopies made of flammable materials, in the premises of a residential building, as well as on balconies and loggias, in outbuildings, garages, attics, on flat roofs. Avoidance of leaving burning coal unattended	gross
	Avoidance of the use of open fire and smoking in fire-hazardous and	

28.	explosion-hazardous areas, under foundations, gas-hazardous places, near containers for storing fuels and lubricants, petroleum products, flammable substances and reagents	gross
29.	Cleaning the area of flammable waste, garbage, containers, fallen leaves, combustible debris and combustible materials	significant
30.	Availability of external lighting on the territory of the organization in the dark for quickly finding fire hydrants, external fire escapes and places for placing fire equipment, as well as entrances to the piers of fire reservoirs	significant
31.	When operating block containers, avoiding changes in the design parameters provided by the manufacturer	significant
32.	Placement of individual block containers and household trailers in groups of no more than 10 in a group, with a distance between groups of these buildings and from them to nearby buildings and structures of at least 18 meters	gross
33.	Ensuring the construction of protective firebreaks with a width of at least 4 meters, planting deciduous trees, removing dry vegetation in the summer	gross
Requirements for the maintenance of buildings, facilities and structures		
34.	Placement on the doors of emergency exits from premises, buildings (structures) for production and warehouse purposes, on external technological installations of information about their category in terms of explosion and fire hazard, as well as about the classes of explosive or fire-hazardous zones located in them	minor
	Ensuring by the head of the organization of the availability, compliance with design documentation and constant condition in good working order of fire extinguishing and fire alarm systems, warning and evacuation control systems for people in case of fire, smoke protection and fire water	

35.	supply, fire-fighting equipment and fire-fighting equipment, fire doors, valves and hatches, fillings of openings in fire barriers, premises of buildings and structures, means of protection and rescue of people, as well as lightning protection devices for buildings, structures and external technological installations	gross
36.	Avoidance of work on equipment with faults that could lead to a fire	gross
37.	Availability of serviceable lightning protection devices in buildings, structures and external technological installations provided for by the project	gross
38.	Inspection of lightning protection devices at least once a year. Availability of a log of operation of lightning protection devices with a mark of inspection of lightning protection devices at least once a year during the pre-storm season	gross
39.	Inspection of lightning protection devices	significant
40.	Availability of protective grounding in all metal structures of technological devices, tanks, gas pipelines, pipelines, oil pipelines, devices, and equipment located inside buildings, structures and in open spaces, in which flammable or combustible liquids are handled, stored or processed, as well as flammable gases, as well as external technological installations and overpasses	gross
41.	Preventing the use of process pipelines of buildings and structures as grounding (neutral) conductors	gross
42.	Availability and maintenance in good condition of devices for self-closing doors in buildings and structures. Preventing the installation of devices that obstruct the free closing of fire doors and smoke protection devices (curtains, screens, blinds)	gross
43.	Preventing the establishment of storage rooms (utility rooms) on stairwells, landings and corridors, as well as storing things, furniture, and	gross

	flammable materials under flights of stairs and on landings	
44.	Availability of fire-retardant treatment and coatings of building structures, combustible finishing heat-insulating materials, wooden structures, air ducts, metal supports and overpasses and checking the state of fire-retardant treatment (impregnation) with confirmation of fire-retardant effectiveness (for metal structures in accordance with national technical regulations)	gross
45.	Ensuring that the doors of attics, as well as technical floors and basements, where technology does not require the constant presence of people, are locked. Availability on the doors of the specified premises of information about the location of key storage, to which 24-hour access is provided	minor
46.	Avoidance of use and application of basements, ground floors, attics, technical floors and rooms, ventilation chambers not for their intended purpose, except in cases provided for by design documentation	gross
47.	Clearing debris and facilities from pits near window openings in the basement and ground floors of buildings, structures and structures, and opening locks on windows from the inside without a key	gross
48.	Preventing the installation of bars on the windows of all floors of the building, and pits near basement windows (except for premises of the penal system and special institutions that provide temporary isolation from society, warehouses, cash registers, weapons rooms, secret parts of institutions, storage and circulation of precursors)	gross
49.	Preventing the use of elevator halls for purposes other than their intended purpose	gross
50.	Preventing glazing of balconies, loggias and galleries leading to smoke-free staircases	gross

51.	Preventing changes in space-planning solutions, as a result of which the conditions for the safe evacuation of people worsen, access to fire extinguishers, fire hydrants, and fire safety equipment is limited, or the area of operation of automatic fire protection systems (automatic fire alarms, stationary automatic fire extinguishing installations, smoke removal systems, warning systems) is reduced and evacuation management)	gross
52.	Preventing storage and warehousing in basements and ground floors, attics, technical floors and premises, ventilation chambers of flammable and combustible liquids, explosives, pyrotechnic products, cylinders with flammable gases, goods in aerosol packaging, celluloid and explosive, flammable substances and materials	gross
53.	Preventing the removal of project-designed doors for evacuation exits from floor corridors , halls, foyers, vestibules and staircases, as well as doors that prevent the spread of fire hazards along evacuation routes	gross
54.	Preventing obstruction and obstruction of passages to fire safety and fire extinguishing equipment, as well as to places where rescue devices are attached	gross
55.	Preventing the installation of built-in premises in production and warehouse premises of buildings (except for buildings of fire resistance V class) that are not provided for in the design documentation	gross
56.	Preventing the simultaneous presence of 50 people or more in premises with one emergency exit	gross
57.	Availability of the required number of serviceable and well-maintained primary fire extinguishing equipment. Operation and maintenance of fire extinguishers in accordance with the requirements of standardization documents	significant
	Sealing with mortar or other non-combustible materials that	

58.	provide the required fire resistance and smoke and gas tightness, the resulting holes and gaps at the intersection of fire walls, ceilings and enclosing structures with various engineering and technological communications	gross
59.	Implementation of changes in functional purpose, major repairs, technical re-equipment, reconstruction and redevelopment of buildings, structures and structures according to design documentation	significant
60.	Availability and maintenance in good condition of external fire escapes and fences on the roofs of buildings, structures and structures	significant
61.	When operating household gas appliances, preventing placing furniture and flammable materials at a distance of less than 0.2 meters horizontally from the nearest vertical surface and less than 0.7 meters vertically from the nearest horizontal surface of these products overhanging it	gross
62.	Availability of certificates (declarations) at the facility to confirm the compliance of fire safety and fire extinguishing means	significant
Requirements for the maintenance of evacuation routes and exits		
63.	In buildings with stained glass windows more than 1 floor high, preventing violations of the structures of smoke-tight non-combustible diaphragms installed in stained glass windows at the level of each floor	significant
64.	Automatic lowering to the main landing floor, and in underground structures - raising to the floor the main emergency exits from the structure and de-energizing elevators and lifts (except for fire elevators), as well as automatic shutdown of escalator (travelator) drives in the event of a fire	gross
65.	Ensuring compliance with design decisions during the operation of evacuation routes and exits (including lighting, quantity, size and space-planning solutions for	gross

	evacuation routes and exits, as well as Availability of fire safety signs on evacuation routes)	
66.	Installation of doors on evacuation routes that open freely and in the direction of exit from the building (except for premises of functional fire hazard classes F1.3 and F1.4, premises with simultaneous occupancy of no more than 15 people, except for premises of categories "A" and "B" according to explosion and fire hazard, storerooms with an area of no more than 200 square meters, sanitary facilities,) exits to type 3 staircase landings)	gross
67.	Providing locks on emergency exit doors with the ability to open them freely from the inside without a key	gross
68.	Maintaining three-dimensional fire safety light signs "Exit", "Evacuation (emergency) exit", "Emergency exit door", used on evacuation routes, in good condition and with light indication turned on	gross
69.	Ensuring automatic switching on of evacuation lighting when the power supply to the working lighting is interrupted	gross
70.	Preventing the installation of obstacles that narrow the design dimensions of evacuation routes and exits (including passages, corridors, vestibules, galleries, elevator halls, landings, flights of stairs, doors, and evacuation hatches), as well as hammering (welding) of emergency exit doors	gross
71.	Preventing the installation of thresholds on evacuation routes (except for thresholds in doorways), sliding and up-and-down doors and gates, revolving doors and turnstiles, as well as devices that impede the free evacuation of people, in the absence of other (duplicate) evacuation routes or in the absence of technical solutions that allow you to manually open and lock the specified devices in the open state	gross

72.	Preventing the use of flammable materials that do not meet the fire hazard class for finishing, cladding and painting floors, walls, ceilings, stairs and flights of stairs on escape routes, except for buildings of fire resistance class V	gross
73.	Preventing the fixation of self-closing doors of staircases, corridors, halls and vestibules in the open position, as well as their removal	gross
74.	Preventing glazing or obstructing air spaces in smoke-free stairwells	gross
75.	Preventing the replacement of reinforced glass with conventional glass in the glazing of doors and transoms	gross
76.	Availability of garbage chute valves in buildings and structures provided for by the project, which are in the closed position, are maintained in good condition and are provided with a seal in the vestibule	gross
77.	Availability of evacuation passages to staircases and escape routes when arranging equipment in the room	gross
78.	Fastening carpets, carpet runners, and floor coverings to the floor in rooms with large numbers of people	significant
Requirements for the operation of electrical networks, electrical installations and electrical products		
79.	Preventing the laying and operation of overhead power lines over flammable roofs, canopies, as well as open warehouses (stacks, haystacks) of flammable substances, materials and products, external technological installations for explosion and fire hazard categories A, B, B1-B4	gross
80.	Preventing the use of electrical networks and electrical energy receivers in violation of the safety requirements set out in the manufacturer's instructions, electrical receivers with malfunctions that could lead to a fire (cause sparking, short circuit, excessive heating of cable and wire insulation, failure of automatic control systems, emergency and fire	gross

	protection), as well as the operation of electrical wires and cables with insulation that is damaged or has lost its protective properties	
81.	Preventing the use of electrical energy receivers in violation of the design and protection systems provided by the manufacturer, including damaged and loose electrical installation products, as well as preventing the operation of a temporary electrical network	gross
82.	Preventing the use of electric heating devices in the absence or malfunction of thermostats provided by the design	gross
83.	Preventing the use of electric irons, electric stoves, electric kettles and electric heating devices without special stands (power sockets, heating disks) that eliminate the risk of fire, if their presence is provided for in the manufacturer's instructions	gross
84.	Preventing the use of non-standard (homemade) electric heating devices, the use of uncalibrated fuse links, homemade overload and short circuit protection devices	gross
85.	During the operation of electrical installations, prohibition of placement (storage) of flammable and (or) explosive substances and materials near electrical panels, electric motors and starting equipment, as well as in the rooms and corridors of closed switch gears, placement of storage rooms, including electrical equipment, spare parts, containers with flammable liquids and gas cylinders	gross
86.	Preventing the use of electrical equipment in explosive and fire-hazardous areas that do not have the level and type of protection against explosion and (or) fire from the manufacturer.	gross
87.	Checking the condition of stationary equipment and electrical wiring of the power and lighting networks, testing and measuring the insulation resistance of wires, cables and grounding devices during	gross

	commissioning, and subsequently according to the schedule, but at least once every three years	
88.	Mounting of all current-carrying parts, distribution devices, apparatus and measuring instruments, as well as break-type safety devices, switches, starting devices and electrical installation devices only on non-combustible bases	gross
89.	Connecting, terminating and branching wires and cables to avoid fire-hazardous transient resistances using crimping, welding, soldering or special clamps	gross
90.	Carrying out the connection and branching of wires and cables, except for wires laid on insulating supports, in junction and branch boxes, insulating housings of connecting and branch clamps, special niches of building structures, inside the housings of electrical installation products, devices and machines	gross
Requirements for the maintenance of heating and ventilation systems of buildings and structures		
91.	Removal of combustion products from heat-generating apparatus outside buildings and structures through smoke ducts specially designed for this purpose. Preventing the use of ventilation system air ducts as smoke ducts	gross
92.	Availability of technological holes in the design of the smoke channel for periodic cleaning of soot	significant
93.	Availability on the floor of combustible materials under the combustion door of heat-generating devices operating on solid fuels, a pre-furnace metal sheet measuring at least 0.5 x 0.7 meters without holes, located in front of the combustion opening along the stove	significant
94.	Installation of a liquid fuel device in a metal tray that can hold the entire volume of fuel in the fuel tank in the event of an emergency spill. Filling the tray with sand or another non-flammable adsorbent	gross

95.	Availability on heat-generating devices operating on liquid, solid and gaseous fuels of serviceable doors and fire-prevention separations (derogations) from combustible structures established by standards. Availability of at least two valves on the fuel line near each nozzle of heating boilers and heat-generating units: one at the firebox, the other at the fuel tank	gross
96.	Carrying out firing of furnaces by specially designated persons instructed on fire safety measures when operating heating appliances	minor
97.	Preventing the use of faulty stoves and heating appliances	gross
98.	<p>Avoidance of the following during operation of heat-generating equipment:</p> <ol style="list-style-type: none"> 1) work on the device with a broken fuel line seal and a faulty shut-off valve on it, loose connections of the nozzle body with the heat-generating device, faulty chimneys, electric motors and protection devices, as well as in the absence of thermal protection of the electric motor and malfunctions; 2) work on the device with open fuel tanks; 3) installation of fencing made of materials of flammability groups G3-G4 around the apparatus and supply tanks; 4) heating fuel lines with an open flame; 5) ignition of the working mixture through the inspection window; 6) regulation of the gaps between the spark plug electrodes when the heat-generating device is operating; 7) leaving operating heat-generating equipment unattended or entrusting supervision of them to children. 	gross
	<p>Prevention during central boiler houses operation intended for heating organizations and residential buildings in populated areas of:</p> <ol style="list-style-type: none"> 1) storage of liquid fuel in premises not intended for these purposes; 	

99.	<p>2) the use of flammable substances (solid, liquid, gaseous) as fuel that is not provided for in the operating instructions for the equipment;</p> <p>3) operation of heat-generating installations in the event of leakage of liquid fuel or gas leakage from fuel supply systems;</p> <p>4) drying of flammable materials on boilers and steam pipelines</p>	gross
100.	<p>Avoidance when operating stove heating of:</p> <p>1) leaving burning stoves unattended, as well as entrusting supervision of them to children;</p> <p>2) placing fuel prepared for combustion, as well as flammable substances and materials on the pre-furnace sheet;</p> <p>3) the use of flammable and combustible liquids for igniting solid fuel stoves;</p> <p>4) heating the furnace with other types of fuel, the use of which is not intended for a specific type of furnace;</p> <p>5) firing furnaces in premises during meetings and public events;</p> <p>6) overheating the furnace;</p> <p>7) drying flammable substances and materials at a distance of less than 0.5 m from the surface of the stove and chimneys;</p> <p>8) using a valve (damper) without the holes provided for by the design standards;</p> <p>9) using ventilation and gas ducts as chimneys, laying transit chimneys through residential premises.</p> <p>Carrying out maintenance of heating devices and systems before the start of the heating season. Cleaning smokestacks, chimneys and elements of heating furnaces and systems from soot immediately before, as well as during the heating season.</p>	gross
101.	<p>Storing fuel (coal) in premises specially adapted for this purpose or in specially designated areas located no closer than 8 meters from combustible buildings</p>	gross

102.	Availability of specially designated places, excluding the possibility of fire, for placing ash and slag and spilling them with water	gross
103.	Preventing the placement of flammable substances, materials, products and equipment at a distance of less than 1.25 meters from the combustion openings of furnaces and less than 0.7 meters from other heated parts of furnaces	gross
104.	Availability of whitewash in the attics of chimneys and walls in which smoke ducts pass	significant
105.	Availability of spark arresters on chimneys of boiler installations	gross
106.	Compliance with the instructions of manufacturers, as well as the requirements of state regulations in the field of architecture, urban planning and construction for heating systems when installing factory-made stoves in dormitories, administrative, public administrative and domestic buildings of industrial enterprises, residential buildings	gross
107.	Compliance with fire safety requirements when installing temporary metal stoves: 1) metal stoves are provided with legs no less than 0.2 meters high; 2) metal stoves are installed at a distance of at least: 1 meter - from wooden structures, furniture, goods, shelving, showcases, counters and other equipment; 0.7 meters – from structures protected from fire; 1.25 meters – from combustion openings to wooden structures and other equipment	significant
108.	Compliance with the requirements when placing metal pipes of heat-generating apparatuses out of the window: 1) when removing a metal chimney through a window, a sheet of roofing iron replacing the cut is inserted into it, measuring at least three times the diameter of the chimney; 2) the pipe is led beyond the wall of the building to a distance of no less than 0.7 meters and directed upward	gross

	<p>to a height of no less than 0.5 meters ;</p> <p>3) the pipe leading out of the upper floor window protrudes above the cornice by at least 1 meter. A cap is installed on the pipe.</p>	
109.	<p>Application of electric heaters with a working alarm and interlock, preventing the supply of electricity to the heating elements when the fan is not working, and automatic control of the temperature of the outlet air and its regulation, provided for by electrical and thermal protection</p>	gross
110.	<p>Operation of the design of air ducts and channels of supply and exhaust smoke ventilation systems and transit channels (including air ducts, collectors, shafts) of ventilation systems in accordance with design documentation</p>	significant
111.	<p>Preventing storage of any equipment or materials in ventilation chambers and keeping them locked. Permanently locking the ventilation chambers</p>	significant
112.	<p>Inspection within the time limits established by the technical documentation and maintenance in good condition of fire-retarding devices (sliders, gates, valves) in air ducts, blocking devices for ventilation systems with automatic fire alarm or fire extinguishing installations, automatic ventilation shutdown devices in case of fire. Cleaning of sensitive elements of the valve drives from contamination with flammable dust (low-fusible locks, flammable inserts, heat-sensitive elements). Cleaning ventilation chambers, cyclones, filters, air ducts from flammable dust , production waste and fatty deposits</p>	significant
113.	<p>Preventing during operation of ventilation and air conditioning systems of:</p> <p>1) leaving the doors of ventilation chambers open;</p> <p>2) closing exhaust ducts, openings and grilles;</p>	gross

	<p>3) connections to the air ducts of gas heating devices;</p> <p>4) burning out fatty deposits, dust and flammable substances accumulated in air ducts</p>	
Requirements for the maintenance of fire-fighting water supply sources		
114.	<p>Availability, compliance with design documentation and maintenance in good condition of natural and artificial sources of fire-fighting water supply (including fire-fighting water supply, fire reservoirs, and water storage tanks for fire-fighting purposes), as well as entrances with platforms (piers) with a hard surface measuring at least 12x12 meters for installing fire trucks and collecting water at any time of the year</p>	gross
115.	<p>Availability of an act and test report of the results of technical inspection and testing for water yield and operability of internal fire water supply systems by starting water for equipment of fire water supply systems (fire hydrants, fire plugs, dry pipe water and foam fire extinguishing systems, as well as water irrigation)</p>	significant
116.	<p>Insulation and cleaning of fire hydrants from snow and ice in winter</p>	significant
117.	<p>Sealing manual start devices for fire extinguishing installations, locking and starting devices for fire extinguishers and fire cabinet doors</p>	significant
118.	<p>Providing fire hydrants for the internal fire water supply system at a height of 1.35±0.15 m above the floor of the room, complete with hoses, trunks, and enclosure in fire cabinets.</p> <p>Indication on the cabinet door of the letter index "FH"(fire hydrant) and the serial number. Keeping fire hoses dry, well rolled or folded and attached to valves and trunks</p>	significant
119.	<p>Availability of fire cabinets in any of three options (mounted, attached and built-in), with the possibility of placing in them a set of fire hydrant equipment and at least two hand-held fire extinguishers, with a fire extinguishing agent charge</p>	significant

	weight of at least 5 kilograms, as well as personal protective and rescue equipment of people	
120.	Availability in the premises of the pumping station of a general fire-fighting water supply scheme and a pump piping diagram. Indication on each valve and fire pump booster of their purpose	minor
121.	Providing power supply to the enterprise for uninterruptible power supply of electric motors of fire pumps	gross
122.	Availability of electrically driven valves on the bypass lines of water metering devices of external and internal fire-fighting water supply systems. Opening of valves from buttons installed in fire cabinets and interlocked with the launch of fire-fighting water supply booster pumps, if any. Checking the operability of electric valves installed on bypass lines of water metering devices - at least twice a year, and fire pumps - monthly	significant
123.	Providing pumping installations for fire-fighting purposes with manual and remote control, and for buildings over 50 meters high, cultural and entertainment institutions, conference rooms, assembly halls and for buildings equipped with sprinkler and deluge installations - with manual, automatic and remote control	gross
124.	Providing a signal to open the electrified valve on the water meter bypass line at the water supply inlet, simultaneously with the signal for the automatic or remote start of fire pumps, the opening of a fire hydrant, opening of a sprinkler or turning on (manual or automatic) of a deluge system	gross
125.	The adaptability of water towers for water extraction by fire equipment at any time of the year. Preventing the use of water reserves intended for fire extinguishing purposes for economic and production needs	significant
Requirements for the operation of fire automatic systems and installations		

126.	Maintaining fire automatics systems and installations in working condition through timely maintenance, inspection and scheduled maintenance by qualified facility specialists or organizations in the field of working with low-current equipment with paperwork	gross
127.	Availability of technical documentation at the facility equipped with fire automatic systems and installations.	minor
128.	Knowledge of the devices and principles of operation of fire automatic systems and installations installed at the facility by the facility's maintenance personnel or a qualified organization specialist in the field of working with low-current equipment	significant
129.	Carrying out a technical examination of fire automatic systems and installations after the expiration of the service life specified in the documentation for the technical device, as well as in cases of failure of these systems and installations	significant
130.	Availability of an independent electrical network of the first reliability category, starting from the input distribution device to the electricity consumer, for powering fire protection systems and emergency lighting	significant
Requirements for industrial enterprises		
131.	Availability at each enterprise of information on fire hazard indicators of substances and materials used in technological processes, and for buildings and premises the categories according to explosion and fire hazard	significant
132.	Preventing the joint use, storage and transportation of substances and materials that, when interacting with each other, cause ignition, explosion or form flammable and toxic gases (mixtures)	gross
133.	Carrying out work on cleaning the structure of exhaust devices (cabinets, painting, drying chambers), apparatus and pipelines using	minor

	fireproof methods according to the schedule approved by the head of the enterprise	
134.	Maintaining spark arresters, spark extinguishers, fire retardant, fireproof, dust and metal collection and anti-explosion devices of the static electricity protection system installed on process equipment and pipelines in working order	gross
135.	Taking samples of flammable and combustible liquids from tanks (containers) and measuring the level during daylight hours using devices that prevent sparking during impacts. Avoiding to carry out the specified sampling operations during a thunderstorm or the injection or pumping of product. Preventing the supply of flammable and combustible liquids into tanks (containers) by a "falling jet", as well as exceeding the speed of filling and emptying the tank of the total capacity of the breathing valves (ventilation pipes) installed on the tanks	gross
136.	Keeping doors and hatches of dust collection chambers and cyclones closed during their operation, timely removal of flammable waste collected in chambers and cyclones	significant
137.	Preventing the use of industrial buildings and warehouses on the premises of enterprises for residential purposes, as well as the placement of production workshops in warehouses	gross
138.	Preventing the storage of storerooms, equipment, and flammable materials in pedestrian tunnels and passages, the hanging of stands and posters made of flammable materials, as well as the laying of power cables, and pipelines transporting gases, acids, flammable and combustible liquids	gross
139.	Marking the boundaries of passages and walkways in workshops with markings	minor
	Preventing the laying of transit electrical networks through	

140.	warehouses and production facilities, as well as pipelines for transporting flammable gases, flammable and combustible liquids, and combustible dust	gross
141.	<p>Keeping production premises clean and preventing overload with equipment, raw materials and finished products exceeding the shift requirement - output, and in case of a round-the-clock production process - daily.</p> <p>Regulatory establishment for workshop storerooms of the permissible amount of simultaneous storage of flammable and combustible liquids and chemicals within the daily (shift) norm.</p> <p>Storing flammable and combustible liquids used in production in hermetically sealed metal containers and in quantities not exceeding the daily (shift) norm</p>	significant
142.	Protection of technological openings in walls and ceilings with fire-retarding devices	gross
143.	Maintaining the protective membranes of explosion safety valves on lines and adsorbers in good condition at all times	significant
144.	Availability in hydraulic systems using flammable fluid monitoring the oil level in the tank and preventing the oil pressure in the system from exceeding that specified in the passport	significant
145.	Equipping bunkers of crushed wood particles and forming machines with an aspiration system that maintains a vacuum in the container, and provision of sensors indicating their fullness	significant
146.	Equipping the drum dryer and dry chip and dust bins with automatic fire extinguishing installations and anti-explosion devices	significant
147.	Equipping the system for transporting chips and dust materials with devices that prevent the spread of fire and hatches for extinguishing fires	significant

148.	Equipping a container for collecting wood and explosive dust from aspiration and pneumatic transport systems with anti-explosion devices that are in working condition	significant
149.	Carrying out cleaning at least once a day from residual volatile resin emissions and wood pyrolysis products, dust and waste from heat treatment chambers for slabs. To remove explosive gases from the heat treatment chambers of particle boards, there shall be an automatic device for opening the exhaust pipe damper for 2-3 minutes every 15 minutes. Preventing heat treatment of under-pressed slabs with loose edges	significant
150.	Automatic temperature control in processing chambers and oil baths	significant
151.	Equipment of drying drums using flue gases with spark arresters	significant
152.	Equipping impregnating, hardening and other baths with flammable liquids with emergency drainage devices into underground containers located outside the building. Equipping each bath with local suction of flammable vapours	significant
153.	Equipping supply and exhaust channels of steam-air and gas chambers with special dampers (dampers) that close in the event of a fire	gross
154.	Equipping gas drying chambers with serviceable devices that automatically stop the flow of flue gases if ventilation stops	significant
155.	Installation of spark arresters in front of gas drying chambers to prevent sparks from entering the drying chambers	significant
156.	Preventing the operation of drying installations with cracks on the surface of the hogs and with non-functioning spark arresters	gross
157.	Equipping combustion and drying departments with working devices for monitoring the temperature of the drying agent	significant

158.	Equipping drying chambers with devices that turn off heater fans when a fire occurs in the chamber and include stationary fire extinguishing means	gross
159.	Equipping drying chambers (rooms, cabinets) for raw materials, semi-finished products and painted finished products with automatic heating shutdown when the temperature exceeds the permissible limit	significant
160.	Storing quicklime in special rooms of at least II degree of fire resistance, the floor of which provides a distance above the ground of at least 0.5 meters	significant
161.	Maintaining the lining of blast furnaces, steel-smelting furnaces, converters, mixers, ladles and other containers for molten metal in good condition	significant
162.	Protection of entrances to cable tunnels, oil cellars located close to spill sites, as well as at places of transportation of molten metal, from the ingress of molten metal by fire-resistant thresholds with a height of at least 300 millimetres	significant
163.	Protection of cables of electric mechanisms, electrical equipment and hydraulic drive devices at places of metal spills, slag and in areas of elevated temperatures from mechanical damage, exposure to radiant heat, as well as from splashes of molten metal and slag.	significant
164.	Providing the flue pit and areas for research work with two exits	gross
165.	Equipping blast furnaces with casing temperature monitoring devices over the entire height and area of the furnace	significant
166.	Preventing storage of materials and production waste near the foundations of blast furnaces	minor
167.	Equipment for monitoring burnout of air tuyeres using signalling devices. Avoidance of work on burnt-out tuyere devices	significant

168.	Preventing the storage of equipment and storage of materials (including flammable materials) in places where molten metal and slag may enter	significant
169.	Preventing the placement of fuel oil supply tanks under the furnaces, placing the tanks at a distance of at least 5 meters from the furnaces and reliable protection with special heat shields	significant
170.	Connection of supply tanks with closed drain and overflow pipelines with emergency tanks for draining fuel oil in case of fire	gross
171.	Preventing the converter from operating if there is a leak of converter gases in the cooler and cooling hot spots on the converter casing with molten metal with water	gross
172.	Preventing the use of flammable liquids for igniting gas when placing steel-smelting furnaces, converters, and mixers for drying	gross
173.	Preventing the use of open fire in places of storage, preparation and preparation of fire-explosive materials and mixtures based on them	gross
174.	Preventing the combined transportation and storage of aluminium-magnesium, aluminium-barium and aluminium powders with saltpetre, acids, alkalis and oxidizing agents, as well as flammable materials	significant
175.	Preventing placement of a bunker with flammable charge materials under the trolleys of charge cranes	significant
176.	Providing furnace transformers with fire extinguishing means and emergency oil receivers designed for the full volume of oil in the transformer	significant
177.	Equipping vacuum chambers of induction and vacuum arc furnaces, as well as melting chambers of electron beam furnaces with explosion safety valves	gross
	Preventing the operation of systems for removing dust and gas emissions	

178.	from electric furnaces and ore reduction furnaces that are not equipped with devices that prevent fires, explosions of gases and dust	significant
179.	Equipping bunkers and chambers for spraying liquid aluminium with shutters that prevent hot powder from entering the conveyor belt during the spraying process	significant
180.	In order to avoid oxidation, spontaneous combustion and the explosion of aluminium powder, avoiding the presence of moisture and dampness in the places of its production and storage	significant
181.	Preventing the construction of basements, underground channels and pits in premises for the production of powders and dust from aluminium, magnesium and alloys based on them	significant
182.	Preventing joint storage and transportation of barium-aluminium and aluminium powders with saltpeter, acids, alkalis, oxidizing agents and flammable substances	significant
183.	Storing flammable materials or materials that promote rapid combustion (magnesium shavings and magnesium alloys, saltpeter, bertholet salt, thermite mixture) in specially designated areas of the smelting body of metallothermic shops in closed metal containers (cans, barrels) in quantities not exceeding two-day requirements	significant
184.	Equipping bunkers for storing spontaneously combustible materials with devices for controlling the temperature of these materials, the operation of which is interlocked with the launch of fire extinguishing means	significant
185.	Equipping hydraulic drive systems with a device for automatically shutting off pressure valves in the event of an oil line break	significant
186.	Preventing the use of open flame sources and sparks in oil basements and near oil-filled equipment during the operation of oil facilities	gross

187.	Keeping oil cellars and cable tunnels closed to prevent scale, sparks and ignition sources from entering them from work sites	significant
188.	Ensuring, in the event of a fire, automatic shutdown of ventilation devices of tunnels and oil cellars	gross
189.	Providing, in case of fire, baths for depreservation of bearing units, as well as fuel oil supply tanks, with emergency tanks for draining flammable liquids, which are located outside the workshop building	gross
190.	Maintaining process automation in good condition to prevent the creation of explosive concentrations in areas using protective explosive gases	gross
191.	When heat-treating metal (continuous annealing of the strip), preventing using a bath of molten sodium without a protective gas. Preventing water or wet materials from entering the sodium bath	gross
192.	Preventing the storage of sawdust, shavings and waste of titanium and its alloys in workplaces. Storing containers labelled "Titanium waste" in a specially designated dry room with constant ventilation	significant
193.	Preventing using open flames, open electric coils or surfaces with temperatures above 100°C to heat the mixture and dissolve paraffin and stearin in kerosene	gross
194.	Preventing work from being carried out in areas where the kerosene-stearine mixture is prepared and used without the availability of fire extinguishers	significant
195.	Preventing spills of kerosene-stearine mixture and collection of waste kerosene-stearine mixture at workplaces during additional pressing of products	significant
196.	Preventing the use of flammable (explosive) gases as fuel and reducing media	gross
197.	Providing paint preparation departments of paint shops (areas)	gross

	with independent access to the outside	
198.	Making floors in rooms where paint and varnish preparation, painting and gas washing works are carried out, from non-flammable materials that do not generate sparks upon impact	significant
199.	Cladding the internal surfaces of the walls of premises at a height of at least 2 meters with non-flammable, easily cleaned material	gross
200.	Opening all doors of the workshop, site, and installations opening outwards or towards the nearest exits from the building	gross
201.	Carrying out painting work and washing parts only with active supply and exhaust ventilation with local suction from paint cabinets, baths, chambers and cabins. Blocking the operation of installations, as well as supply systems for painting, washing, varnishing, washing and degreasing operations using nitro-based coatings, gasoline and flammable liquids with a ventilation system	significant
202.	Preventing the operation of exhaust ventilation of paint cabinets, chambers and cabins without water sprinklers (hydraulic filters) or other effective devices for trapping particles of flammable paints and varnishes	significant
203.	Preventing the use of fire to burn off paint deposits in cabins and air ducts	gross
204.	Application of non-flammable compounds, pastes, solvents and fire-safe technical detergents for washing and degreasing products and parts	significant
205.	Storing caustic soda, nitrate, and additives in a specially equipped room	significant
206.	Providing acid storage areas with ready-made solutions of chalk, lime or soda for immediate neutralization of accidentally spilt acids	minor
207.	Storing containers for paint and varnish materials tightly closed and in special areas located at a distance	significant

	of at least 20 meters from buildings and structures	
208.	Equipping racks for laying pipes and products after oiling with devices for drainage and removal of oil with its subsequent pumping	significant
209.2	Availability of at least two gas analyzers of refrigerant vapours, which are interlocked with supply and exhaust ventilation and compressor shutdown devices in the machine and equipment rooms of ammonia refrigeration units	gross
210.	Ensuring the storage of cylinders with refrigerants (ammonia) in special warehouses. Prevent their storage in engine rooms. Preventing the placement of communications with refrigerant in evacuation corridors and passages, staircases, and elevator shafts, as well as their transit through fire and explosion hazardous areas	significant
211.	Placing ammonia cylinders at a distance of at least 10 meters from open sources of fire and no closer than 5 meters from heating devices	significant
212.	Availability in the premises of ammonia refrigeration units of internal fire hydrants with spray barrels that allow receiving atomized water	gross
213.	Preventing the replacement of non-flammable thermal insulation of pipelines with refrigerants with flammable ones	gross
214.	Separation of the ventilation systems of the engine and equipment rooms from the ventilation systems of the premises	gross
215.	Maintaining explosion-proof electrical equipment in mechanical and equipment rooms of ammonia refrigeration units in technically good condition	gross
216.	Preventing the replacement of easily removable elements (panels, windows, doors) during the operation of the machinery and equipment rooms of ammonia refrigeration units.	gross

217.	Preventing the installation of devices or equipment in the premises of compressor rooms that are not structurally or technologically related to compressors, as well as the arrangement of workplaces, office and storage rooms	significant
218.	Preventing changes to existing refrigerant piping layouts	significant
Requirements for automobile enterprises, transport service facilities, parking areas (parking lots)		
219.	Compliance with the requirements for minor repairs and routine maintenance of vehicles in open parking areas on hard-surfaced areas	minor
220.	Availability at each site for minor repairs and routine maintenance of vehicles a fire shield with a set of fire-fighting equipment	significant
221.	Preventing the cluttering of garages, parking lots and open storage areas for vehicles with objects and equipment that may impede their evacuation in the event of a fire or emergency.	significant
222.	Preventing the use of garages, premises in parking buildings, parking lots and open parking lots for purposes other than their intended purpose (storage of flammable materials, gas cylinders, the establishment of repair shops, painting booths, premises, living rooms)	minor
223.	Preventing the conversion of closed parking buildings (built-in, attached, underground, free-standing) or the use of individual boxes and parking spaces intended for storing cars as premises for repair work and storage of substances and materials	gross
224.	Availability of water or air heating in vehicle storage areas, combined with forced ventilation	gross
225.	Availability of diagrams for the placement of vehicles and indicators of vehicle routes to evacuation exits in garages, boxes, parking lots and open storage areas for vehicles (except for individual ones)	minor
	Preventing parking of vehicles equipped with gas-cylinder	

226.	equipment, the engines of which run on compressed natural gas and liquefied petroleum gas, in built-in buildings for other purposes and attached to them, as well as parking lots located below ground level and closed premises and parking lots	gross
227.	Preventing the construction and (or) placement of premises for other functional purposes not provided for in the design documentation in parking lots in closed parking lots. Preventing storage of flammable, explosive substances and materials, flammable and combustible liquids, oils, flammable gas cylinders, and pressure cylinders in utility storerooms and customer luggage storage rooms	gross
228.	Placement of utility storage rooms and storage rooms for customer luggage only on the first (landing) floor of the parking lot, for underground parking lots of passenger cars not lower than the first (upper) underground floor of the building. Preventing the storage of flammable materials outside utility storerooms and customer luggage storage rooms	gross
229.	Preventing the installation of vehicles in quantities exceeding the norm of the layout plan, reducing the distance between cars and buildings (structures)	significant
230.	Avoiding obstruction of exit gates and driveways, performing forging, thermal, welding, painting and woodworking work, as well as washing parts using flammable and combustible liquids	gross
231.	Preventing the leaving vehicles with open fuel fillers, leaking fuel tanks, fuel lines, carburetors, or faulty electrical systems.	gross
232.	Preventing the filling of vehicles with fuels and lubricants, as well as discharging them into the drainage system or the adjacent territory. Collection of used fuels and lubricants, filters, and rags shall be provided in containers made of	significant

	non-flammable materials equipped with lockable lids	
233.	Preventing recharging batteries directly on vehicles, as well as in premises unsuitable for these purposes	significant
234.	Preventing heating engines with open fire (bonfires, torches, blowtorches, gas burners), use open fire sources for lighting	gross
235.	Preventing the installation of vehicles for the transport of flammable and combustible liquids, as well as combustible gases, in public parking areas	significant
236.	Preventing storing containers containing flammable and combustible liquids	significant
237.	Preventing painting vehicles and washing parts with flammable and combustible liquids	gross
238.	Preventing the release of liquefied petroleum gas in premises intended for storing vehicles	gross
239.	Maintaining in good condition systems related to monitoring pressure, gas production, engine heating, switching to different types of fuel and gas supply to the carburettor-mixer. Operation in good condition of safety valves on cylinders with liquefied petroleum gas, as well as solenoid valves that block the fuel supply. Inspection of cylinders at least once every 2 years	gross
240.	Preventing the use and storage of liquefied petroleum gas in parking lots, closed parking garages and heated rooms where the air temperature exceeds 25 °C	gross
241.	Equipping parking lots, parking spaces and open storage areas for vehicles (except for individual vehicles) with towing ropes and rods , at the rate of 1 rope (rod) per 10 units of equipment	significant
242.	Preventing the storage of furniture, and household items made of flammable materials, as well as fuel	gross

	reserves of more than 20 litres and oil reserves of more than 5 litres in private garages	
243.	Preventing repairing vehicles with tanks filled with fuel (and for gas vehicles with gas cylinders) and crankcases filled with oil in vehicle repair rooms and utility rooms.	significant
244.	Avoiding smoking, lighting fires, and using electric heating devices.	gross
245.	Preventing the storage of acids, alkalis or electrolytes in quantities exceeding the one-shift requirement	minor
246.	Preventing leaving special clothing and foreign objects at workplaces	minor
247.	Preventing the placement of washing and painting shops in the basements, basements and first floors of multi-storey buildings	gross
248.	Making the floors of washing and painting shops, as well as paint preparation departments, non-flammable, electrically conductive, resistant to solvents, eliminating sparking	significant
249.	Availability of cladding with non-combustible material to a height of at least 2 meters of the internal surfaces of the walls of washing and painting shops	significant
250.	Equipping the premises of washing and painting shops, paint laboratories and paint preparation departments with independent mechanical supply and exhaust ventilation and local exhaust ventilation from painting booths, dipping baths, spray installations, manual painting stations, drying chambers, and areas for washing and degreasing surfaces. Availability of automatic gas analyzers in the specified premises	gross
251.	Preventing the use of finned radiators in washing and painting shops	significant
252.	Installation of electric starting devices, push-button electromagnetic starters outside washing and painting rooms	significant

253.	Equipment with protective devices for mobile technological equipment of washing, painting shops and paint preparation departments (ladders, stepladders, boards, carts)	significant
254.	Preventing workers and employees from wearing clothing made of synthetic materials and silk, as well as rings and bracelets	minor
255.	Providing workers with conductive shoes and antistatic wristbands	minor
256.	Making shelving at railway transport facilities in hand luggage storage rooms and luggage compartments only from non-flammable materials. Preventing the construction of mezzanines	gross
Requirements for administrative buildings (multifunctional complexes), multi-apartment (individual) residential buildings and dormitories		
257.	In buildings with a height of more than 28 meters, avoiding cluttering areas intended for the installation and turning of aerial ladders or articulated lifts	gross
258.	In buildings over 28 meters high, it shall be prohibited to install doorways in solid partitions and walls separating smoke-free stairwells from rooms, passages, and basements, as well as openings in load-bearing walls.	gross
259.	Preventing painting, whitewashing, covering, and insulating automatic fire detectors and sprinklers in buildings over 28 meters high	significant
260.	Preventing finishing fencing of balconies and loggias with flammable materials in buildings over 28 meters high	gross
261.	Preventing the establishment of various types of workshops and warehouses in apartments of residential buildings and dormitories where explosive and fire-hazardous substances and materials are used and stored	gross
262.	Equipment in dormitories (except for residential premises) of designated smoking areas with "Smoking area" signs, bins or ashtrays made of non-flammable materials	minor

263.	Preventing the de-energization of system control panels in buildings over 28 meters high after acceptance of the smoke protection system	gross
264.	Preventing the operation of a newly constructed building in buildings with a height of more than 28 meters until the fire protection systems are installed	gross
265.	Preventing the storage of flammable, combustible liquids, explosives, and gas cylinders on balconies and loggias in apartments and living rooms	gross
Requirements for automobile filling and gas filling stations (stationary and mobile) (hereinafter referred to as Gas stations, Fuel stations)		
266.	Equipping gas and gas filling station buildings with central heating systems. Application of factory-made electric oil heating devices in the premises of gas and gas filling stations that meet fire safety requirements, observing the required distances to combustible structures and materials. Preventing the use of heating installations and devices using open fire on the territory and in the buildings of gas stations and gas filling stations	significant
267.	Availability on the doors of all premises of gas stations, and fuel stations, as well as on external installations of inscriptions indicating: 1) categories of premises according to explosion and fire hazard; 2) class of explosive or fire-hazardous areas; 3) surnames and initials of the employee responsible for fire safety; 4) telephone numbers for calling fire departments	minor
268.	Availability of a rigid tow bar, at least 3 meters long, for emergency evacuation of a burning vehicle from the territory of a gas station or gas station	significant
	Availability of a clearing not less than 4 meters wide along the borders	

269.	of gas stations, and fuel stations, when located near crops, forests and steppes	significant
270.	Preventing the landscaping of the territory of gas stations and fuel stations with shrubs and trees that produce flakes, fibrous substances or pubescent seeds during flowering	significant
271.	Preventing filling household gas cylinders at gas stations	gross
272.	Making of non-combustible materials canopies over technological equipment and gas stations. Avoiding installation of canopies with unventilated volumes (sinuses, pockets)	significant
273.	Preventing the operation of technological equipment: 1) in the presence of fuel leaks; 2) in the absence, malfunction, shutdown or overdue checks of control and regulation devices; 3) if there are any malfunctions	gross
274.	Preventing the laying of transit utility networks through the territory of gas stations and fuel stations	gross
275.	Prevention of making design changes to process equipment that increases the degree of fire hazard at gas stations and fuel stations	gross
276.	Sealing of control and measuring instruments and marking with maximum permissible parameters (pressure, temperature, concentration, filling level) ensuring fire-safe operation of process equipment. Ensuring automatic delivery of warning (light or sound) signals when one of the parameters deviates from acceptable limits	significant
277.	Availability of static electricity protection for main and auxiliary process equipment	gross
278.	Availability of non-sparking gaskets and resistant ones to the effects of petroleum products and the environment covers and nozzles of flanges, pipes, fittings and devices separating fuel and its vapours from the atmosphere, in places of contact with fittings. The design of the	gross

	specified covers and plugs, which are designed to be opened during operation, shall be made of non-sparking material	
279.	Availability of deaeration lines in fuel storage tanks. Equipping deaeration line pipelines with fire arresters or breathing valves with built-in fire arresters that remain operational at any time of the year	gross
280.	Equipping tanks for underground fuel storage with systems for monitoring their tightness	gross
281.	Equipping pumps for filling tanks with manual power switches located in the control room	gross
282.	Ensuring fuel drainage from tank trucks in a closed circuit	gross
283.	Ensuring the removal of all vehicles and unauthorized persons from the territory of the gas station when tank trucks with fuel enter it. Preventing two or more tank trucks at a gas station at the same time	minor
284.	Provision for carrying out the operation of draining fuel from tank trucks into the tanks of a gas station: 1) a mobile powder fire extinguisher with a volume of at least 100 litres; 2) an emergency tank for removing fuel spills and atmospheric precipitation contaminated with petroleum products; 3) grounding devices for each tanker	significant
285.	Avoiding connecting grounding conductors to painted and contaminated metal parts of tank trucks	significant
286.	Preventing refuelling vehicles with running engines	gross
287.	Preventing the passage of vehicles over underground tanks, unless this is provided for in the agreed and approved technical conditions and technical and operational documentation for the technological system used	significant
288.	Preventing filling tanks with fuel and distributing fuel to consumers during a thunderstorm and the danger of atmospheric discharges	gross

289.	Preventing the entry of tractors not equipped with spark arresters into the territory of a gas station where operations for receiving, storing or dispensing gasoline are carried out	gross
290.	Preventing carrying out repair work not directly related to the repair of equipment, buildings and structures of the gas station	significant
291.	Preventing refuelling vehicles with passengers (except for passenger cars with at least four doors)	significant
292.	Preventing the entry of vehicles loaded with explosives, compressed and liquefied flammable gases, flammable and combustible liquids, flammable materials, toxic and radioactive substances and other dangerous substances and materials	gross
293.	Placement of mobile gas stations in specially designated areas	significant
294.	Carrying out activities before the start of operation of mobile gas stations at a specially designated site : 1) checking the tightness of the station using instrumentation and visual; 2) connecting the grounding conductors of gas stations to the site grounding device; 3) installing a tray under the fuel tank of the vehicle; 4) installation of barriers limiting the access of vehicles to the gas station by at least 1 meter; 5) installation of a warning sign and information board	significant
Requirements for subways		
295.	Availability of an operational fire extinguishing plan, a passenger evacuation plan, and a procedure for subway workers when operating tunnel ventilation shafts in the event of smoke or fire	significant
296.	Preventing the use of flammable materials for cladding walls and ceilings of escape routes (corridors, staircases, lobbies, halls), as well as	gross

	for advertising in the decoration of underground premises and station lobbies	
297.	Use of wardrobes installed in the underground space of subways only from non-combustible materials	significant
298.	Preventing storing more than two gas cylinders with a capacity of more than 5 litres each outside a specially designated area in underground structures	significant
299.	Carrying out gas welding and electric welding work in existing tunnels only from special units installed on mobile vehicles	gross
300.	Preventing the placement of more than 30 subway employees in technical classrooms located in underground spaces for training purposes	gross
301.	Preventing the storage of spare parts and materials in machine rooms, escalators and dismantling chambers	gross
302.	Installation of trade kiosks only in ground-based station vestibules. Making kiosks from non-combustible materials. Placement of trade kiosks in such a way that they do not obstruct the passage of passengers	gross
303.	Application of oil electric radiators or heating electric panels for heating kiosks	significant
304.	Equipping kiosks with primary fire extinguishing means and automatic fire alarms with signal output to the premises with round-the-clock presence of on-duty personnel	gross
305.	Preventing trade and use of flammable and combustible liquids, flammable gases, goods in aerosol packaging, pyrotechnic products, flammable materials	gross
306.	Preventing the storage of goods, packaging material, and trade equipment on station premises	significant
Requirements for tourist centres, guest houses, holiday homes, boarding houses, health camps, summer vacation spots for children		

307.	Preventing the placement of children's health camps in wooden buildings above the 1st floor	significant
308.	Availability of non-combustible roofing and insulation, as well as plastering of the frame and panel buildings of children's health camps	gross
309.	Preventing the building from being covered with flammable materials, including straw, wood chips, reeds, and roofing felt.	gross
310.	Preventing the installation of kitchens and laundries in wooden buildings occupied by children	significant
311.	Preventing the placement of more than 50 children in buildings and structures of IV and V fire resistance degrees	gross
312.	Avoiding heating stoves and using kerosene and electric heating devices in rooms occupied by children in the summer	gross
313.	Placement of laundries and kitchens in children's summer recreation areas and health camps in separate buildings at a distance of at least 15 meters from wooden buildings in which children are accommodated	gross
314.	Preventing accommodation of children in summer recreation areas and health camps that are not provided with an external fire-fighting water supply	significant
315.	Providing summer recreation areas for children and summer health camps with an alarm signal in case of fire and primary fire extinguishing equipment. Presence of 24-hour service personnel	significant
316.	Availability of mineralized firebreaks with a width of at least 4 meters along the perimeter of the territory of sanatoriums, rest homes and health institutions (including summer cottages for children, and children's health camps) located in forests and steppe areas	significant
	Availability in the children's camp of a plan of organizational and technical measures to ensure fire safety and a diagram of the camp (

317.	base), which shall indicate all buildings, places of residence (residential buildings, tents), places of economic purpose, sources of external fire-fighting water supply, and parking lots. Placing a diagram at the entrance to the camp (base) territory	minor
318.	Construction of tents (yurts) on the territory of children's summer recreation areas and health camps; the area of the territory occupied by one group (1 or 2 rows) shall be accepted to be no more than 800 square meters. Ensuring a distance between groups of at least 15 meters and between tents (yurts) - of at least 2.5 meters	minor
Requirements for cultural and entertainment, entertainment and sports institutions		
319.	Connection in rows with each other and strong fastening to the floor of all seats and chairs in auditoriums and the stands (except for the availability of an independent exit from the box with a number of seats of no more than 12, as well as in auditoriums used for dance evenings with a number of seats of no more than 200 when they are connected in a row with each other)	significant
320.	Carrying out deep impregnation with fire retardants of wooden structures of the stage frame (grids, stage flooring, suspension bridges, working galleries) during the construction process. Ensuring periodic processing of these structures, as well as flammable decorations, stage and exhibition designs, draperies in auditoriums and exhibition halls, foyers, buffets	gross
321.	Preventing the simultaneous presence of scenery and stage equipment for no more than two performances within the stage box of theatrical and entertainment institutions. Marking with signs the places where stage decorations are stored. Preventing the storage of scenery, props, wooden machines, slopes, equipment and property in holds, on grates and work platforms (galleries), under flights of stairs and	significant

	landings, as well as in basements under auditoriums	
322.	When designing productions, ensure that there is a free circular passage at least 1 meter wide around the stage board	significant
323.	Prevention of smoking, open flames, arc lights, fireworks or fire effects on stage	gross
324.	Preventing the construction of temporary seats for spectators (retractable, removable, collapsible), as well as preventing the construction of seats from synthetic materials that emit highly dangerous and extremely dangerous combustion products during combustion in the stands, indoor and outdoor sports facilities	significant
325.	Preventing the installation of side seats on escape routes	gross
326.	Making removable seats designed to place a background in the stands during sports and artistic festivals, the opening and closing of international competitions or international events, as well as cultural and entertainment events	gross
327.	Preventing the arrangement of seats for spectators in sports halls that create counter or intersecting flows of spectators from permanent and temporary stands	gross
328.	Maintaining in good condition devices for fastening temporary structures for seating spectators in indoor sports facilities, as well as fastening platforms, stages and rings	gross
329.	Ensuring the stacking of flammable sports equipment, prefabricated hall structures, removable hall coverings, materials during non-rack storage in stacks with an area of no more than 100 square meters, a height of 2.5 meters and no more than 2.5 meters below the load-bearing structures of the floor or covering 0.5 meters, with a width passage between stacks; stacks and walls - 0.8 meters (except for passages opposite doorways, made along the width of the door)	significant

330.	Preventing the storage of flammable materials in sports halls, as well as the arrangement of rooms with structures made of flammable materials directly under the fastening points of metal and wooden load-bearing structures	significant
331.	Ensuring that block-generating lasers are installed at a distance of no closer than 1 meter from the surfaces of combustible structures and decorations in equipment rooms on bases made of non-combustible materials when used for staging or illumination lighting of laser installations	significant
332.	Ensuring the laying of non-flammable material 8-10 millimetres thick between the wooden ramp of the platform (stage) and the casings of electric lights, protection with non-flammable materials on the outside of all portable electric lights (backlights) installed on the stage or platform	significant
333.	Ensuring that all soffits are installed on the light side of a protective metal mesh to prevent falling out glass lamps and fragments of ruptured lamp bulbs	significant
Requirements for religious buildings (structures)		
334.	Installation of candlesticks, lamps and lighting equipment using open fire on non-combustible bases in a stable position to prevent them from tipping over	gross
335.	Preventing the use of open flame sources for services and rituals at a distance of less than 0.5 meters from room and interior decoration, clothing and items made of flammable materials	gross
336.	Preventing the use of lamps using open flames with damaged glass bulbs, as well as the use of flammable liquids when refilling them	gross
337.	Storing flammable liquids for refilling lampadas, lamps and similar devices in closed, unbreakable containers in metal cabinets with a capacity of no more than 2 litres	significant

Requirements for oil and gas production and oil and gas refining industry facilities

338.	Availability of fencing of the territory of oil depots, loading and pumping stations with a ventilated fence made of non-combustible material with a height of at least 2 meters	minor
339.	Preventing the planting of trees and shrubs in the dikes of tanks	minor
340.	Preventing making fires, burning garbage, and waste, using torches, kerosene lanterns, and sources of open fire on the premises	gross
341.	Cleaning the area allocated for installation, clearing of above-ground and underground pipelines, and cables, clearing of trees, bushes, grass	significant
342.	Availability of a 10-12 meter wide area around ground structures for the movement of vehicles and firefighting equipment	significant
343.	Availability of liquid drainage from the mouth and ground structures into special barns (traps). Placement of fuel tanks and installations no closer than 20 meters from ground premises, equipment, and pipelines. Equipping fuel installations with pumps, tanks - level gauges, warning and prohibitory inscriptions (signs)	significant
344.	Preventing the use of flexible hoses in explosive process systems	significant
345.	Placement of fire extinguishing equipment near fire-hazardous areas (power and pumping unit, fuel installation, power plant)	minor
346.	Availability of access roads and embankments at installation sites based on the storage volume of fuels and lubricants	significant
347.	Availability of shut-off, shut-off and safety devices on the suction and discharge lines of pumps and compressors pumping flammable products	significant
348.	Preventing the storage of fuels, lubricants and flammable materials inside fire and explosion hazardous structures	gross

349.	Exit exhaust lines of internal combustion engines at a distance of at least 15 meters from the wellhead, 5 meters from the wall of the shelter (base) and 1.5 meters from the top of the roof (canopy)	gross
350.	Availability of a gap of at least three pipe diameters in places where the exhaust line passes through walls, shelters, and roofs (canopies). Availability of heat-insulating gasket and non-flammable cutting	significant
351.	Equipping exhaust pipes with spark arresters	significant
352.	Preventing the use of open fire and smoking in fire and explosive areas, under foundations, gas hazardous areas, near containers for storing fuels and lubricants, petroleum products, flammable substances and reagents	gross
353.	Preventing hazardous gas, fire and welding work in the presence of gas contamination, contamination with fuels and lubricants, and oil products	gross
354.	Constant maintenance of power, drilling and oilfield equipment, shelters, wellheads and areas of the facility in a fire-safe condition, regular protection against oil contamination, spills of fuels and lubricants, petroleum products	significant
355.	Use of special equipment used for cementing, installation of oil and acid baths, research and emergency work in the presence of spark arresters for exhaust pipes	gross
356.	Installation of a mobile compressor during well development at a distance of at least 25 meters from the well on the windward side	significant
357.	When flushing a well with oil, install the unit at a distance of at least 10 meters from the mouth	significant
358.	Preventing the development of gas and gas condensate wells by swabbing, and of flowing wells by tarting with a bailer	significant
	When developing wells with mobile units, ensure the possibility of connecting the required number of	

359.	units to the working manifold, both for development and in case of killing the well	significant
360.	Avoiding the release of oil drainage devices into common barns and traps through open ditches to avoid ignition (fire)	significant
361.	Availability of check valves on the lines from the gas and air distribution booths at the wells, installed to prevent oil and gas from entering the compressor from the well	significant
362.	Availability on the outside of the gas distribution booths of the inscription "Gas! Flammable!"	minor
363.	Equipping exhaust pipes of internal combustion engines of mobile compressors with a muffler with a spark arrester	significant
364.	Availability of a safety device on the flow line of the last compression stage of the compressor (outside the compressor building) that is triggered at a pressure exceeding the operating pressure by 10%	significant
365.	Equipping the compressor with an alarm for deviation of parameters from normal operation, as well as automatic shutdown when the pressure and temperature of the burned gas (air) increases, when the supply of cooling water is stopped and the pressure drops at the intake and in the lubrication system	significant
366.	Preventing the placement in gas compressor rooms of inventory and equipment not related to the operation of the compressor unit	significant
367.	Preventing air intake for air compressors in areas where flammable vapours or gases are emitted, as well as in areas where ignition sources may appear.	significant
368.	Providing access for inspection of grounding conductors and their welding points	significant
369.	Preventing the use of steel rope for the grounding conductor	significant
	Preventing the installation of control stations, autotransformers, and	

370.	transformers under power line wires of any voltage	significant
371.	Arrangement of premises or booths for installation of electrical equipment for submersible centrifugal electric pumps made of non-flammable material	significant
372.	Availability of a plan for the elimination of possible accidents and fires, developed and posted in a visible place, taking into account the implementation of production intensification methods	minor
373.	Providing facilities where production intensification methods are carried out with reliable telephone or radio communication with the central control centre of the enterprise	significant
374.	Availability of signs posted at communication facilities indicating the names and order of signalling, calling managers, fire service, ambulance, gas rescue service	minor
375.	Preventing the drainage of residual oil and chemicals from the tanks of units and tank trucks into the industrial drainage system	significant
376.	Preventing the use of fire-fighting inventory and equipment, emergency and gas rescue equipment for work not related to their direct purpose	minor
377.	Availability of the inscription "Flammable" on containers with flammable chemicals	minor
378.	Preventing loading and draining of foam reagents and flammable chemicals during a thunderstorm	gross
379.	The location of mobile technological equipment for pumping the reagent into the formation, taking into account the terrain and wind direction, to ensure, if necessary, its exit from the danger zone and the evacuation of personnel	significant
380.	Preventing the location of mobile equipment and pumping units within the security zone of overhead power lines or above oil and gas pipelines	significant
	Equipping the furnace with automatic devices that regulate the temperature of heated oil within	

381.	specified limits, as well as turning off the gas supply to the burners when the gas pressure specified by the manufacturer increases or decreases	significant
382.	Equipping the fuel pipeline with an adjusted reducing device and a safety valve in the burner, as well as a device to prevent condensate from entering control instruments	gross
383.	Equipping technical vehicles (cars, tractors) with spark arresters	gross
384.	Installing a container with hot oil no closer than 10 meters from the mouth on the leeward side	significant
385.	Installation of compressors and electrical equipment at a distance of no closer than 10 meters, and a compressor with an internal combustion engine - no closer than 25 meters from the wellhead. Equipping the exhaust pipe of an internal combustion engine with a spark arrester	significant
386.	Availability of an inscription or sign "Flammable" on tank trucks or other containers containing gas condensate	minor
387.	To drain or fill condensate, providing tank trucks with grounding devices	significant
388.	Installation of units and tank trucks no closer than 25 meters from the wellhead and at least 6 meters from each other on the windward side	significant
389.	Supplying the territory of the site where the formation is processed using the method of intra-formational moving combustion front, with warning posters and fencing with metal pickets with a red flag	significant
390.	Using non-combustible materials for thermal insulation of equipment	gross
391.	Equipping ladders, separators and apparatus with ladders and platforms for maintenance	significant
392.	Construction of oil and sand traps from non-flammable material. Availability of a fence around the open oil trap with a height of at least 1 meter	significant

393.	Preventing malfunction of devices designed to drain oil in case of an accident or fire. Marking the valves of emergency drain lines with identification marks, clearing the approaches to them	gross
394.	Equipping pump rooms for pumping oil with forced supply and exhaust ventilation in a spark-proof design	gross
395.	Preventing pumps from starting up when ventilation is faulty or turned off	gross
396.	Separation of rooms for housing internal combustion engines from rooms for pumps by gas-tight walls	gross
397.	Preventing the use of flat belt drives in areas where pumps for flammable liquids are installed	gross
398.	Preventing the accumulation of lubricants under pumps, spreading and splashing. Keeping pump house floors clean and regularly rinsing them with water	gross
399.	Storing lubricants in pump rooms in quantities not exceeding daily requirements, in special metal barrels or boxes with lids	significant
400.	Preventing storing flammable and combustible liquids in the pump room	significant
401.	Preventing driving through when purging and testing the pipeline, being within the adhesion zone of cars, and tractors with running engines, as well as using open fire and smoking	significant
402.	Separation of rooms for housing internal combustion engines from rooms for pumps by gas-tight fireproof walls	gross
403.	Preventing the accumulation of petroleum products. Equipping pumping rooms with water risers with rubber hoses for removing spilt oil products	significant
404.	Maintenance of working and evacuation ladders, as well as winches installed at the end of railway trestle dead ends, in good condition	gross

405.	Providing operational sites for loading devices on overpasses with a hard surface and unhindered flow of various liquids through a hydraulic seal into the industrial stormwater drainage system or a special collection tank	significant
406.	Availability of the permissible number of machines established by the enterprise administration that are simultaneously on the operational site	minor
407.	Availability of a cable or rod on the loading rack for towing tank trucks in case of fire	significant
408.	Availability of signal signs - control posts on both sides of drainage and loading devices or stand-alone risers on the railway tracks (at a distance of two two-axle or one four-axle cars), behind which diesel locomotives are not allowed to enter	minor
409.	Equipping transition bridges on a railway loading and loading rack for flammable petroleum products with wooden pads with countersunk bolts or materials that prevent sparking	significant
410.	Availability of grounding of railway tracks, overpasses, pipelines, telescopic pipes and hose tips. Checking the resistance of grounding devices at least once a year.	significant
411.	Preventing the passage of vehicles into the territory of the plant, the technological process of which involves the accumulation of flammable vapours and gases, while installing prohibitory signs	gross
412.	Preventing persons wearing shoes lined with metal nails or horseshoes from entering hazardous areas and gas hazardous areas	significant
413.	Preventing the use of transport trolleys whose wheels cause sparks upon impact in explosive workshops of categories A and B. Maintenance of inspection wells of the drainage system with permanently closed lids, which are covered with sand in a layer of 10 centimetres	gross

414.	Installing the hydraulic valves in special wells (the layer of water forming the valve must be at least 0.25 meters high in each hydraulic valve) to prevent the spread of fire through the industrial drainage network during a fire	gross
415.	Installing hydraulic valves at all outlets from rooms with technological equipment, platforms of technological installations, groups and free-standing tanks, valve units, groups of devices, pumping, boiler rooms, and unloading racks	gross
416.	Preventing the operation of the drainage system with faulty or incorrectly installed hydraulic valves, as well as without them	gross
417.	Preventing the release of fire and explosive products into drainage systems. Availability of special containers for these purposes	significant
418.	Availability of grounding of metal blowers of ventilation systems installed in explosive industrial premises	gross
419.	Preventing equipment from operating with faulty ventilation	significant
420.	Ensuring round-the-clock operation of ventilation in enclosed spaces containing equipment and communications containing flammable and explosive gases	significant
421.	Availability of mechanical emergency ventilation in industrial premises where the sudden intense release of harmful or explosive gases or vapours is possible	significant
422.	Ensuring the automatic start of emergency mechanical ventilation under the influence of gas analyzer sensors and the availability of remote start of emergency ventilation from buttons located at the outer door of the production room	significant
423.	Availability of grounding of loading risers of trestles for filling railway tanks. Electrical connection of railway rails within the loading front to each other and connection to a	significant

	grounding device not connected to the grounding of the electric traction network	
424.	Connecting tanker trucks during the process of draining and filling flammable gases to a grounding device. Using a flexible (stranded) copper wire with a cross-section of at least 6 square millimetres as a grounding conductor	significant
425.	Preventing the operation of devices, pipelines and equipment if the product passes through leaks in the flange and detachable connections	significant
426.	Providing flammable surfaces of devices and containers with proper thermal insulation from non-combustible materials	gross
427.	Preventing the use of sampling taps without passing the hot product through the refrigerator. Keeping the outlet pipes and tubes of the refrigerator in good condition	significant
428.	Preventing the use of open-type lamps in production premises for work related to the possibility of sparking	gross
429.	Maintaining devices designed to drain the product in case of an accident or fire in good condition. Identification of emergency drain line valves with identification marks	gross
430.	Preventing the operation of tube furnaces with faulty twins and their cabinets	significant
431.	Construction of platforms for heat exchangers with a hard surface with drainage into a tray, with an outlet to the industrial drainage system through a hydraulic seal. Providing a platform with a device for flushing flammable products	significant
432.	Painting of pipelines with identification colors depending on the substance transported through them, availability of a digital designation and the direction of movement of the product	minor
433.	Preventing the operation of pipelines intended for pumping explosive and	significant

	fire-hazardous media in the presence of "clamps"	
434.	Availability of fencing of the area around the torch within a radius of at least 50 meters and marking with warning signs, as well as clearing of grassy vegetation within the fences	minor
435.	Preventing the construction of wells, pits and recesses within the fencing of the flare area	significant
436.	Installation of fire arresters on gas pipelines before entering the flare pipe, accessible for inspection and repair	significant
437.	Maintaining in good condition blocking and signalling devices for monitoring technological parameters of compressors and pumps	gross
438.	Availability of grounding of pumps pumping fire and explosive products, regardless of the grounding of electric motors located on the same frame with the pumps	significant
439.	Carrying out the removal of the ejected product outside the premises when purging pumps, liquid - through a pipeline into a special container, and vapours and gases - to a torch or candle	significant
440.	Carrying out constant monitoring of the lubrication of rubbing parts during pump operation, as well as the temperature of pump bearings and seals. Preventing spreading and splashing of lubricants	significant
441.	Availability of external lighting of enterprise territories, the inclusion of which is provided from places with the permanent presence of service personnel	significant
442.	Preventing the operation of electrical equipment in hazardous areas without an explosion protection sign	significant
443.	Preventing the operation of explosion-proof electrical equipment with a broken protection system	gross
444.	Preventing changes in the design of explosion-proof electrical equipment	gross
	Preventing the laying of power lines over the territory of explosion and fire-hazardous zones and at a	

445.	distance of less than 1.5 meters from the height of the power line support from these zones	gross
446.	Preventing using hose cables with damaged sheaths (punctures, cuts at joints)	gross
447.	Preventing the use of process pipelines containing flammable gases, and liquids, as well as pipelines coated with insulation for corrosion protection as grounding conductors and grounding wiring	gross
448.	Availability of a common grounding circuit for electrical equipment, lightning protection, and protection against static electricity	gross
Requirements for medical organizations		
449.	Daily reporting from the head of the organization after the end of the extract of data on the number of patients located in each building of the institution	minor
450.	Providing medical organizations with inpatient facilities for patients unable to move independently with stretchers at the rate of one stretcher for five patients	gross
451.	Preventing placement in buildings with wards for patients, of premises that are not related to the medical process, or renting them out	gross
452.	Preventing the use of rubber and plastic hoses to supply oxygen from cylinders to hospital rooms	significant
453.	Preventing the use of faulty medical electrical equipment	gross
454.	Preventing the use of irons, hotplates and electric heating devices in hospital wards and rooms occupied by patients	gross
455.	Preventing the installation and storage of oxygen cylinders in premises not provided for in the design documentation	gross
456.	Preventing the installation of boilers, water heaters, sterilization of medical instruments, as well as heating of paraffin and ozokerite outside specially adapted premises	significant

457.	Ensuring the storage in laboratories, departments, and doctors' offices of medications and reagents (relating to flammable and combustible liquids - alcohol, ether) in special lockable metal cabinets with a total amount of no more than 3 kilograms, taking into account their compatibility	significant
458.	Preventing the joint storage of cylinders with oxygen and flammable gas, as well as the storage of these cylinders in material and pharmaceutical warehouses	significant
459.	Maintaining in good condition all medical electrical devices in physiotherapy rooms, anesthesiology departments, resuscitation and intensive care, operating departments , provision of reliable grounding, factory electrical circuit and technical passport	gross
460.	Providing sterilizers, including those with an air gap, used in electrical and light therapy rooms, only factory-made and on surfaces made of non-combustible materials	significant
461.	Execution of emissions from local ventilation systems of premises from devices and installations at a height of at least 2 meters above the highest point of the roof	significant
462.	Carrying out a preventive inspection of equipment within the time limits established by the technical passport (instructions) with taking measures to eliminate detected defects	minor
463.	Maintaining logs of fire safety training conducted with service personnel and observed defects in the operation of electrical equipment in each electrical and light therapy department (office)	minor
464.	Preventing the use of external open stairs for the evacuation of patients from hospital buildings	gross
465.	Ensuring free transportation of patients on gurneys, through doorways and passages in operating rooms, preoperative rooms, anaesthesia rooms and operating room areas	gross

466.	Provision of protective measures to prevent fires and explosions in the operating room to prevent spontaneous combustion of narcotic drugs and preparations	significant
467.	Storing flammable and combustible liquids in work areas in quantities not exceeding shift requirements, in thick-walled glass or unbreakable containers with tight stoppers, placed in a metal box lined inside with non-flammable material, with a lid. Preventing storing such liquids in plastic containers	significant
468.	Ensuring the storage of substances and materials in laboratories strictly according to the assortment. Preventing joint storage of substances whose chemical interaction results in a fire or explosion	significant
469.	Making coverings and edges from non-combustible materials on the working surfaces of tables, shelving, and fume hoods designed for working with fire and explosive liquids and substances. Making tables and cabinets from corrosion-resistant materials for working with acids, alkalis and other chemically active substances	significant
470.	Preventing using fume hoods with broken glass or faulty ventilation. Equipping fume hoods with a ventilation system with independent ventilation ducts	gross
471.	Preventing storing liquid oxygen in the same room as flammable substances, fats and oils	gross
472.	Installation of cylinders with compressed, liquefied and dissolved flammable gases outside the laboratory building in metal cabinets with slots or louvres for ventilation	significant
473.	Preventing placing flammable and combustible liquids, as well as combustible materials within 1 meter of heating devices, burners, fire sources	gross
474.	Preventing the pouring of waste flammable and combustible liquids into the drainage system	significant

475.	Availability of grounding of pipelines for supplying flammable and combustible liquids	gross
476.	Making the doors of hyperbaric chambers without glazing, self-closing, with sealed doorways, without locks, as well as locking devices, with the width of the doors of the hyperbaric chambers allowing the transport of patients on a hospital gurney or chair, but not less than 1 meter	gross
477.	Cladding the walls of pressure chambers and suspended ceilings from non-combustible materials	gross
478.	Heating device for pressure chamber rooms with central water heating with a coolant temperature of no more than 95°C. Ensuring a distance from heating appliances and heat sources to the pressure chamber of at least 1 meter	significant
479.	Availability of emergency lighting in rooms where two or more single-place pressure chambers or one multi-place chamber are installed	significant
480.	Availability of only incandescent lamps in luminaires installed directly in pressure chambers	significant
481.	Availability of automatic gas analyzers in rooms with pressure devices for monitoring oxygen content	gross
482.	Preventing patients from being placed in a barometric apparatus wearing synthetic clothing	significant
483.	Preventing the operation of pressure devices without grounding the pressure units (pressure chamber, pressure air conditioner)	significant
484.	Preventing the use of faulty devices and electrical wiring (with damaged insulation, unreliable sparking contacts), the use of electric heating devices, the use of furniture made of flammable materials, materials and objects that can cause a spark, the use of open fire, smoking, open lamps versions for lower lighting of workplaces	gross

485.	Preventing the storage of flammable and combustible liquids, oils, as well as flammable materials, including dressings, in the barozal	gross
486.	Preventing connection of the barometric apparatus to a network with a voltage exceeding the permissible limit	gross
487.	Preventing the operation of pressure apparatus and pressure rooms without primary fire extinguishing means	significant
488.	Preventing storage in premises through which transit electrical cables pass, as well as in premises with gas communications and oil-filled equipment	significant
489.	Preventing storing products in bulk and placing them close to radiators and heating pipes	significant
490.	Avoiding unpacking and packing materials directly in storage areas	minor
491.	Ensuring the storage of plastic products in a ventilated, dark, dry room at room temperature, at a distance of at least 1 meter from heating systems	significant
492.	Providing premises for storing flammable and explosive medicines with fireproof and stable racks and pallets	significant
493.	Storing flammable and combustible liquids in built-in fireproof cabinets with doors at least 0.7 meters wide and at least 1.2 meters high	significant
494.	Storing flammable liquids in quantities over 100 kilograms in a separate building in glass or metal containers isolated from storage areas for flammable substances of other groups	gross
495.	Availability of signs near the entrance to each storage room for flammable and explosive substances with the inscription "Responsible for ensuring fire safety (last name, first name, patronymic (if any) of the responsible person)"	minor
	Preventing storing flammable and combustible liquid medicines with mineral acids (sulfuric, nitric and	

496.	other acids), compressed and liquefied gases, flammable substances, as well as with inorganic salts that produce explosive mixtures with organic substances (potassium chlorate, potassium permanganate)	significant
497.	Storing flammable and explosive medicines in thick-walled, tightly closed containers (bottles, jars, drums), pouring paraffin into closures	significant
Requirements for educational organizations and educational institutions		
498.	Conducting classes with students to study fire safety measures at home and actions in case of fire. Conducting conversations on fire safety topics with primary school students, as well as in preschool organizations. In secondary schools, vocational schools, colleges, higher colleges, organizations of higher and (or) postgraduate education - instructional classes on studying fire safety rules	significant
499.	Preventing the storage of flammable and combustible liquids in laboratories in quantities not exceeding shift requirements	significant
500.	Accommodation of groups (classes) of children of preschool and primary school age no higher than the third floor in the buildings of children's organizations	gross
501.	Ensuring unimpeded evacuation of people and access to fire extinguishing means when arranging furniture and equipment in classrooms, offices, workshops, bedrooms, dining rooms and other premises	gross
502.	Preventing the number of desks (tables) in classrooms and offices from exceeding those established by the design documentation	significant
503.	Availability of round-the-clock service personnel with telephone communications, in educational organizations and preschool organizations with round-the-clock attendance of children	significant

Requirements for medical and social institutions (organizations), boarding schools, children's homes (homes for the elderly and people with disabilities, orphanages, boarding schools, psychoneurological centres, hospices)

504.	Preventing the use of furniture and equipment made using polymer materials that can release highly toxic products when burned	significant
505.	Ensuring the preparation (warming) of food in places specially designated and equipped for these purposes. Preventing the use of electric heating devices for domestic needs without automatic shutdown means	gross
506.	Preventing the use of irons, hotplates and electric heating devices in bedrooms, playrooms and premises occupied by people served. Ironing clothes only in rooms specially equipped for this purpose.	gross
507.	Accommodation of bedridden persons with disabilities and the elderly in premises, taking into account ensuring their fastest possible evacuation	significant
508.	Preventing the placement of storerooms with flammable and combustible materials directly under living rooms and wards, as well as next to them	significant
Requirements for trade facilities		
509.	Preventing temporary storage of flammable materials, waste, packaging and containers in sales areas and on evacuation routes, as well as placing flammable containers close to windows inside and outside buildings	gross
510.	Preventing the storage of flammable goods or non-flammable goods in flammable packaging in premises that do not have window openings or smoke exhaust shafts. Placing storerooms of flammable goods and goods in flammable packaging near external walls	gross
511.	Storing ammunition for weapons and pyrotechnic products in cabinets made of non-combustible materials installed in rooms separated from	gross

	other rooms by fire partitions. Preventing the placement of these cabinets in basements	
512.	Preventing hot work while customers are in the sales area	gross
513.	Preventing trade in flammable and combustible liquids (except for medicines, medical products, cosmetics and alcoholic products), flammable gases, gunpowder, primers, pyrotechnic and explosive products when placed in buildings for other purposes, not related to trade buildings	gross
514.	Preventing the placement of trading, gaming machines and equipment, as well as the sale of goods on evacuation routes	gross
515.	Preventing the installation of flammable gas cylinders in sales areas for filling balloons and other purposes	gross
516.	Making canopies over shopping arcades of open markets from non-combustible materials	gross
517.	Preventing covering of open aisles between shopping aisles with fabrics , paper, films	gross
518.	Preventing the placement of markets in parts of buildings for other purposes or in extensions to them	gross
519.	Construction of kiosks and stalls, pavilions installed in buildings and structures made of non-combustible materials. Construction of pavilions and kiosks intended for the sale of flammable liquids, deodorants, and compressed gases of the 1st, 2nd, and 3rd degree of fire resistance, stand-alone or in a group with kiosks selling similar goods	significant
520.	Preventing the loading of goods and unloading of containers along paths connected with emergency exits for customers during working hours	significant
521.	Preventing trade in household chemicals, varnishes, paints and other flammable and combustible liquids packaged in glass containers with a capacity of more than 1 litre each, as well as fire-hazardous goods	significant

	without labels with warnings such as "Flammable", "Do not spray near fire". Packaging of flammable goods in premises specially adapted for this purpose	
522.	Placing kiosks, as well as one-story pavilions with an area of up to 35 square meters inclusive, in a designated area in groups. Placement in one group of no more than 20 kiosks and pavilions of I, II, III, IIIa fire resistance degrees or 10 kiosks - IIIb, IV, IVa and V fire resistance degrees. Separating a group of 10 containers with type 1 fire barriers. Availability of a fire safety distance between groups of kiosks and (or) pavilions, between free-standing kiosks and (or) pavilions, as well as from groups and free-standing kiosks and (or) pavilions to other buildings and structures.	gross
523.	Placement of a collection point for combustible waste at a distance of at least 15 meters from kiosks and pavilions	gross
524.	Construction of premises for temporary placement of packaging materials and equipment with an area of no more than 5 square meters	gross
525.	Using electric (using oil radiators, heating panels - with a certificate of conformity), steam or water heating in kiosks installed in populated areas	gross
526.	Availability in kiosks and pavilions of automatic fire alarms with sound and light signal output to the facade of the structure or directly to the protected premises	significant
527.	Preventing the location of entertainment areas for children in shopping and entertainment centres on the ground and basement floors	gross
Requirements for storage facilities		
528.	Preventing joint storage of materials and goods in the same section with rubber or tyres, regardless of the uniformity of the fire extinguishing agents used	significant
	Ensuring the protection of cylinders with flammable gases, containers	

529.	with flammable and combustible liquids, as well as aerosol packages from solar and other thermal effects	significant
530.	Storing aerosol packages in multi-storey warehouses in fireproof compartments only on the top floor, with the number of packages in the compartment no more than 150,000 pieces	gross
531.	Storing no more than 15,000 packages (boxes) in an isolated compartment of the warehouse, with a total warehouse capacity of no more than 900,000 packages. Placing warehouses in buildings without attics, with easily removable coverings	gross
532.	Storing aerosol packages in quantities of no more than 5,000 pieces in general warehouses	gross
533.	Storing aerosol packages in open areas or under canopies only in non-flammable containers	gross
534.	Storing materials in stacks in warehouses using a rackless storage method. Availability of free passages with a width equal to the width of the doors, but not less than 1 meter opposite the doorways of the warehouse premises. Availability of longitudinal passages with a width of at least 0.8 meters every 6 meters in warehouses	gross
535.	Carrying out fire retardant treatment of wooden structures inside warehouses	significant
536.	Preventing the placement of warehouses in premises through which transit electric cables, gas and other communications pass	significant
537.	Availability of a distance from lamps to stored goods of at least 0.5 meters and 0.2 meters to the surface of flammable building structures	gross
538.	Preventing the usage of the premises intended for storing inventory as workers' locker rooms, rooms for meals and utility services	significant
539.	Preventing parking and repair of loading and unloading vehicles and	minor

	vehicles in warehouses and landing stages	
540.	Carrying out operations in warehouse buildings related to opening containers, checking serviceability and minor repairs, packaging products, preparing working mixtures of flammable liquids (nitro paints, varnishes) in rooms isolated from storage areas	minor
541.	Locating devices intended for disconnecting the power supply to a warehouse outside the warehouse, on a wall made of non-combustible materials or on a separate support, enclosing them in a cabinet or niche with a device for sealing and locking them	gross
542.	Preventing emergency lighting in warehouse premises, as well as the operation of gas stoves, electric heating devices and the installation of plug sockets	gross
543.	Storing materials in an open area with an area of one section (stack) of no more than 300 square meters, and fire breaks between stacks of at least 6 meters	gross
544.	Preventing personnel and other persons from living in buildings located on the territory of bases and warehouses	significant
545.	Preventing the entry of locomotives into warehouses of categories A, B and B1-B4	significant
546.	Preventing the storage of flammable and combustible liquids in workshop storerooms in quantities exceeding the norm established at the enterprise	significant
547.	Preventing the storage of flammable materials or non-combustible materials in flammable containers in basement and ground floor rooms that do not have windows with pits for smoke removal, as well as when connecting common stairwells of buildings with these floors	gross
548.	Placing warehouses for storing flammable gas cylinders in one-story, attic-free buildings with easily removable coverings	gross

549.	Painting the windows of rooms where gas cylinders are stored with white paint or equipping them with sun-protection, non-flammable devices	minor
550.	Preventing the storage of flammable materials and performing hot work at a distance of 10 meters around the storage area of cylinders	gross
551.	Making cabinets and booths where the cylinders are located from non-combustible materials and equipping them with natural ventilation to prevent the formation of explosive mixtures in them	gross
552.	Storing cylinders with flammable gases separately from cylinders with oxygen, compressed air, chlorine, fluorine, and oxidizers, as well as from cylinders with toxic gases	significant
553.	Storing gas in a compressed, liquefied and dissolved state in cylinders. Painting the outer surface of the cylinders in the color specified for a given gas	significant
554.	Preventing the ingress of oils (fats) and contact of the cylinder fittings with oily materials during storage and transportation of oxygen cylinders	gross
555.	Equipping gas storage rooms in quantities of more than 40 cylinders with serviceable gas analyzers up to explosive concentrations	gross
556.	Preventing persons from wearing shoes lined with metal nails or horseshoes in the warehouse where flammable gas cylinders are stored.	significant
557.	Storing flammable gas cylinders with boots in a vertical position in special nests, cages, and devices to prevent them from falling	minor
558.	Storing cylinders without shoes in a horizontal position on frames or racks. Using a stack height of no more than 1.5 meters, closing the valves with safety caps, and turning them in one direction	significant
559.	Preventing storing any substances, materials and equipment in gas warehouses	significant

560.	Availability of natural ventilation in warehouses with flammable gases	significant
561.	Availability of a plan for the placement of stacks, indicating the maximum volume of stored materials, fire breaks and passages between stacks, as well as between stacks and neighbouring facilities in timber warehouses	minor
562.	Preventing storage of timber and equipment in fire breaks between stacks	gross
563.	Clearing the areas allocated for stacks to the ground of grass, flammable debris and waste, or availability of a layer of sand, earth or gravel at least 0.5 meters thick	minor
564.	Availability in each warehouse of an operational fire extinguishing plan with the definition of measures for dismantling stacks, pulp heaps, and wood chips, taking into account the possibility of involving employees and equipment of the enterprise	minor
565.	Availability in warehouses of points (posts) with a stock of various types of firefighting equipment in quantities determined by operational fire extinguishing plans, in addition to primary fire extinguishing means. Providing timber warehouses with the necessary supply of water for firefighting	gross
566.	Preventing work not related to the storage of timber in warehouses	minor
567.	Construction of living quarters for workers in timber warehouses in separate buildings in compliance with fire breaks	significant
568.	Application only factory-made electric heating devices for heating domestic premises in timber warehouses	gross
569.	Placing winches with internal combustion engines at a distance of at least 15 meters from round timber stacks	significant
570.	Preventing the installation of transport packages in fire breaks, driveways, and entrances to fire water sources	gross

571.	Availability in closed warehouses of a passage width between stacks and protruding parts of the building walls is at least 0.8 meters. Availability of passages with a width equal to the width of the doors, but not less than 1 meter opposite the warehouse doorways	gross
572.	Preventing partitions and office spaces in closed warehouses	gross
573.	Making floors of closed warehouses and areas under canopies from non-combustible materials	gross
574.	Storing wood chips in closed warehouses, bunkers and open areas with a base made of non-combustible material	gross
575.	Availability of wells made of non-combustible materials for installing thermoelectric converters to control the heating temperature of wood chips inside the pile	gross
576.	Preventing the storage of freshly mined coal on old coal dumps that have lain for more than one month	significant
577.	Preventing the transportation of burning coal along conveyor belts and their loading into railway transport or a bunker	gross
578.	Avoiding the location of coal stacks above heat sources (steam pipelines, hot water pipelines, heated air channels), as well as above-laid electrical cables and oil and gas pipelines	gross
579.	Preventing wood, fabric, paper and flammable materials from getting into piles when laying coal and storing it	significant
580.	Isolation by fire barriers (walls and partitions) of coal storage rooms located in the basement or first floor of industrial buildings	gross
581.	Preventing the mass of fibre in a stack from exceeding 300 tons	significant
582.	Ensuring that the stack size is no more than 22x11 meters, and the height is no more than 8 meters	significant
	Availability of no more than six stacks or canopies in the nest, the gap between stacks is at least 15	

583.	meters, and between canopies - 20 meters in all directions	gross
584.	Availability in a group of no more than four nests (24 stacks or canopies), the gap between nests is at least 30 meters in all directions	gross
585.	Availability in the sector of no more than four groups (96 stacks or canopies), gaps between groups of at least 50 meters in all directions	gross
586.	Preventing gaps between storage sectors of flammable fibrous materials of less than 100 meters	gross
587.	Availability of fencing of areas occupied by warehouses, sheds and open areas for storing fibrous materials	significant
588.	Preventing storage of production waste together with raw materials and finished products	significant
589.	Preventing the access of railway (except for steam locomotives) and motor vehicles closer than 5 meters, and tractors - 10 meters to sheds and stacks of fibrous materials without spark arresters	gross
590.	Carrying out the volume of diking of tanks equal to the volume of the largest tank located in the diking and constantly maintaining it in good condition. Preventing violation of the integrity and height of the embankment, as well as travel along the boundaries of the tank farm	significant
591.	Preventing the installation of electrical equipment and the laying of power lines inside the bund of tanks and directly in tanks, except for lines of devices for control and automation of filling and level measurement in explosion-proof design	gross
592.	Installation of pipeline communications in a tank farm, providing the ability to pump oil and petroleum products from one tank to another in the event of an accident with the tank	significant
593.	During the winter period of the year, timely removal of snow from the roofs of tanks, as well as clearing of	minor

	snow from paths and fire passages on the territory of the tank farm	
594.	Availability of gas analyzers with light and sound alarms for constant monitoring of hydrocarbon concentrations in explosion and fire-hazardous areas on the territory of the tank farm	gross
595.	Presence in prominent places of inscriptions about the inadmissibility of violating the fire safety regime throughout the entire territory of the tank farm and free-standing tanks	minor
596.	Measuring the level and taking samples of petroleum products only with stationary systems of measuring devices, except for tanks with excess pressure of the gas space up to 2.10 Pa, in which the level is measured and samples are taken through the gauging hatch manually.	minor
597.	Availability of sealed covers on hatches, used for measuring the level and taking samples from tanks, as well as metal rings that prevent sparking on the measuring hole from the inside	gross
598.	Preventing the operation of tanks that have settled, have leaks, as well as with malfunctions of taps, pipeline connections, gland packings, valves, fire extinguishing and cooling systems	gross
599.	Availability of a schedule of planned work to remove deposits of pyrophoric iron sulfide for tanks in which sulfurous petroleum products are stored	minor
600.	Availability of shut-off devices in the form of flapper valves, actuated outside the embankment to remove oil spilt during an accident, as well as for draining storm water at drainage outlets from the embankment	gross
601.	Preventing a decrease in the embankment height established in the design documentation	significant
602.	Preventing the operation of tanks that have distortions and cracks, as well as faulty equipment,	gross

	instrumentation, supply pipelines and stationary fire-fighting devices	
603.	Preventing the planting of trees, shrubs, and grass in a square of embankments	minor
604.	Avoiding installation of containers on a flammable base	gross
605.	Avoiding overfilling of tanks and cisterns	significant
606.	Inspection of breathing valves and fire arresters in accordance with the requirements of technical documentation of manufacturers. Cleaning valves and mesh from ice during inspections of breathing valves. Heating them only using fireproof methods	significant
607.	Preventing joint storage of flammable and combustible liquids in containers in the same room when their total quantity does not exceed 200 cubic meters of flammable liquids or 1000 cubic meters of flammable liquids	gross
608.	Installation of barrels with flammable and combustible liquids in storage facilities with manual laying on the floor in no more than 2 rows, with mechanized laying of barrels with flammable liquids - no more than 5, and with flammable liquids - no more than 3	gross
609.	Preventing making stacks wider than 2 barrels. The width of the main aisles for transporting barrels is at least 1.8 meters, and between stacks - at least 1 meter	gross
610.	Storing liquids only in serviceable containers	significant
611.	Fencing open areas for storing petroleum products in containers with an earthen rampart or non-combustible solid wall at least 0.5 meters high with ramps for access to the areas	gross
612.	Placing within one bunded area no more than 4 stacks of barrels measuring 25 × 15 meters and a height of 5.5 meters with gaps between the stacks of at least 10 meters, and between the stack and	gross

	the shaft (wall) - at least 5 meters. Making gaps between stacks of two adjacent sites of at least 20 meters	
613.	Preventing spills of petroleum products, as well as storing packaging material and containers directly in storage facilities and on bunded areas	significant
614.	Availability of the required special equipment (bulldozer, dump truck, excavator, loader, watering machine, water dispenser, motor pumps for pumping water) to prevent fires and maintain solid waste storage sites	gross
615.	Providing a mineralized strip along the perimeter with a width of at least 4 meters of the territory of the landfill for the storage of solid household waste	significant
616.	Availability of a serviceable external fire-fighting water supply with a capacity designed for the required flow rate of the external fire-fighting water supply	gross
617.	Dividing landfills (sites) into storage areas with an area of no more than 10,000 square meters. Availability of fire breaks at least 8 meters wide between sections	gross
Requirements for agricultural facilities, livestock farming, poultry farms		
618.	Preventing the establishment of workshops, warehouses, parking for vehicles, tractors, and agricultural machinery in premises for animals and poultry, as well as the performance of work not related to the maintenance of farms. Preventing the entry into these premises of tractors, cars and agricultural machines whose exhaust pipes are not equipped with spark arresters	minor
619.	Preventing the storage of roughage in the attics of farms	gross
620.	When operating electric brooders, the distances from the heating elements to the litter and combustible objects are at least 80 centimetres vertically and at least 25 centimetres horizontally. Preventing the use of exposed heating elements	gross

621.	Location of mobile ultraviolet installations and their electrical equipment at a distance of at least 1 meter from flammable materials	gross
622.	Installation of the gasoline engine of the shearing unit on an area cleared of grass and debris at a distance of 15 meters from buildings. Storing fuel and lubricants in closed metal containers at a distance of 20 meters from the cutting point and buildings	gross
623.	Preventing the accumulation of wool at the shearing station beyond the shift output and blocking the passage and exit with bales of wool	gross
624.	Storing ammonium nitrate in self-contained 1st or 2nd-degree fire resistance non-attic one-story buildings with non-combustible floors. In exceptional situations, the storage of nitrate is allowed in a separate compartment of the general warehouse of mineral fertilizers of an agricultural enterprise of fire resistance class I or II. Storing strong oxidizing agents (magnesium and calcium chlorates, hydrogen peroxide) in separate compartments of buildings of I, II and IIIa fire resistance degrees	significant
625.	Availability of protective firebreaks with a width of at least 4 meters when locating farms and agricultural facilities near coniferous forests, between buildings and forests for the spring-summer fire-hazardous period	gross
626.	Availability of isolated premises for cleaning flour bags and storing them with the installation of a bag-beating machine	significant
627.	Ensuring bulk storage of liquid fat and vegetable oil in a separate room at bakery enterprises	significant
628.	Preventing the presence of a reserve of solid fuel in the combustion chamber for no more than one shift	significant
629.	Availability outside of the building of an isolated room made of non-combustible structures for the installation of liquid fuel consumable tanks when operating liquid fuel bakery ovens	significant

630.	Making doors from industrial premises with the simultaneous presence of 15 people at elevators, flour mills, feed mills and cereal factories opening into the premises (against the direction of evacuation). Arrangement of doors from airlock vestibules opening in different directions (doors from production premises to airlock vestibules opposite the evacuation route, doors from vestibule airlocks to stairwells - along the evacuation route)	gross
631.	Availability of automatic fire dampers or devices for shutting them off in the event of a fire in the openings of firewalls for the passage of belt conveyors	gross
632.	Preventing the passage of air ducts, material pipelines, gravity pipes through household, utility and administrative premises, control panels, electrical distribution devices , ventilation chambers and staircases	gross
633.	Preventing the installation of elevators, the passage of gravity and aspiration pipes, as well as the installation of transport and technological equipment in mines for laying cables	significant
634.	Availability of aspiration at feed mills in places of unloading of mealy raw materials and bran	significant
635.	Providing tight connections for hatches of silos and bunkers, as well as hatches in gravity pipes, air ducts and aspiration hoods, preventing the penetration of dust into the premises	gross
636.	Availability in all warehouses of external ladders located at a distance of no more than 100 meters from one another	significant
637.	Availability on elevators with a capacity of more than 50 tons/hour of automatic braking devices that protect the belt from reversing when stopping. Avoidance of installations of elevators and individual parts made of flammable materials	significant
	Preventing the aspiration of containers for collecting and storing dust and operational (production)	

638.	containers from being combined into one aspiration unit with technological and transport equipment	significant
639.	Availability of blocking of technological and transport equipment with aspiration units	significant
640.	Preventing the placement of fans and dust collectors for grain dryers in working buildings of elevators	significant
641.	Preventing the collection and storage of aspiration waste and industrial dust in bunkers and silos located in the production premises of elevators	significant
642.	Preventing the laying of transit air ducts through the premises of warehouses for raw materials and finished products, as well as through premises of categories A, B and C 1-4 for explosion and fire hazards	gross
643.	Preventing the use of containers for gravitational settling of dust (aspiration shafts, dust-sediment chambers) located after fans and blowers	significant
644.	Grounding of air and material pipelines in at least two places	gross
645.	Additional grounding of dust collectors and blowers. Preventing the use of washers for bolts made of dielectric materials painted with non-conductive paints in connections between installation elements	gross
646.	Preventing the air ducts of the aspiration units from touching the pipelines of the heating system	significant
647.	Preventing the operation of equipment without aspiration systems, explosion arresters on elevators and crushers, provided for in the design and technical documentation	gross
648.	Availability of magnetic separators before passing products (raw materials) through roller machines, crushers, whipping machines and impact machines	significant
649.	Preventing the whips from touching the inner surface of the whip drum to avoid sparking	gross

650.	Preventing operating chain conveyors (with submersible scrapers) without pressure sensors or ring switches that automatically stop the conveyor when boxes are overfilled	significant
651.	Preventing the operation of screws without safety valves installed at their ends in the direction of product movement, opening under pressure	gross
652.	Preventing splicing of conveyor belts and drive belts using metal brackets and bolts	significant
653.	Preventing operation of the crusher with malfunctions, as well as without blocking the electric motor with a device for automatic load control	gross
654.	Preventing the use of homemade safety pins for granulators, as well as metal rods with undefined dimensions and mechanical characteristics	significant
655.	Preventing the operation of roller machines without a working light alarm, without loading the product, with the rollers pressed, skewed and displaced along the axis	significant
656.	Preventing the use of elastic and strong connections on the bodies of sifters, stone separators, and separators when operating sieve machines. Making flexible connections of bodies from materials that do not allow dust to pass through with a durable connection and exhaust pipes	significant
657.	Preventing starting hulling machines with heads removed, faulty tensioners, loose abrasive discs or without drying wheels	significant
658.	Preventing the operation of peeling and grinding machines with cracks and damage to disks, rollers, decks, as well as existing imbalances	significant
659.	Preventing the operation of electromagnetic separators without blocking them with electromagnets to prevent the supply of products in the event of a power outage	significant
	Preventing the operation of channel furnaces without explosion safety	

660.	valves, with a minimum area of one explosion valve - 0.05 cubic meters, installed in the upper parts of the fireboxes and flues	gross
661.	Preventing the operation of furnaces without ventilation devices to remove heat and gaseous substances	gross
662.	Availability in furnaces operating on gaseous or liquid fuels of devices that automatically turn off the fuel supply in emergencies: 1) stopping the supply of liquid fuel to the furnace and air to combustion devices (for furnaces operating on liquid fuel); 2) exceeding the permissible temperature of heating gases in the heating system; 3) conveyor stops	gross
663.	Preventing the operation of ovens without a backup manual drive mechanism for unloading baked goods in emergencies	significant
664.	Preventing the operation of sluice gates or groups of unloader gates from intra-shop pneumatic transport without speed control relays on the end rollers (the requirement does not apply to sluice gates of a set of high-performance equipment)	significant
665.	Preventing the storage of non-grain products (meal, cake, granulated grass meal) in silos and bunkers of grain elevators	significant
666.	Drying corn in grain in direct-flow shaft dryers installed outside the building	significant
667.	Preventing the storage of rice, millet, and buckwheat husks in open areas and undercover outside bunker-type warehouses over the 2-day operating capacity of the cereal plant	significant
668.	Preventing the operation of silos storing grain, cake and meals, without installations of remote daily temperature control (stationary thermometry systems)	significant
669.	Preventing the use of gravity and mechanical transport and pneumatic transport (elevators, chain conveyors, belt and rollerless conveyors) for	significant

	transporting industrial waste without closed casings	
670.	Dividing grain tracts into plots of no more than 50 hectares before harvesting grain. Making swaths at least 8 meters wide between sections . Immediate removal of mown bread from swaths. Availability of ploughing in the middle of the swath with a width of at least 4 meters	significant
671.	Preventing the placement of temporary field camps closer than 100 meters from grain tracts and currents. Implementation of ploughing with a width of at least 4 meters of field campsites and grain currents	significant
672.	Availability of a tractor with a plough for ploughing the burning zone in the event of a fire near harvested grain tracts with an area of more than 25 hectares	gross
673.	Preventing storage and refuelling of motor vehicles with petroleum products in field conditions outside special areas cleared of dry grass, and flammable debris and ploughed with a strip of at least 4 meters wide, or in ploughing at a distance of 100 meters from leks, hay and straw stacks, grain tracts and at least 50 meters from buildings and structures	gross
674.	Preventing the storage and transportation of flammable substances in the cabin and body of agricultural machinery. Keeping the engine compartment, parts of components and assemblies of agricultural machinery clean	gross
675.	Prevention during the sowing campaign, harvesting of grain crops and procurement of feed: 1) operation of tractors, self-propelled chassis and cars without hoods or with open hoods; 2) the use of blowtorches to burn dust in engine radiators; 3) operation of agricultural machinery (cars, combines, tractors and equipment involved) without working spark arresters	gross

676.	Installation of units for preparing herbal flour under a canopy or indoors	significant
677.	Preventing the placement of grass meal preparation points at a distance of less than 50 meters from buildings, structures and tanks with fuels and lubricants, and from open roughage warehouses less than 150 meters	gross
678.	Installation of the consumable fuel tank outside the unit. Equipping fuel lines with at least two valves (one at the unit, the second at the fuel tank)	significant
679.	Preventing the storage of flour in bulk, the joint storage of flour with other substances and materials, as well as in buildings, structures and premises made of flammable materials. Storage in a separate warehouse or compartment, with the room equipped with a ventilation system and preventing moisture from entering the room	significant
680.	Storing bags of flour in stacks no more than 2 meters high, two bags in a row. Making passages between rows at least 1 meter wide, and along the walls - 0.8 meters	significant
681.	Ensuring that rooms for processing flax, hemp and industrial crops are isolated from the engine room	gross
682.	Preventing the operation of internal combustion engines of the engine room without spark arresters on the exhaust pipes, as well as without a fire-prevention cutting device at the outlet of pipes through the flammable structures of the walls of the engine room premises	gross
683.	Storing flax raw materials (straws, hemp stocks) in stacks, sheds (under open sheds), closed warehouses, and fibre and tow - only in closed warehouses	significant
	Avoidance during primary processing of industrial crops: 1) storage and threshing of flax on the territory of farms, repair shops, and garages; 2) entry of cars, and tractors into production premises, warehouses of finished products and sheds.	

684.	Stopping of cars shall be provided at a distance of at least 5 meters, and for tractors - at least 10 meters from the specified buildings, stacks and shafts; 3) furnace heating devices in the pulverizing shop	significant
685.	Preventing the entry of cars, tractors and self-propelled vehicles into the territory of the flax processing facility without working spark arresters	gross
686.	Preventing vehicles from approaching stacks (shed) with the side in the direction of exhaust gases exiting from engine exhaust systems	significant
687.	Preventing placing smoking areas on the territory of a flax processing facility at a distance of less than 30 meters from production buildings and storage areas for finished products	significant
688.	Preventing natural drying of hemp stocks outside specially designated areas	significant
689.	Separation of dryers located in industrial buildings from other premises by firewalls made of non-combustible materials. Plastering on both sides of combustible structures of free-standing drying buildings and drying chambers	gross
690.	Preventing the shift requirement from exceeding the amount of hemp stock located in the production area. Storing in stacks no closer than 3 meters from the machines	significant
691.	Making racks and shelves in tobacco dryers from non-flammable materials. Fire dryers have metal canopies above the fire tubes to protect them from tobacco ingress	gross
692.	Avoidance when harvesting cotton: 1) smoking and using an open fire in a cotton field; 2) leaving in the field, refuelling a cotton picker with a hopper filled with raw cotton;	gross

	<p>3) operating cotton pickers with faulty hydraulic systems and electrical equipment;</p> <p>4) parking of cotton pickers at cotton drying sites</p>	
693.	Preventing parking of tractors, cars, cotton picking machines, repairs, lubrication and refuelling at a distance of less than 50 meters from the site for natural drying of raw cotton	significant
694.	Placement of sites for natural drying of raw cotton from residential buildings, public buildings, and repair shops at a distance of at least 150 meters, and from high-voltage and low-voltage power lines at least 1.5 meters of support height	gross
695.	Providing areas for natural drying of raw cotton with an estimated amount of water for external fire extinguishing purposes, but not less than 50 cubic meters	significant
696.	Asphalting or compacting a clay layer with a thickness of at least 5 centimetres of the area for natural drying of raw cotton. Preventing the production of cotton drying on the roadway	significant
697.	Preventing the operation of devices in a faulty state that prevents the release of dust from process equipment (sealing units, local suction)	significant
698.	Providing elevators with stationary platforms with stairs. Fencing the site with railings at least 0.9 meters high with continuous cladding at the bottom to a height of 0.1 meters	significant
699.	Preventing malfunction of the automatic protection of the elevator drive in case of a belt break, as well as the working parts touching the wall of the elevator box	significant
700.	Equipping the elevator casing with easy-to-open hatches with reliable locks and elastic gaskets that ensure tightness (tightness) of the cover around the perimeter	significant
	Preventing the operation of conveyors without working special	

701.	devices for removing raw cotton from the bottom belt	significant
702.	Preventing the operation of machines and devices included in the pneumatic transport system without working grounding devices. Preventing mechanized shovelling of raw cotton through a fan	significant
703.	Preventing the number of riots in a group from exceeding more than two riots, with an area of 65×14 meters, four with an area of 25×14 meters for one riot, or six with an area of 25×11 meters for one riot. The height of the riot is no more than 8 meters	gross
704.	Preventing the reduction of fire gaps between riots in a group of less than 15 meters, and between groups of riots of less than 30 meters	gross
705.	Installation of heat-producing units used for drying raw cotton in isolated rooms made of non-combustible structures	significant
706.	Storing cotton fibre in bales	significant
707.	Making a standard stack of cotton measuring no more than 22 meters in length, 11 meters in width and 8 meters in height when storing bales of cotton fibre in stacks in open areas	gross
708.	Availability of high-pressure fire-fighting water supply at cotton factories and cotton points when storing raw cotton of more than 2,400 tons	significant
709.	Availability of two or more independent gates in the stable premises, in front of which it shall be prohibited to install thresholds, steps, or gateways. Closing the gate with easy-open latches	gross
710.	The presence of devices in the stable premises, allowing to simultaneously release and withdraw horses from stalls in case of fire	significant
711.	Laying of electrical wires in stables shall be open, on insulators, cables, in steel pipes or cables. Arrangement of switchboards, switches, fuses in vestibules or on external walls of	gross

	stables in cabinets made of non-combustible materials	
712.	Availability of the animal evacuation plan in case of fire to evacuate horses from stables	insignificant
713.	Prevention during operation of electrical networks in stables: 1) the location of the electrical conductor above the places where the animals shall be located; 2) storage under electrical wiring of hay, straw; 3) laying electrical wires and cables in transit through the stable premises ; 4) use of lamps, the power of which exceeds the maximum permissible for this type of lamp; 5) suspension of lamps directly on wires	gross
714.	Prevention of the arrangement of workshops, warehouses, parking lots of vehicles, as well as work not related to animal maintenance	gross
715.	Prevention of entry of vehicles with internal combustion engines whose exhaust pipes shall not be equipped with spark arresters	significant
716.	Prevention of installation of springs and units on gates for their automatic closing	significant
717.	Prevention of the use of kerosene lamps, candles and faulty electrical lantern for lighting premises	gross
718.	Prevention of temporary furnaces installation	gross
719.	Prevention of storage of hay, forage, horse litter in the vestibules and aisles, in the attics of the stable	significant
720.	Prevention of smoking and the use of open fire in the stables	gross
721.	Storage of coarse feed stock only in extensions (extensions) separated from farm buildings by blind non-combustible walls (partitions) and ceilings with fire resistance rating of at least EI-45. Equipping attachments (subassemblies) with exits only directly to the outside	gross

722.	The fence was covered with an earthen rampart and a wire fence. Placing the weight outside the haymaking	insignificant
723.	Location of hay stacks (stacks), sheds and piles of rough stem at a distance of at least 15 meters to power lines, at least 20 meters to roads and at least 50 meters to buildings and structures	gross
724.	Ensuring distances from the fence of hay storages to at least 20 meters of forest areas located near the perimeter and a strip with a width of at least 4 meters along the perimeter	gross
725.	Location of crude feed warehouses on the territory of the production and economic complex on a specially designated site	gross
726.	The presence of a platform for placing hay stacks (stacks), as well as a pair of hay stacks (stacks) or stacks along the perimeter with a strip at least 4 meters wide. Ensuring distances from the edge of the strip to the hay stacks (stack) located on the site, at least 15 meters, and to the free-standing hay stacks (stack) - at least 5 meters	gross
727.	Prevention of exceeding the area of the base of one hay stacks (stack) more than 150 square meters, and stacks of pressed hay (straw) - 500 square meters	gross
728.	Provision of fire gaps between individual stacks, sheds and hay stacks (stacks) of at least 20 meters, between stacks and sheds when stacks, sheds and hay stacks (stacks) are placed in pairs of at least 6 meters, and between their pairs - at least 30 meters. Provision of fire gaps between quarters (20 hay stacks or stacks shall be allowed in a quarter) at least 100 meters	gross
729.	Storage of hay with increased humidity in conical stacks (piles) with gaps between them of at least 20 meters	gross
730.	Availability of at least 50 cubic meters of water in crude feed warehouses in case of fire	significant

731.	Arrangement of grain stacks in free-standing facilities	gross
732.	Ensuring the distance from the top of the embankment to the combustible structures of the coating, as well as to lamps and electrical wires, shall not be less than 0.5 meters when storing grain by embankment. Presence of fire retardants in places of grain transportation through openings in fire barriers	gross
733.	Presence of fire retardants in places of grain transportation through openings in fire barriers	significant
734.	Prevention of the use of grain cleaning and other machines with internal combustion engines inside warehouses	gross
735.	Prevention of work on mobile mechanisms with closed gates on both sides of the warehouse	significant
736.	Prevent ignition of solid fuel dryers with flammable and combustible liquids and liquid fuel dryers with flares	gross
737.	Prevention of operation on dryers with faulty temperature monitoring devices and automatic shutdown of fuel supply when the flare fades in the furnace, electric ignition system or without them	significant
738.	Prevention of grain filling above the level of the conveyor belt and tolerance of belt friction on the conveyor design	significant
739.	Installation of a mobile drying unit at a distance of at least 10 meters from the grain storage facility	significant
740.	Arrangement of fans at a distance of at least 2.5 meters from combustible walls when venting grain in grain stacks, making non-combustible air ducts	gross
741.	Prevention of the use of machinery and equipment with internal combustion engines inside production and warehouse premises	gross
742.	Use of standard wooden bread boards for separation of individual grain batches	significant

743.	Application of width when there shall be passages between built-in silos and warehouse walls at least 0.7 meters	gross
744.	Prevention of the use of electric heaters with open heating elements in all facilities and rooms, and the use of all types of electric heaters in explosion and fire hazardous rooms	gross
745.	Device at bakery and pasta enterprises during storage of bags with flour of passages and passages with width not less than: 1) passages between stacks, at least after 12 meters - 0.8 meters; 2) distances from stacks to walls - 0.7 meters; 3) driveways for electric loaders - 3.0 meters; 4) driveways for trolleys with a lifting platform - 2.0 meters	gross
746.	Device inside the warehouse for storage of products in the container of other enterprises of the bakery products industry: 1) one - along the centre of the warehouse with a longitudinal width that ensures the operation of mechanisms, but not less than 1.25 meters; 2) two transverse ones - against the warehouse gate, through ones, with a width of at least the width of the gate ; 3) between stacks and warehouse walls - at least 0.7 meters wide	gross
747.	Use of heating devices with a smooth surface and at a height that shall ensure the possibility of systematic cleaning of them from dust	gross
748.	Provision of free access to heating devices	gross
Requirements for power facilities (power generating and power transmitting)		
749.	Provision of cleaning of electrical equipment of closed switchgears according to the schedule approved by the technical manager with obligatory implementation of organizational and technical measures	significant

750.	Execution of floors in chemical laboratory made of metal tiles, linoleum and materials depending on process requirements and handled chemicals	gross
751.	Coating of working tables and fume cabinets designed to work with the use of heating or explosion and fire hazardous substances with a completely incombustible material, and designed to work with acids and alkalis - with an anticorrosive material and the presence of flanges that prevent the spill of liquid substances	gross
752.	Cleanliness of rooms for preparation and transfer of petroleum products (oil pump, oil pump, oil regeneration)	insignificant
753.	Regular check of the technical condition of permanently installed automatic gas analysers, as well as sound and light alarm devices on the presence of a dangerous concentration of vapours in the air in production premises with entry of the inspection results into the operational log	insignificant
754.	Equipment at open switchgears of grounding points of firefighting equipment installation with location designation (in accordance with the operational fire extinguishing plan)	gross
755.	Installation of oil cleaning plant equipment on non-combustible bases	gross
756.	Implementation of filling oil products in tanker trucks, tanks on specially equipped platforms with a hard coating. Availability on the platform of an organized drain (for removal of spilled liquids) through a water seal in the special combined capacity which shall be periodically cleaned	significant
757.	Availability of organized runoff at the site (for removal of spilled liquids) through the hydraulic seal into a special collection tank, which is periodically cleaned	significant
758.	Availability of a cable or rod for towing tank trucks on the truck rack	significant

759.	Availability of diagrams and local equipment operating instructions in gas facilities of gas control units, which shall describe specific fire safety requirements	insignificant
760.	Arrangement of rooms with instrumentation and control devices separately from gas control stations, gas control plants and separation by gas-tight wall, in which through holes and slots shall not be allowed. Allowing the passage of communications through the wall only with the use of special devices (glands)	significant
761.	Design with distinctive painting of gas pipelines laid open	significant
762.	Prevention of the use of existing gas pipelines for the installation of suspension (support) of devices and scaffolding flooring	significant
763.	Cleaning of the site for storage of solid fuel (coal, shale, peat) from plant debris and materials	significant
764.	Preventing the laying of coal, peat and oil shale on soil containing organic substances and ponds	significant
765.	Availability of a special site in the warehouse for extinguishing self-ignited fuel and it's cooling down after removal from the stack	significant
766.	For routine works with stacks, as well as for the passage of mechanisms and fire engines, the distance from the bottom of the stacks to the fence and the foundation of crane tracks is at least 3 meters, and to the outer face of the rail head or the edge of the road - at least 2 meters. Prevention of backfilling of driveways with solid fuel and their cluttering with equipment	significant
767.	Ensuring the operation of aspiration plants or dust suppression plants at fuel transfer units using finely sprayed water, air-mechanical foam or water vapor mixture	significant
768.	Operability of dedusting means located on the fuel supply path, as well as devices for catching metal,	significant

	chips and foreign impurities from fuel during fuel supply	
769.	Keeping clean in the fuel supply path rooms, regular cleaning with removal of dust from all places of its accumulation. Availability of the approved cleaning schedule depending on the type of solid fuel, its tendency to oxidation and dust content of the premises	insignificant
770.	Installation of heating devices, along the fuel supply path, their implementation with smooth surfaces, easily accessible for cleaning	gross
771.	Execution of electric equipment installed along the fuel supply path in dust-proof design and meeting the requirements of dust hydration	gross
772.	Clearances between cables on cable routes running along the fuel supply path to reduce dust accumulation	significant
773.	Application of dust-proof lamps in rooms, galleries of conveyors and silos of raw fuel	significant
774.	Maintenance of transition bridges through conveyors in fuel supply path galleries in serviceable condition	significant
775.	Prevention of fuel supply path in production premises: 1) smoking outside designated areas; 2) applications for heating electrical heating devices; 3) use of open incandescent lamps; 4) fuel supply with combustion foci (smouldering) to conveyors and its discharge into bunkers; 5) fuel accumulation under the lower lines of conveyor belts; 6) stops of conveyors loaded with fuel, except for emergency cases; 7) storage, especially in galleries of conveyors, dismantled equipment, conveyor belt and other combustible materials	gross
776.	Operation of dust preparation plants, which include mills, separators, cyclones	gross
	Prevention of laying new cable routes opposite the neck of the safety	

777.	<p>devices of vacuum systems at a distance of closer than 10 meters.</p> <p>Protection of existing cable routes passing at the specified distance with metal covers (ducts) at a length of at least 5 meters, or baffles at safety valves</p>	significant
778.	<p>Application of non-combustible heat insulation on fuel oil pipelines.</p> <p>Periodic, but not less than once per half year, visual inspection of the condition of thermal insulation of pipelines, equipment and silos.</p> <p>Record of detected violations in the equipment defects and malfunctions log</p>	significant
779.	<p>Prevention of tightness violations of oil supply, control, gas supply systems, as well as flange and choke connections on liquid fuel pipelines of gas turbine plants during operation of power plants</p>	significant
780.	<p>Prevention of oil ingress on hot surfaces, basements and cable routes during operation of units</p>	gross
781.	<p>Storage of oiled rags and rags in special metal closing boxes with a capacity of not more than 0.5 cubic meters with the inscription "For rags, " which shall be installed at the main service elevations</p>	insignificant
782.	<p>Availability of "Emergency oil drain " inscription on the shutoff device (gate valve) of emergency oil drain from the oil tank of power plants, painting of the manual actuator in red</p>	insignificant
783.	<p>Prevention of installation of gas cylinders at the generator gas stations (synchronous compensator) to fill their bodies with hydrogen or inert gas, except for accidents with centralized systems for supplying these gases or their repair</p>	significant
784.	<p>Prevention of flammable works (welding, grinding, soldering) directly on the housings of units, apparatuses and gas pipelines filled with hydrogen</p>	gross
	<p>Availability of safety signs on generator housings (synchronous compensators) and equipment of</p>	

785.	gas-oil system with hydrogen cooling "Do not use open fire," "Do not smoke," "Caution! Danger of explosion, "and in visible places of the oil system - a warning sign:" Caution! Flammable substances " unless fire-resistant oils are used. Safety sign on gas turbine units' housings "Caution! Explosion danger"	insignificant
786.	Passing by maintenance personnel of energy-producing organizations before appointment for independent work of production training, as well as testing of knowledge of safety and operation of equipment	insignificant
787.	Execution of fire-fighting measures in places of contact of combustible building structures of the power plant building with exhaust pipes: 1) presence in the attic room and walls around the passing exhaust pipe, regardless of the presence of thermal insulation, non-combustible cutting at a distance of at least 0.5 meters from the wall of the exhaust pipe. Treatment of wooden structures at a distance of up to 1 meter from the pipe with fire retardant compositions; 2) in the roof around the outgoing exhaust pipe, cutting out of non-combustible materials for a width of at least 0.5 meters from the pipe; 3) execution of exhaust pipe height at least 2 meters above the roof; 4) entering the end of the exhaust pipe into a concrete or brick silencer (sump) located outside the building at its horizontal position	gross
788.	Prevention of storage of empty barrels from petroleum products in rooms	significant
789.	Prevention of storage of storerooms and auxiliary facilities in rooms and corridors of closed switchgears that shall not be related to the switchgear, as well as storage of electrical equipment, materials, spare parts, tanks with combustible liquids and cylinders with various gases	gross

790.	Regular inspection of cable structures according to the schedule approved by the workshop manager. Recording of inspection results and identified deficiencies in the operational log and log (or file cabinet) of defects and failures with equipment	insignificant
791.	Prevention of storerooms, workshops , as well as storage of materials and equipment, including unused cable products in rooms of closed switchgears	gross
792.	In cable structures, the presence of signs of the nearest exit in at least 50 meters	insignificant
793.	Make the doors of sectional partitions of cable structures self-closing, opening towards the nearest exit and have a tight narthex	gross
794.	Prevention of oil-filled combustible materials storage cables not related to this unit in the premises of makeup devices	significant
795.	On-board enclosures of oil receiving devices shall be made along the entire perimeter of gravel filling without breaks at least 150 millimetres above the ground	significant
796.	Prevention of the use (accessory) of cable channel walls as an on-board fence for oil receivers of transformers and oil reactors	significant
797.	Prevention of commissioning of transformers and oil reactors at power plants and substations, unless full readiness for operation of fire extinguishing units provided for by the design shall be ensured	significant
798.	The presence of inscriptions on the doors of the storage battery premises , as well as the necessary prohibiting and prescribing safety signs	insignificant
799.	Execution of glass matte or coated with white adhesive paint resistant to aggressive environment in natural light of the storage battery room	insignificant
800.	Prevention of smoking, acid and alkali storage in quantities exceeding one-shift demand directly in the rooms of storage batteries, leaving	significant

	overalls, foreign objects and combustible materials	
801.	Provision of free access to warehouse buildings on the territory of power plants. Presence of gaps of at least 5 meters between stacks of materials and equipment storage and passages for fire engines	significant
802.	Prevention in the warehouse area: 1) obstructing fire breaks and passages between buildings, stacks of materials and equipment, as well as their installation near buildings even for a short time; 2) incineration of packaging, containers and other wastes; 3) storage of goods and loading mechanisms at unloading sites of warehouses	gross
803.	Warehouse compliance with the following requirements: 1) storage of flammable and combustible liquids separately from other materials; 2) separate storage of varnishes, paints and solvents; 3) separate storage of gas cylinders and poisonous substances. Grouping of various materials and equipment for storage and storage based on signs of homogeneity of their combustibility (combustible, hardly combustible) and the use of fire extinguishing agents (water, foam) to them	significant
804.	Availability of at least two exits or one exit and a window in storage rooms located in basement or basement floors to ensure evacuation of people directly to the first floor, as well as for introduction of fire extinguishing equipment	gross
805.	Prevention in warehouses: 1) smoking and using open fire; 2) storage of various materials and equipment at a distance of less than 1 meter from heating devices; 3) laying of transit communications (cables, gas pipelines, steam and water pipelines);	gross

	4) storing, even temporarily, various materials in the passages between racks, stacks, as well as between racks, stacks and the warehouse wall	
806.	Location of a disconnecting device for de-energizing (automatic, switch) outside the warehouse premises on a non-combustible wall, and for combustible and hardly combustible warehouse buildings - on a free-standing support	gross
807.	Ensuring storage of varnishes, paints, oils, solvents (subject to the principle of product uniformity) in metal barrels, jars, containers with tightly closed covers in separate rooms or compartments of the warehouse (boxes)	significant
808.	Storage of metal powders capable of self-ignition (aluminium powder, magnesium powder) in metal cans with tightly closed covers in dry rooms	significant
809.	Prevention of storage of nitro-lacquers, nitro-paints and solvents in basement rooms	significant
810.	Storage and dispensing of varnishes and paints in a separate room equipped with electrical lighting and ventilation in explosion-proof design . Use of special hand pumps, gauges or small mechanization means for filling (packing) varnishes, paints and solvents	significant
811.	Prevention of operation of warehouses with paint and varnish rooms in case of faulty supply and exhaust ventilation	significant
812.	Operation, storage and transportation of cylinders at the enterprise according to the instructions approved by the chief engineer of the enterprise. Storage of cylinders under canopies in open areas to protect against atmospheric precipitation and sunlight. Availability of fencing of open areas	insignificant
813.	Prevention of storage of materials and equipment in the premises of	significant

	cylinder warehouses, as well as joint placement of gas cylinders in common warehouses	
814.	Preventing the use of combustible materials to cover the floor of warehouses with cylinders	gross
815.	Storage of filled cylinders in vertical position, for which the open and closed warehouses shall be equipped with "sockets" or barriers that protect the cylinders from falling. Storage of filled and empty cylinders separately	significant
816.	Preventing the installation of bitumen cookers, making fires and storing combustible materials within a radius of 50 meters around warehouses with cylinders	gross
Requirements to the facilities of the Armed Forces, other troops and military formations, law enforcement agencies		
817.	Presence of a fire protection plan approved by the commander in the military unit	insignificant
818.	The duty officer for the military unit has an extract from the plan, including fire safety requirements in the military unit, calculation of the forces and means involved in extinguishing the fire, the procedure for evacuating personnel, weapons, military and other equipment, property and material	insignificant
819.	The presence of an abnormal fire brigade of five to fifteen people in a military unit that shall not have a regular fire brigade	gross
820.	Permanent cleaning of the territory of the military unit and the external perimeter from garbage and dry grass at a distance of fifty meters	insignificant
821.	Prevention of fire breeding closer than fifty meters from buildings, sites with property, military and other equipment, as well as smoking and the use of devices with open fire in parks, storage facilities, hangars and similar premises, leaving lighting on when leaving the room	gross
822.	Prevention of works on the repair of equipment and networks of electricity, gas supply and central (autonomous) heating by persons who	gross

	do not have special training and permission to perform these works	
823.	Prevention of installation of highly flammable combustible liquids and combustible materials in the basements of workshop buildings and warehouses	gross
824.	Storage of fire extinguishing equipment in warehouses, parks, hangars and industrial premises on boards	insignificant
825.	The telephone sets have inscriptions indicating the telephone number of the nearest fire department, and on the territory of the military unit for sending a fire alarm signal means of sound alarm	insignificant
826.	Prevention of refuelling of vehicles at parking lots and storage of vehicles (aircraft) with leaking fuel tanks and fuel lines	gross
827.	Prevention of storage of lubricants, empty containers and fuel in parking areas of machines	significant
828.	Prevention of storage of foreign objects, oiled rags, covers, special clothes in machines	insignificant
829.	Prevention of storage of fuel tanks together with other equipment in tank farm storages and hangars	significant
830.	Prevention of welding works in the premises for parking of machines	gross
831.	Prevention of cluttering of gates in premises for parking and storage of machines, arrangement in these premises of storerooms, workshops and housing	gross
832.	Daily availability of on-duty tractors with special towing devices (devices) and the required number of military personnel to ensure the immediate withdrawal of vehicles (aircraft) in case of fire	insignificant
833.	Timely mowing and harvesting of grass on the territory of warehouses (storages). Prevention of dry grass drying and burning in warehouses (storages)	insignificant

834.	Storage in warehouses (storages) of only those types of property for which they shall be intended	significant
835.	Prevention of cluttering in warehouses (storages) of passages and exits, as well as upholstery of racks and darkening of windows with paper, cardboard, film made of polymer materials and fabrics not treated with fire retardant	gross
836.	The production of stacking of property so that passages and exits remain free. Prevention of laying of property close to furnaces, heating radiators, electrical wiring and lamps	gross
837.	Prevention of storage near warehouses (storages) of construction materials, fuel reserves, property. Arrangement of furnaces and wood holes of furnaces outside warehouses (storages), provision of pipes with spark catchers	gross
Requirements for non-state fire service facilities		
838.	The non-state fire service has a certificate for the right to carry out work on fire prevention and extinguishing, ensuring fire safety and emergency rescue operations at facilities	gross
839.	Hiring citizens of the Republic of Kazakhstan who have reached eighteen years of age and have completed special training courses in specialized training centres in the field of fire safety for training, retraining and advanced training of specialists of non-state fire services	gross
840.	Availability of documentation regulating the activities of the non-state fire service	gross
841.	Maintenance of the non-state fire service in constant (round-the-clock) readiness	gross
842.	Presence in fire departments of a non-state fire service of a calculation on a fire truck, headed by the commander of the calculation	gross
843.	The presence of a guard headed by the head of the guard (shift manager) in the presence of two or more fire trucks in the non-state fire service	gross

844.	Availability of a fire prevention group with instructors in fire departments with field equipment	gross
845.	Availability of fire-fighting instructors (at least 2 full-time employees in duty shift), to protect facilities where a non-state fire service has been established without field equipment	gross
846.	Availability of a communication point in fire departments and posts of the non-state fire service	gross
847.	Provision of fire trucks with mobile radio stations, fire extinguishing manager, employees on duty and in accordance with the working conditions located outside the place of permanent deployment of the fire department or post by portable means of communication	gross
848.	Availability of a gas and smoke protection service established by decision of the facility manager	gross
849.	Availability of the required number of main firefighting vehicles for the non-state fire service	gross
850.	Availability of portable or mobile fire motor pumps in case of repair and/or maintenance of the main fire fighting vehicles required to extinguish fires at the facilities	gross
851.	Availability of the appropriate number of special firefighting vehicles for the non-state fire service determined by the facility manager taking into account their specifics	gross
852.	Location and operation of fire fighting vehicles in accordance with the safety requirements of firefighting equipment for the protection of facilities	gross
853.	Availability of the appropriate number of employees of the non-state fire service at the facility in the duty shift, according to the number of fire trucks multiplied by the number of calculations on the fire truck	gross
	Implementation of annual special training of employees in the non-state fire service, including	

854.	theoretical and practical exercises, taking into account the production characteristics of the facility	gross
requirements for rotational facilities		
855.	Provision of a mineralized strip along the perimeter with a width of at least 4 meters of the territory of the rotation facility during the spring-summer fire hazard period	significant
856.	Parking of vehicles, equipment at a distance of at least 15 meters from block containers, structures, places of open storage of materials and equipment	significant
857.	Prevention of parking of fuelling equipment at a distance of less than 50 meters from block containers, structures, places of open storage of materials and equipment, parking lots of motor vehicles	significant
858.	Availability of a scheme at the entrance to the rotational facility indicating: 1) places of placement of buildings, block containers, structures, vehicles , machinery, places of storage of materials and equipment; 2) organization of movement of motor vehicles; 3) locations of primary fire extinguishing equipment; 4) locations of the nearest fire water sources	insignificant
859.	Availability of grounding of buildings, structures, buildings of electrical equipment control panels, block containers	gross
860.	Prevention of the use of open fire in premises, structures, block containers	gross
861.	Provision of protective equipment for each person individually in the premises of rotation facilities. Availability of fire safety instructions in visible places in the premises of the rotational facility	gross
862.	Familiarization of individuals living at the rotational facilities with instructions on fire safety measures against signature or during fire briefing at the workplace	insignificant

863.	The length of the evacuation exit from the most remote point to the location of a person shall not be more than 20 meters during the assembly of block containers, prefabricated modular complexes	gross
864.	Provision of factory heating with heating elements of closed type in block containers, prefabricated modular complexes	significant
865.	Prevention of cylinders with compressed and/or liquefied gas, tanks with flammable and combustible liquids, drying clothes and linen on the surfaces of heating devices, making fires, using open fire on the territory of the rotational facility	gross
Permitting requirements for the non-state fire service with field fire equipment certified according to the permitting requirements valid until July 31, 2018		
866.	Availability of at least one fire truck	gross
	<p>Availability of fire-technical equipment and equipment on fire-fighting equipment:</p> <ol style="list-style-type: none"> 1) suction hose with a length of 4 m with a diameter of 125 mm in the amount of 2 pieces; 2) suction hose with a length of 4 m with a diameter of 75 mm in the amount of 2 pieces; 3) pressure hose, for operation from a hydrant, with a length of 4-5 m with a diameter of 77 mm in the amount of 2 pieces; 4) pressure hose with a length of 20 m with a diameter of 77 mm in the amount of 6 pieces; 5) pressure hose with a length of 20 m with a diameter of 66 mm in the amount of 10 pieces; 6) pressure hose with a length of 20 m with a diameter of 51 mm in the amount of 6 pieces; 7) suction hose with a length of 4 m with a diameter of 30 mm in the amount of 1 piece; 8) mesh for suction hose CB -125, with rope 12 m long in the amount of 1 piece; 9) 3-way branching PT - 70 (PT - 80) in the amount of 2 pieces; 	

867.

- 10) hose sump BC - 125 with plugs in the amount of 1 piece;
- 11) end wrench for opening hydrants in the amount of 1 piece;
- 12) guiding cable of gas and smoke protection service in the amount of 1 piece;
- 13) 66x51 adapter head in the amount of 2 pieces;
- 14) transition connecting head 77x51 in the amount of 2 pieces;
- 15) transition connecting head 77x66 in the amount of 2 pieces;
- 16) hose delay in the amount of 4 pieces;
- 17) sleeve clamps in the amount of 4 pieces;
- 18) fire column in the amount of 1 piece;
- 19) wrenches for connection of suction hoses K-150 in the amount of 2 pieces;
- 20) wrenches for connection of pressure hoses K-80 in the amount of 2 pieces;
- 21) wrench for opening of hydrant covers in the amount of 1 piece;
- 22) Г -600 hydraulic elevator in the amount of 1 piece;
- 23) PCK -50 barrel in the amount of 4 pieces;
- 24) PCA barrel in the amount of 2 gross
- 25) PC -70 barrel in the amount of 2 pieces;
- 26) air-foam CBП -4 barrel in the amount of 2 pieces;
- 27) portable monitor in the amount of 1 piece;
- 28) medium-fold foam generator ППС -600 in the amount of 2 pieces;
- 29) tricycle ladder in the amount of 1 piece;
- 30) assault staircase in the amount of 1 piece;
- 31) ladder-stick in the amount of 1 piece;
- 32) metal spear 2.5 m long in the amount of 1 piece;
- 33) universal scrap in the amount of 1 piece;

	<p>34) blacksmithing sledgehammer in the amount of 1 piece;</p> <p>35) carpentry ax in the amount of 1 piece;</p> <p>36) bayonet shovel in the amount of 1 piece;</p> <p>37) saw-cutter on wood in a wooden case;</p> <p>38) scissors for cutting reinforcement;</p> <p>39) a set of tools for cutting electrical wires, including: scissors with a dielectric handle; dielectric gloves; dielectric bots; dielectric mat ;</p> <p>40) rescue rope, 30 m long in a canvas cover;</p> <p>41) heat reflecting suit in the amount of 3 pieces;</p> <p>42) rubber boots in the amount of 4 pairs;</p> <p>43) electric individual canopy in the amount of 5 pieces;</p> <p>44) electric group canopy in the amount of 1 piece;</p> <p>45) medical first-aid kit in the amount of 1 set;</p> <p>46) fire extinguisher OY-5 or OII - 5 in the amount of 1 piece;</p> <p>47) scoop shovel in the amount of 1 piece;</p> <p>48) a set of tools for vehicle maintenance in the amount of 1 set;</p> <p>49) automobile radio station in the amount of 1 piece;</p> <p>50) portable radio station in the amount of 4 pieces;</p> <p>51) signal-loudspeaker in the amount of 1 piece;</p> <p>52) jack from 5 to 10 tons in the amount of 1 piece.</p>	
868.	Availability of a building or premises for accommodation of employees, fire and rescue equipment, equipment and equipment on the right of ownership or other legal right	significant
869.	Availability of at least 16 full-time employees, at the rate of 4 employees including the driver for each main fire truck in the duty shift	significant

Qualification of employees of non-state fire-fighting services with field equipment:

1) for the head of the service (detachment) and his deputy, the head of the fire department and his deputy , the availability of documents confirming - higher technical education or secondary technical education in the field of fire safety, at least 3 years of experience in senior positions of control apparatus or fire extinguishing units of state fire service bodies;

2) for the head of the fire station and his deputy, the availability of documents confirming - higher technical education or secondary technical education in the field of fire safety, at least 1 year of work experience in the positions of control devices or fire service units;

3) for the head of the guard (shift supervisor) availability of documents confirming - secondary technical education, at least 1 year of work experience in positions in fire service units, special training in a specialized training centre in the field of fire safety;

4) for the foreman of the gas and smoke protection service, the availability of documents confirming - secondary education, special training in a specialized training centre in the field of fire safety and having access to work in compressed air devices;

5) for the commander of the department, the presence of documents confirming - secondary education, at least 1 year of work experience in positions in the fire service units, special training in a specialized training centre in the field of fire safety;

6) for the senior firefighter, availability of documents confirming - secondary education, special training in a specialized training centre in the field of fire safety;

7) for the driver (senior driver) of a fire truck, the presence of documents confirming - secondary education, a

870.

significant

	<p>driver's license of category "C" with experience of at least 1 year of driving a car in this category, passing special training in a specialized training centre in the field of fire safety;</p> <p>8) for a radio telephone operator (communication point dispatcher), the presence of documents confirming - secondary education, special training in a specialized training centre in the field of fire safety.</p>	
871.	<p>Availability of special uniforms and fire-fighting equipment for one employee of the non-state fire-fighting service:</p> <ol style="list-style-type: none"> 1) firefighter's combat clothing; 2) wool slipper; 3) sweater without protective colour cut-out; 4) canvas mittens with crags; 5) fur mittens with crags; 6) rescue fire belt with a carbine; 7) fire helmet (helmet); 8) fireman's boots; 9) belt holster for fireman's axe; <p>the rubber boots</p>	significant
Permitting requirements for the non-state fire service with field fire-fighting equipment certified under the permitting requirements established after July 31, 2018		
872.	<p>Availability of at least two fire-fighting vehicles owned or leased as lessee, confirmed by vehicle registration certificates</p>	gross
	<p>Availability of fire-technical equipment and equipment on fire-fighting equipment:</p> <ol style="list-style-type: none"> 1) suction hose with a length of 4 m with a diameter of 125 mm in the amount of 2 pieces; 2) suction hose with a length of 4 m with a diameter of 75 mm in the amount of 2 pieces; 3) pressure hose, for operation from a hydrant, with a length of 4-5 m with a diameter of 77 mm in the amount of 2 pieces; 4) pressure hose with a length of 20 m with a diameter of 77 mm in the amount of 6 pieces; 5) pressure hose with a length of 20 m with a diameter of 66 mm in the amount of 10 pieces; 	

- 6) pressure hose with a length of 20 m with a diameter of 51 mm in the amount of 6 pieces;
- 7) suction hose with a length of 4 m with a diameter of 30 mm in the amount of 1 piece;
- 8) mesh for suction hose CB -125, with rope 12 m long in the amount of 1 piece;
- 9) 3-way branching PT - 70 (PT - 80) in the amount of 2 pieces;
- 10) hose sump BC - 125 with plugs in the amount of 1 piece;
- 11) end wrench for opening hydrants in the amount of 1 piece;
- 12) guiding cable of gas and smoke protection service in the amount of 1 piece;
- 13) 66x51 transition connecting head in the amount of 2 pieces;
- 14) transition connecting head 77x51 in the amount of 2 pieces;
- 15) transition connecting head 77x66 in the amount of 2 pieces;
- 16) hose delay in the amount of 4 pieces;
- 17) sleeve clamps in the amount of 4 pieces;
- 18) fire column in the amount of 1 piece;
- 19) wrenches for connection of suction hoses K-150 in the amount of 2 pieces;
- 20) wrenches for connection of pressure hoses K-80 in the amount of 2 pieces;
- 21) wrench for opening of hydrant covers in the amount of 1 piece;
- 22) Г -600 hydraulic elevator in the amount of 1 piece;
- 23) PCK -50 barrel in the amount of 4 pieces;
- 24) PCA barrel in the amount of 2 pieces;
- 25) PC -70 barrel in the amount of 2 pieces;
- 26) air-foam CBII -4 barrel in the amount of 2 pieces;
- 27) portable monitor in the amount of 1 piece;
- 28) medium-fold foam generator ГПЧ -600 in the amount of 2 pieces;

873.

gross

- 29) tricycle ladder in the amount of 1 piece;
- 30) assault staircase in the amount of 1 piece;
- 31) ladder-stick in the amount of 1 piece;
- 32) metal pole 2.5 m long in the amount of 1 piece;
- 33) universal scrap in the amount of 1 piece;
- 34) blacksmithing sledgehammer in the amount of 1 piece;
- 35) carpentry ax in the amount of 1 piece;
- 36) bayonet shovel in the amount of 1 piece;
- 37) saw-cutter on wood in a wooden case;
- 38) scissors for cutting reinforcement;
- 39) a set of tools for cutting electrical wires, including: scissors with a dielectric handle; dielectric gloves; dielectric bots; dielectric mat ;
- 40) rescue rope, 30 m long in a canvas cover;
- 41) heat reflecting suit in the amount of 3 pieces;
- 42) rubber boots in the amount of 4 pairs;
- 43) electric individual canopy in the amount of 5 pieces;
- 44) electric group canopy in the amount of 1 piece;
- 45) medical first-aid kit in the amount of 1 set;
- 46) fire extinguisher OY-5 or OII - 5 in the amount of 1 piece;
- 47) scoop shovel in the amount of 1 piece;
- 48) a set of tools for vehicle maintenance in the amount of 1 set;
- 49) automobile radio station in the amount of 1 piece;
- 50) portable radio station in the amount of 4 pieces;
- 51) signal-loudspeaker in the amount of 1 piece;
- 52) jack from 5 to 10 tons in the amount of 1 piece.

874.	Availability of a building or premises for accommodation of employees, fire and rescue equipment, equipment and equipment on the right of ownership or other legal right	significant
875.	Availability of at least 17 full-time employees, at the rate of 1 head of subdivision, 4 employees including the driver for each main fire truck in duty shift	significant
876.	<p>Qualification of employees of non-state fire-fighting services with field equipment:</p> <p>1) for the head of the service (detachment) and his deputy, the head of the fire department and his deputy , the availability of documents confirming - higher technical education or secondary technical education in the field of fire safety, at least 3 years of experience in senior positions of control apparatus or fire extinguishing units of state fire service bodies;</p> <p>2) for the head of the fire station and his deputy, the availability of documents confirming - higher technical education or secondary technical education in the field of fire safety, at least 1 year of work experience in the positions of control devices or fire service units;</p> <p>3) for the head of the guard (shift supervisor) availability of documents confirming - secondary technical education, at least 1 year of work experience in positions in fire service units, special training in a specialized training centre in the field of fire safety;</p> <p>4) for the foreman of the gas and smoke protection service, the availability of documents confirming - secondary education, special training in a specialized training centre in the field of fire safety and having access to work in compressed air devices;</p> <p>5) for the commander of the department, the presence of documents confirming - secondary education, at least 1 year of work</p>	significant

	<p>experience in positions in the fire service units, special training in a specialized training centre in the field of fire safety;</p> <p>6) for the senior firefighter, firefighter, availability of documents confirming - secondary education, special training in a specialized training centre in the field of fire safety;</p> <p>7) for the driver (senior driver) of a fire truck, the presence of documents confirming - secondary education, a driver's license of category "C" with experience of at least 1 year of driving a car in this category, passing special training in a specialized training centre in the field of fire safety;</p> <p>8) for a radio telephone operator (communication point dispatcher), the presence of documents confirming - secondary education, special training in a specialized training centre in the field of fire safety.</p>	
877.	<p>Availability of special uniforms and fire-fighting equipment for one employee of the non-state fire-fighting service:</p> <p>1) firefighter's combat clothing;</p> <p>2) wool slipper;</p> <p>3) sweater without protective colour cut-out;</p> <p>4) canvas mittens with crags;</p> <p>5) fur mittens with crags;</p> <p>6) rescue fire belt with a carbine;</p> <p>7) fire helmet (helmet);</p> <p>8) fireman's boots;</p> <p>9) belt holster for fireman's axe;</p> <p>10) rubber boots</p>	significant
Permitting requirements for the non-state fire service without field fire-fighting equipment, according to the permitting requirements valid until July 31, 2018		
878.	<p>Availability of at least 8 full-time employees, at the rate of 2 employees per duty shift</p>	significant
	<p>Qualification of employees of non-state fire-fighting services without field equipment:</p> <p>1) for the senior fire prevention instructor, the availability of documents confirming - secondary technical education, at least 1 year of</p>	

879.	work experience in positions in fire service units, special training in a specialized training centre in the field of fire safety; 2) for the fire prevention instructor, the availability of documents confirming - secondary education, special training in a specialized training centre in the field of fire safety.	significant
Permitting requirements for the non-state fire service without field fire-fighting equipment, according to the permitting requirements established after July 31, 2018		
880.	Availability of at least 9 full-time employees, at the rate of 1 head of post and 2 employees in duty shift	significant
881.	Qualification of employees of non-state fire-fighting services without field equipment: 1) for the senior fire prevention instructor, the availability of documents confirming - secondary technical education, at least 1 year of work experience in positions in fire service units, special training in a specialized training centre in the field of fire safety; 2) for the fire prevention instructor, the availability of documents confirming - secondary education, special training in a specialized training centre in the field of fire safety.	significant
Permitting requirements for fire safety audit expert organizations		
882.	Availability of at least three specialists meeting one of the following conditions: availability of documents confirming higher education in the specialty - fire safety; having other higher education and work experience in state and (or) non-state fire services for at least five years	gross
883.	Availability of employment contracts for employment of specialists	significant
884.	Availability of premises owned by an expert organization on the right of ownership or another legal basis	significant

control with visit subject (object) of
control
and fire supervision safety and inspections
for compliance permitting requirements
according to the permits issued

List of subjective criteria for determining the degree of risk by subjective criteria in the field of state control and supervision in the field of fire safety in accordance with Articles 138 and 139 of the Entrepreneur Code of the Republic of Kazakhstan in relation to subjects (objects) of control and supervision in the field of fire safety

Footnote. The criteria as added by Annex 2 in accordance with the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).

№ r/n	Subjective criterion indicator	Source of information on the subjective criterion indicator	Specific gravity by significance, point (in total should not exceed 100 points), wi	Conditions/values, xi condition/value
1	2	3	4	5
For preventive control with visit				
1	Administrative penalty on a business entity under Article 410 of the Code of Administrative Offenses of the Republic of Kazakhstan	The presence of adverse incidents (fires) caused by a state control entity (object) and supervision in the form of an administrative penalty on a business entity under Article 410 of the Code of Administrative Offenses of the Republic of Kazakhstan	35	1 fact 100%
2	Facility operation 5 years or more	Results of analysis of information submitted by state agencies and organizations	35	1 fact 100%
3	Carrying out activities with confirmed information on load	Results of analysis of information	30	1 fact

	violations (design capacity), three-shift training	submitted by the state agencies and organizations		100%
For compliance verifications				
1	Administrative penalty on a business entity under Article 410 of the Code of Administrative Offenses of the Republic of Kazakhstan	The availability of adverse incidents (fires) caused by a subject (object) of state control and supervision in the form of an administrative penalty on a business subject under Article 410 of the Code of Administrative Offenses of the Republic of Kazakhstan	20	1 fact 100%
2	Availability of a certificate of non-state fire-fighting services and expert organizations on audit in the field of fire safety	Results of analysis of information submitted by state agencies and organizations	80	1 fact 100%

Annex 2 to a joint order
of Minister of the Republic of Kazakhstan
dated October 30, 2018 № 758
and of Minister of National Economy of
the
Republic of Kazakhstan
dated October 30, 2018 № 31

Criteria for assessing the degree of risk used for preventive control with a visit to the subject (object) of control in the field of civil defence

Footnote. Annex 2 - as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall enter into force from 01.01.2023).

Chapter 1. General provision

1. These risk assessment criteria used for preventive control with subject visit (objects) of control in the field of civil defence (hereinafter referred to as the Criteria) have been developed in accordance with the Entrepreneur Code of the Republic of Kazakhstan, The Law of the Republic of Kazakhstan "On civil protection," the Rules for the formation of a risk

assessment and management system by regulatory state bodies, approved by order of the Acting Minister of National Economy of the Republic of Kazakhstan dated June 22, 2022 № 48 (registered in the Register of State Registration of Regulatory Legal Acts № 28577), by order of the Acting Minister of National Economy of the Republic of Kazakhstan dated July 31, 2018 № 3 "On approval of the verification sheet form" (registered in the Register of State Registration of Regulatory Legal Acts № 17371).

2. Criteria shall be formed by defining objective and subjective criteria.

Chapter 2. Objective criteria

3. Objective criteria shall be determined through risk determination.

Risk determination shall be carried out depending on the specifics of the sphere in which state control shall be carried out, taking into account one of the following criteria:

1) hazard level (complexity) of the facility;

2) the scale of severity of possible negative consequences, harm to the regulated sphere (area);

3) the possibility of an adverse incident for human life or health, the environment, the legitimate interests of individuals and legal entities, the state.

4. After analyzing all possible risks, the subjects (objects) of control shall be distributed according to two levels of risk (high and medium).

Footnote. Paragraph 4 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and the acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication)

5. High risk shall include:

1) organizations classified as civil defence with the highest working shift;

2) organizations, which shall be assigned places of mass recreation on natural and artificial reservoirs;

3) excluded - by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and the acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication).

Footnote. Paragraph 5 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and the acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication)

6. Medium risk shall include:

1) organizations classified as civil defence;

2) organizations on the basis of which civil protection services shall be created.

7. Excluded - by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and the acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication).

8. For the areas of activity of subjects (objects) of control classified as high and medium risk, preventive control shall be carried out with a visit to the subject (object) of control and an unscheduled inspection.

9. Excluded - by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and the acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication).

10. With respect to subjects (objects) of control classified as high and medium risk, subjective criteria shall be applied in order to conduct preventive control with a visit to the subject (object) of control.

Chapter 3. Subjective criteria

11. Subjective criteria shall be defined based on the following sources of information:

1) results of monitoring reports and information submitted by the control entity (reports on the implementation of civil defence measures);

2) the results of the previous preventive control with a visit to the subject (object) of control and unscheduled inspections;

3) excluded by joint order of acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication);

4) excluded by joint order of acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication);

5) excluded by joint order of acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication);

6) excluded by joint order of acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).

Footnote. Paragraph 11 as amended by the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting

Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).

$$R_{\text{проМ}} = SP + SC, \text{ where}$$

12. Based on available sources of information, subjective criteria to be evaluated shall be formed.

13. Analysis and assessment of subjective criteria shall make it possible to concentrate the preventive control of the subject (object) of control in relation to the subject (object) of control with the highest potential risk.

14. When analysing, the data of subjective criteria previously taken into account and used in relation to a specific subject (object) of control or data for which the limitation period has expired in accordance with the legislation of the Republic of Kazakhstan shall not be used.

15. When forming lists for the next period of state control, it is not allowed to include subjects of control who have eliminated in full the issued violations following the results of the previous preventive control with a visit.

16. Depending on the possible risk and significance of the problem, the singularity or system of the violation, analysis of earlier decisions on each source of information, subjective criteria are determined, which, in accordance with the Criteria, correspond to the degree of violation - gross, significant and insignificant.

17. The requirements of civil defence shall be attributed to a rough degree, the failure of which shall lead to a decrease in the country's defence capability.

18. Civil defence requirements, attributed to a significant and insignificant degree, shall be organizational in nature.

19. The distribution of civil defence violations to gross, significant, insignificant degrees shall be given in the Annex to these Criteria.

20. When calculating the risk level indicator, the specific gravity of unfulfilled civil defence requirements shall be determined.

21. If one gross violation is detected, the control subject is equated with a risk level indicator of 100 and preventive control shall be carried out with a visit to the control subject (object).

21-1. Calculation of the risk level indicator according to subjective criteria (R) shall be carried out in an automated mode by summing up the risk level indicator according to violations based on the results of previous preventive control with visiting the subjects (objects) of control (SP) and the risk level indicator according to subjective criteria determined in accordance with paragraph 22-1 of these Criteria (SC), with subsequent normalization of data values in the range from 0 to 100 points.

$$R_{\text{проМ}} = SP + SC, \text{ where}$$

Rprom - an intermediate indicator of the degree of risk according to subjective criteria,

SP - an indicator of the degree of risk by violations,

SC - an indicator of the degree of risk according to subjective criteria determined in accordance with paragraph 22-1 of these Criteria.

Calculation shall be carried out for each subject (object) of control of a homogeneous group of subjects (objects) of control of each sphere of state control. At the same time, the list of evaluated subjects (objects) of control, referred to a homogeneous group of subjects (objects) of control of one sphere of state control, forms a selective collection (selection) for the subsequent normalization of data.

Footnote. The criteria as added by paragraph 21-1 in accordance with the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).

22. At not identification of gross violations of definition of an exponent of risk pays off a total indicator on violations of significant and insignificant degree.

When determining an indicator of significant violations, the coefficient 0.7 shall be applied and this indicator shall be calculated by the following formula:

$$SP_3 = (SP_2 \times 100 / SP_1) \times 0,7, \text{ where:}$$

SP_3 - an indicator of significant violations;

SP_1 - the required number of significant violations;

SP_2 - number of detected significant violations;

When determining the indicator of minor violations, a coefficient of 0.3 is used and this indicator shall be calculated using the following formula:

$$SP_H = (SP_2 \times 100 / SP_1) \times 0,3, \text{ where:}$$

SP_H - indicator of minor violations;

SP_1 - required number of minor violations;

SP_2 - number of detected minor violations;

The overall risk score (SP) shall be calculated on a scale of 0 to 100 and shall be determined by summing significant and minor impairment scores using the following formula

:

$$SP = SP_3 + SP_H, \text{ where:}$$

SP - an indicator of the degree of risk for violations;

SP_3 - an indicator of significant violations;

SP_H - an indicator of minor violations.

Footnote. Paragraph 22 - in the wording of the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting

Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).

22-1. Based on the priority of the applied sources of information and the significance of subjective criteria indicators, in accordance with the procedure for calculating the risk level indicator according to the subjective criteria determined in paragraph 22 of these Criteria, the risk level indicator shall be calculated according to subjective criteria on a scale of 0 to 100 points.

The list of subjective criteria for determining the degree of risk by subjective criteria in the field of state control in the field of civil defence shall be determined in accordance with Annex 2 to these Criteria.

Footnote. The criteria as added by paragraph 22-1 in accordance with the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).

22-2. Calculation of the risk level according to subjective criteria shall be carried out on a scale from 0 to 100 points and shall be carried out according to the following formula:

$$SC = \sum_{i=1}^n x_i * w_i, \text{ где}$$

x_i - an indicator of the subjective criterion,

w_i - specific gravity of the index of subjective criterion x_i ,

n - the number of indicators.

The obtained value of the risk level indicator according to subjective criteria shall be included in the calculation of the risk level indicator according to subjective criteria.

Footnote. The criteria as added by paragraph 22-2 in accordance with the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).

22-3. The values calculated by subjects (objects) for the R parameter shall be normalized in the range from 0 to 100 points. Data normalization shall be carried out for each sample set (sample) using the following formula:

$$R = \frac{R_{\text{пром}} - R_{\text{min}}}{R_{\text{max}} - R_{\text{min}}},$$

R – an indicator of the degree of risk (final) according to the subjective criteria of an individual subject (object) of control,

R_{\max} - the maximum possible value on the scale of the degree of risk according to subjective criteria for subjects (objects) included in one selective set (sample) (upper limit of the scale),

R_{\min} - the minimum possible value on the scale of the degree of risk according to subjective criteria for subjects (objects) included in one selective set (sample) (lower limit of the scale),

$R_{\text{ПРОМ}}$ - an intermediate indicator of the degree of risk according to subjective criteria, calculated in accordance with paragraph 21-1 of Annex 2 of these Criteria.

Footnote. The criteria as added by paragraph 22-3 in accordance with the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).

23. According to the indicators of the degree of risk, the subject (object) of control shall refer to:

1) to a high degree of risk - with an indicator of the degree of risk from 71 to 100 inclusive;

2) to the average degree of risk - with an indicator of the degree of risk from 31 to 70 inclusive;

3) to a low risk level - with a risk level indicator from 0 to 30 inclusive.

Footnote. Paragraph 23 - in the wording of the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).

24. For the areas of activity of the subjects (objects) of control classified as high risk, the frequency of preventive control with a visit to the subject (object) of control is not more than once a year.

25. For the areas of activity of the subjects (objects) of control classified as medium risk, the frequency of preventive control with a visit to the subject (object) of control shall not be more than once every two years.

26. Excluded - by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and the acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication).

27. Based on the assessment of sources of information and subjective criteria, semi-annual lists of preventive control are automatically formed with a visit to the subject (object) of control.

28. Preventive control with a visit to the subject (object) of control shall be carried out on the basis of semi-annual lists of preventive control with a visit to the subject (object) of control, formed in accordance with the requirements of the Entrepreneur Code of the Republic of Kazakhstan.

29. Lists of preventive control with a visit to the subject (object) of control shall be compiled taking into account the priority of the subject (object) of control with the highest indicator of the degree of risk according to subjective criteria according to the Annex to these Criteria.

Annex 1
to the Risk assessment criteria,
used for preventive control
by visiting the subject (object) of control
in the field of civil defence

Footnote. The upper right corner - in the wording of the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).

**Degree of violation of requirements to subjects (objects) of control
in the field of civil defence during preventive control with visit**

Footnote. The title - in the wording of the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).

Footnote. Annex 1 as amended by the joint order of the Acting Minister for Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 ((shall enter into force upon expiry of ten calendar days after the day of its first official publication); Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication).

№ r/n	Name of requirements in the field of civil defence (the degree of violation shall be established in case of non-compliance with the specified requirement)	Level of violation
<i>Footnote. The title of Chapter 1 as excluded by a joint order of acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of</i>		

Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).

1.	Submission of the annual report on the civil defence activities performed in the current year on time	gross
2.	Availability of information in the submitted annual report on the implementation of civil defence activities	gross

Footnote. The title of Chapter 2 as excluded by a joint order of acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).

3.	Excluded by joint order Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication).
4.	
5.	
6.	
7.	

6.	Availability of a legal act on the creation of a structural unit or individual employees for the organization and conduct of civil defence	gross
----	--	-------

7.	Availability of civil defence plan approved by civil defence chief	gross
----	--	-------

8.	Excluded by joint order Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication).
9.	

10.	Availability of an emergency response plan for facility-based situations and their consequences	gross
-----	---	-------

11.	Compliance with the structure and content of the civil defence plan and Emergency response plan	significant
-----	---	-------------

12.	Availability of a legal act establishing an evacuation commission	
-----	---	--

13.	
14.	
15.	
16.	
17.	
18.	
19.	
20.	
21.	

22.	Excluded by joint order Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication).	
23.		
24.		
25.		
26.		
27.		
28.		
29.		
30.		
31.		
32.		
33.		
34.	Availability of civil defence protective structures, maintaining them in readiness for operation	gross
35.	Availability of an asylum passport (anti-radiation shelter)	gross
36.	Availability of a civil defence protective structure inspection log	significant
37.	Availability of a log of microclimate and air gas composition in the shelter (anti-radiation shelter)	significant
38.	Availability of civil defence protection plan	significant
39.	Availability of civil defence protection plan	gross
40.	Availability of a list of equipment, tools and property of a civil defence protective structure	significant
41.	Availability of the list of telephones of controls in the protective structure	significant
42.	Availability of a list of personnel of the protective structure maintenance team	significant
43.	Availability of operational diagram of life support systems of the protective structure (ventilation, water supply and sewerage, power supply of protective equipment)	significant
44.	Availability of instructions for servicing the diesel power plant, filtering and ventilation equipment (if any), protective structure	gross significant
45.	Availability of spare city, spare country, auxiliary and mobile control points	gross

46.	Availability, maintenance in good condition of the diesel power plant of the protective structure	gross
47.	Availability, maintenance in good condition of emergency lighting of the protective structure	gross
48.	Availability, serviceability of filtering ventilation equipment of the protective structure	gross
49.	Availability, maintenance in good condition of water supply of the protective structure	gross
50.	Availability, maintenance in good condition of the sewage system of the protective structure	gross
51.	Availability, maintenance in good condition of power supply and disconnecting devices (choppers, cranes, gate valves) of the protective structure	gross
52.	Availability, maintenance in good condition of protective-hermetic and hermetic doors, valves and explosion prevention devices of the protective structure	gross
53.	Presence of civil defence warning signals, rules for use of personal protective equipment, indicators of entrances and exits, diesel power plant and filter ventilation rooms, sanitary stations, water distribution points, sanitary posts of the protective structure at prominent places	significant
54.	Availability of lighting and designation of places of installation of fire protection equipment of the protective structure	significant
55.	Availability of the required quantity and maintenance of civil defence property in readiness	gross
56.	Availability of storage facilities for storage of civil defence property	gross
57.		
58.		
59.		
60.		
61.		
62.		

63.		
64.	Excluded by joint order Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication).	
65.		
66.		
67.		
68.		
69.		
70.		
71.		
72.		
73.		
74.		
75.		
76.	The organization has a legal act on the creation of facility civil protection formations	gross
77.	Excluded by joint order Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication).	
78.		
79.		
80.	Availability of respiratory protection equipment for each member of the civil protection formation	gross
81.	Availability of certificates of training in the territorial divisions of the authorized body of persons carrying out the organization and conduct of civil defence activities	insignificant
82.	Availability of certificates on training or retraining in educational institutions of the authorized body in the field of civil protection of officials who organize and conduct civil defence activities	insignificant
83.	Availability of the required, serviceable warning system	gross
84.	Availability of civil defence monitoring and laboratory control network for timely detection and indication of radioactive, chemical, biological contamination (contamination)	gross
85.	Availability of a set of tools for conducting classes on civil protection and a corner on civil protection	gross

86.	Presence of a multidisciplinary office or one civil protection corner in each administrative and production building	gross
87.	Availability of a list of training groups, session managers and a schedule of sessions approved by the head of the organization	significant
88.	Availability of civil protection training log	insignificant
89.	Availability of certificates of training in the field of civil protection of employees of the organization	significant
90.	Availability of information submitted to the territorial divisions of the authorized body in the field of civil protection on the conduct of exercises and training in the field of civil protection with attached copies of organizational documents	significant
91.	Readiness of the main civil protection units, including those included in the emergency response unit and the units providing emergency rescue and emergency operations	gross
92.	The organizer has a place of mass recreation, tourism and sports at water bodies and water facilities of the rescue post, the staff of the post depending on the length of the beach coastline (head of the post, rescue squad)	gross
93.	Availability of serviceable motor boats at the rescue post depending on the length of the beach coastline (with the inscription "rescue" on the sides)	gross
94.	Availability of serviceable paddle boats at the rescue post depending on the length of the beach coastline (with the inscription "rescue" on the sides)	gross
95.	Availability of serviceable portable radio stations at the rescue post at the rate of one radio station per rescue guard	gross
96.	Availability at the rescue post of serviceable rescue equipment "Rescue circles" in the amount of two units	gross

97.	Availability at the rescue post of serviceable rescue equipment "End-Alexandrov" in the amount of two units	gross
98.	Availability of serviceable two-unit "Megafon" loudspeakers at the rescue station	gross
99.	Availability of a sanitary bag with medicines at the rescue post (first aid kit)	gross
100.	The presence of the rescue vehicle "Tral with cats" at the rescue post	gross
101.	The presence of a rescue line at the rescue post with a length of at least 40 meters	gross
102.	Availability of a safety end at the rescue post at the rate of one safety end per lifeguard of a vigilante	gross
103.	Availability at the rescue station of set № 1 at the rate of one set № 1 per one lifeguard of a vigilante	significant
104.	The presence of binoculars at the rescue post at the rate of one binocular per rescue tower	gross
105.	The presence of a whistle at the rescue post at the rate of one whistle per lifeguard of a vigilante	insignificant
106.	The presence at the rescue post of a rescue bib at the rate of one rescue bib per one lifeguard of a vigilante	gross
107.	The presence of a pole and a rescue bug at the rescue post at the rate of one pole and a rescue bug for each lifeguard of the vigilante	gross
108.	The presence of an observation tower (depending on the coverage of the entire controlled service area)	gross
109.	Availability of a stand at the rescue post with materials on prevention of accidents in water bodies and assistance to a drowning person	insignificant
110.	Availability of a stand at the rescue post with the rules for operation of stationary attractions and safety measures for operation of stationary attractions	insignificant
111.	Availability of a daily routine at the rescue post	insignificant

112.	Availability of instructions of the duty officer for the post at the rescue post	insignificant
113.	Availability of occupational health and safety instructions at the rescue post	insignificant
114.	Availability of a book of water accident reports at the rescue post	insignificant
115.	Presence of a map (diagram) of the serviced area with water depths at the rescue station	insignificant
116.	The presence at the rescue post of the order of behaviour on the reservoirs of citizens and the inventory of the property of the rescue post	insignificant
117.	Availability of telephone communication and video recording system covering the entire service area	gross
118.	The presence of a stand with plates indicating air temperature, direction of wind force and current speed	insignificant
119.	Availability of a stand with phone numbers and addresses of law enforcement agencies, rescue services and the nearest water rescue station	insignificant
120.	Availability of a stand with a schedule of classes, trainings, competitions with indication of persons responsible for safety on water	insignificant
121.	Availability of the appropriate sign in the place reserved for swimming	gross
122.	The presence of appropriate buoys indicating the boundary of the water area allocated for swimming	gross
123.	Compliance of the location of small boat rental points, small boat parking bases for water walks of the population, towing, water bodies, floating boards under sail not closer than 50 meters from the boundaries of beaches and areas (lanes) of water areas used for scuba diving	gross
124.	Availability of swimming training areas for children of preschool and primary school age with a depth of not more than 0.7 meters, for	gross

	children of senior school age with a depth of not more than 1.2 meters	
125.	The presence on the beach at a distance of 10 meters from the water with an interval of no more than 50 meters of shields with lifebuoys and rescue means "End - Alexandrova"	gross
126.	Presence of appointed officials responsible for the safety of children in water bodies	gross
127.	Availability of instructions for actions in case of accidents and emergencies in water bodies	gross
Footnote. The title of Chapter 3 as excluded by the joint order of acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).		
128.	<i>Excluded by the joint order of acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).</i>	
Footnote. The title of Chapter 4 as excluded by the joint order of acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).		
129.	<i>Excluded by the joint order of acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).</i>	
Footnote. The title of Chapter 5 as excluded by the joint order of acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).		
130.	<i>Excluded by the joint order of acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).</i>	
131.	<i>Excluded by the joint order of acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).</i>	
132.	Availability and compliance of the civil defence readiness plan	gross
133.	Availability of logistical support for civil defence units	gross

134.	Availability of a cadastral passport for the real estate object	gross
135.	Availability of main and auxiliary rooms in shelters and radiation shelters	gross
136.	Availability of natural ventilation with mechanical inducement in anti-radiation shelters	gross
137.	Availability of interior finishing of premises of civil defence protective structures made of non-combustible or hardly combustible materials, painting of walls, ceilings, and partitions mainly in light colours, without plastering	gross

Annex 2
to the Risk assessment criteria,
used for preventive control
by visiting the subject (object) of control
in the field of civil defence

List of subjective criteria for determining the degree of risk by subjective criteria in the field of state control in the field of civil defence in accordance with article 138 of the Entrepreneur Code of the Republic of Kazakhstan in relation to controlled entities in the field of civil defence

Footnote. The criteria as added by Annex 2 in accordance with the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication).

№ r/n	Subjective criterion indicator	Source of information on the subjective criterion indicator	Specific gravity by significance, point (in total should not exceed 100 points), w_i	Conditions/values, xi	
				Condition 1/value	Condition 2/value
1	2	3	4	5	
For preventive control with visit					
Organizations classified as civil defence with the highest working shift, organizations classified as civil defence, organizations on the basis of which civil protection services are created, local executive bodies					
	Results of monitoring of reports and information				Condition 2 - within the established period, but with the presence of information in the

1	submitted by the control entity (report on the implementation of civil defence measures)	Results of monitoring of reporting and information submitted by the control entity	71	Condition 1 - failure to provide	report on non-compliance with the requirements leading to a decrease in the country's defence capability
				100%	100%

Annex 3 to the joint order
of the Minister of the Republic of
Kazakhstan
dated October 30, 2018 № 758
and of the Minister of National Economy
of the
Republic of Kazakhstan
dated October 30, 2018 № 31

**Check list in the field of state control and supervision in the field of fire safety
with respect to objects regardless of category, purpose and type of activity**

Footnote. Annex 3 - in the wording of the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall enter into force from 01.01.2023); as amended by the joint order of the acting Minister of Emergency Situations of the Republic of Kazakhstan dated 03.04.2023 № 170 and acting Minister of National Economy of the Republic of Kazakhstan dated 03.04.2023 № 45 (shall enter into force upon expiry of ten calendar days after the day of its first official publication); Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication).

The state body that appointed the inspection/preventive control
with a visit to the subject (object) of control and supervision

Act on appointment of inspection/preventive control with subject visit
(object) of control and supervision

(№, date)

Name of the subject (object) of control and supervision

(Individual identification number), Business Identification Number
subject (object) of control and supervision

Address of the location of the

№ r/n	data requirements list	conforms to requirements	Does not meet the requirements
1.	Availability of persons responsible for ensuring fire safety in certain areas of work		
2.	Availability and compliance with the instruction establishing the fire safety regime for the facility corresponding to its fire hazard		
3.	Availability of a non-state fire service and its compliance with the number of fire trucks, regular employees, fire-fighting equipment and equipment, special uniforms and fire-fighting equipment		
4.	Admission to work of employees after passing fire briefing, fire safety training		
5.	Availability of an official responsible for operation of fire protection systems, purchase, repair, safety and readiness for operation of primary fire extinguishing equipment, timely and high-quality maintenance (reloading of manual fire extinguishers) and scheduled preventive repair		
	<p>Location of the personnel on duty in the premises in which the telephone shall be available and a log of the people remaining in the building at night is kept in any form.</p> <p>Availability of plates indicating the telephone numbers of the fire service "101" and the unified duty-dispatch service "112" in the premises of the duty</p>		

6.	<p>personnel of organizations near the places of placement of telephones, evacuation plans, instructions on fire safety measures. The duty personnel have a set of keys from all locks of the building door, according to the functions assigned to it. Storage of the spare set of keys (provided with a tag with an inscription about its belonging to the lock) in the premises of the duty personnel (security) on the ground floor of the building</p>		
7.	<p>Availability of a special logbook or automated system for accounting of maintenance and scheduled preventive repair of technical means of fire protection systems, checks of availability and condition of primary fire extinguishing means</p>		
8.	<p>Availability and compliance of plans for evacuation of people in case of fire</p>		
9.	<p>Provision of fire safety signs in premises, buildings, structures, equipment with increased fire hazard, as well as indicators of locations of fire water supply sources (fire hydrants, fire water bodies, fire cranes) in accordance with the requirements of standardization documents, documents in the field of architecture, urban planning and construction</p>		
10.	<p>Maintenance or duty personnel have buildings for people living, facilities with a mass presence of electric lights in case of power outage</p>		

11.	Implementation by the heads of organizations of facilities with mass presence of people at least once per six months of practical training with an indication in the training log, compiled in any form		
12.	The presence in rural settlements, horticultural associations, summer cottages (partnerships, consumer cooperatives, non-commercial partnerships), on the territory of which there shall be no fire service units, fire motor pumps with a set of fire hoses and trunks, primary fire extinguishing equipment, non-mechanized tools and fire equipment that are used in extinguishing fires		
13.	Availability of sound alarm devices on the territory of rural settlements, horticultural associations, summer cottages, block-container buildings for warning people about fire, storage of water supply for fire extinguishing purposes		
14.	Maintenance of roads, driveways and entrances to buildings, structures, process units, open warehouses, external fire stairs and fire water supply sources in good condition and accessible for passage of fire equipment		
15.	The presence of a stationary post with round-the-clock personnel duty, and a barrier provided with a device for their manual opening, in case of installation at the entrance to the territory of groups of residential buildings united by a		

	common space (yard) of the barrier		
16.	Prevention of placement (storage) of any objects, structures, structures within fire-fighting distances between buildings and structures, as well as their use for parking of transport and construction (installation) of buildings and structures		
17.	Availability of fire-fighting distances		
18.	Preventing the storage of coarse fodder on the manor plots of residential buildings at a distance of less than 15 meters to buildings and outbuildings (if it is impossible to store coarse fodder at a specified distance, provided that the storage place is provided with an additional capacity with water of at least 500 litres, the distances are reduced to 5 meters)		
19.	Prevention of stacks, piles, coarse feed, combustible substances and materials storage on the roofs of sheds and utility buildings, under power lines, at a distance of less than 3 meters from the external fence of the site. Storage of coarse foddors with a height of not more than 4 meters from ground level		
20.	Prevention of fire breeding, incineration of waste and containers at a distance of less than 50 meters from buildings and structures		
	Prevention of the installation of special devices for the location of burning coal (barbecue, barbecue, grill) in places with dry vegetation, under the canopy of trees, under		

21.	canopies made of combustible materials, in the premises of a residential building, as well as on balconies and loggias, in outbuildings, garages, attics, on flat roofs. Preventing burning coal from being left unattended		
22.	Avoidance of the use of open fire and smoking in fire-hazardous and explosion-hazardous areas, under foundations, gas-hazardous places, near containers for storing fuels and lubricants, petroleum products, flammable substances and reagents		
23.	Cleaning of the territory from combustible waste, garbage, containers, fallen leaves, combustible garbage and combustible materials		
24.	The presence of outdoor lighting on the territory of the organization in the dark for the quick location of fire hydrants, external fire ladders and places where fire equipment is located, as well as entrances to the piers of fire water bodies		
25.	During the operation of block containers, prevention of changes in design parameters provided by the manufacturer		
26.	Arrangement of separate block containers and domestic trailers in groups of not more than 10 in a group, with the distance between groups of these buildings and from them to nearby buildings and structures of not less than 18 meters		
	Provision of protective fire protection strips with a width of at least 4 meters,		

27.	planting of deciduous plantations, removal of dry vegetation in the summer period		
28.	Placement on the doors of evacuation exits from premises, buildings (structures) for industrial and warehouse purposes, on outdoor process units of information on their category of explosion and fire hazard, as well as on the classes of explosion hazardous or fire hazardous areas located in them		
29.	Ensuring by the head of the organization of the availability, compliance with design documentation and constant condition in good working order of fire extinguishing and fire alarm systems, warning and evacuation control systems for people in case of fire, smoke protection and fire water supply, fire-fighting equipment and fire-fighting equipment, fire doors, valves and hatches, fillings of openings in fire barriers, premises of buildings and structures, means of protection and rescue of people, as well as lightning protection devices for buildings, structures and external technological installations		
30.	Avoidance of work on equipment with faults that could lead to a fire		
31.	Availability of serviceable lightning protection devices in buildings, structures and outdoor process units provided for by the design		
	Inspection of lightning protection devices at least once a year. Availability of		

32.	a lightning protection device operation log with a mark of inspection of lightning protection devices at least once a year in the pre-lightning season		
33.	Inspection of lightning protection devices		
34.	Presence of highly flammable, or combustible liquids, as well as combustible gases, protective grounding, as well as external process units and racks in all metal structures of process vessels, tanks, gas pipelines, pipelines, oil pipelines, devices, equipment located inside buildings, structures and in open space, in which highly flammable, or combustible liquids are handled or processed.		
35.	Prevention of use of the process pipeline of buildings and structures as earthing (earthing) conductors		
36.	Availability and upkeep of devices for self-closing of doors in buildings and structures. Prevention of installation of devices preventing the free closing of fire doors, smoke control devices (curtains, screens, curtains)		
37.	Prevention of installation on staircases, platforms and corridors of storerooms (utility rooms), as well as storage under staircases and on staircases of things, furniture, combustible materials		
	Availability of fire-retardant treatment and coatings of building structures, combustible finishing heat-insulating		

38.	materials, wooden structures, air ducts, metal supports and racks and verification of the state of fire-retardant treatment (impregnation) with confirmation of fire-retardant effectiveness (for metal structures in accordance with the national technical regulations)		
39.	Ensuring that the doors of attic rooms, as well as technical floors and basements are locked, in which, according to the conditions of the technology, people are not required to stay permanently. Availability on the doors of the specified premises of information on the place of storage of keys, to which round-the-clock access shall be provided		
40.	Avoidance of use and application of basements, ground floors, attics, technical floors and rooms, ventilation chambers not for their intended purpose, except in cases provided for by design documentation		
41.	Cleaning of debris and pit objects near the window openings of the basement and basement floors of buildings, structures and structures, opening of constipation on windows from the inside without a key		
	Prevention of the installation of grilles on the windows of all floors of the building, and pits near the windows of basements (with the exception of the premises of the penitentiary system		

42.	facilities and special institutions that provide temporary isolation from society, warehouses, cash desks, arms rooms, secret parts of institutions, storage and circulation of precursors)		
43.	Prevention of operation of elevator halls not for their intended purpose		
44.	Prevention of glazing of balconies, loggias and galleries leading to smoke-free stairwells		
45.	Prevention of amendments in space-planning solutions , as a result of which the conditions of safe evacuation of people deteriorate, access to fire extinguishers, fire taps, fire safety equipment is limited or the area of operation of automatic fire protection systems (automatic fire alarm, stationary automatic fire extinguishing plant, smoke removal systems, warning and evacuation control systems)		
46.	Prevention of storage and storage in basement and basement floors, attics, technical floors and rooms, ventilation chambers of flammable and combustible liquids, explosives, pyrotechnic products, cylinders with combustible gases, aerosol-packaged goods, celluloid and explosive and fire-hazardous, combustible substances and materials		
47.	Prevention of removal of evacuation exit doors provided for by the design from floor corridors, halls, foyers, tubbers and staircases, as well as doors that prevent the spread of		

	fire hazards on escape routes		
48.	Prevention of obstructing and closing of passages to fire safety and fire extinguishing equipment, as well as to places where rescue devices are attached		
49.	Prevention of installation in production and storage premises of buildings (except for buildings of fire resistance degree V) of built-in premises not provided for by design documentation		
50.	Prevention of simultaneous stay of 50 people or more in premises with one evacuation exit		
51.	Availability of the required number of serviceable and maintained primary fire extinguishing equipment. Operation and maintenance of fire extinguishers in accordance with the requirements of standardization documents		
52.	Compaction with mortar or other non-combustible materials providing the required fire resistance rating and smoke and gas tightness, formed holes and gaps, at the intersection of fire walls, floors and enclosing structures with various engineering and technological communications		
53.	Modification of functional purpose, major repairs, technical re-equipment, reconstruction and redevelopment of buildings , structures and structures according to the design documentation		
	Availability, maintenance in good condition of external fire ladders and		

54.	fences on the roofs of buildings, structures and structures		
55.	During operation of domestic gas appliances, prevention of furniture and combustible materials at a distance of less than 0.2 meters horizontally to the nearest vertical surface and less than 0.7 meters vertically to the nearest horizontal surface of these products overhanging above it		
56.	Availability of certificates (declarations) at the facility to confirm compliance of fire safety and firefighting equipment		
57.	Prevention in buildings with stained glass windows with a height of more than 1 floor of violations of the structures of smoke-proof non-combustible diaphragms installed in stained glass windows at the level of each floor		
58.	Automatic lowering to the main landing floor, and in underground structures - lifting up to the floor of the main evacuation exits from the structure and de-energizing of elevators and lifts (except for fire elevators), as well as automatic disconnection of escalator drives (travelators) in case of fire		
59.	Ensuring compliance with design decisions during the operation of evacuation routes and exits (including lighting, quantity, size and space-planning solutions for evacuation routes and exits, as well as the availability of fire safety signs on evacuation routes)		

60.	Arrangement of doors on escape routes opening freely and in the direction of exit from the building (except for rooms of classes F1.3 and F1.4, rooms with simultaneous stay of no more than 15 people, except for rooms of category "A" and "B" for explosion and fire hazard, storerooms with an area of no more than 200 square meters, sanitary units, exits to platforms of stairs of type 3)		
61.	Providing locks on emergency exit doors with the ability to open them freely from the inside without a key		
62.	Content in good condition and light indication of volumetric fire safety light signs "Exit," "Emergency (emergency) exit," " Evacuation exit door" used on escape routes		
63.	Provision of automatic actuation of evacuation lighting in case of power outage of working lighting		
64.	Prevention of obstacles narrowing the design dimensions of evacuation routes and exits (including passages, corridors, tubbers , galleries, elevator halls, staircases, doors , evacuation hatches), as well as clogging (welding) of evacuation exit doors		
65.	Prevention of the device on the evacuation routes of thresholds (with the exception of thresholds in doorways), sliding and lifting doors and gates, rotating doors and turnstiles, as well as devices that prevent the free evacuation of people, in the absence of other (

	duplicate) escape routes or in the absence of technical solutions that allow you to manually open and lock these devices in open state		
66.	Prevention of the use of combustible materials that do not meet the fire hazard class for finishing, lining and painting of floors, walls, ceilings, stairs and staircases on escape routes, with the exception of buildings of fire resistance degree V		
67.	Prevention of locking of self-closing doors of staircases, corridors, halls and tambours in open position, as well as their removal		
68.	Prevention of glazing or closing of air zones in smoke-free staircases		
69.	Prevention of replacement of reinforced glass with conventional ones in glazing of doors and transoms		
70.	The presence of garbage chute valves in buildings and structures provided for by the design, which are in a closed position, are kept serviceable and provided with a seal in the surface		
71.	Availability of evacuation passages to staircases and escape routes during arrangement of equipment in the room		
72.	Fastening to the floor of carpets, carpets, flooring in rooms with mass presence of people		
73.	Prevention of laying and operation of overhead power transmission lines over combustible roofs, sheds, as well as open warehouses (stacks, hay stacks) of combustible		

	substances, materials and products, external process units for explosion and fire hazard of categories A, B, B1-B4		
74.	Prevention of the use of electrical networks and electric energy receivers in violation of safety requirements set forth in the manufacturer's instructions, electrical receivers with malfunctions that can lead to fire (spark, short circuit, ultra-permissible heating of cable and wire insulation, failure of automatic control systems, emergency and fire protection), as well as operation of electrical wires and cables with damaged or lost protective properties insulation		
75.	Prevention of the use of electric energy receivers with violation of the design and protection systems provided by the manufacturer, including damaged and loose electrical installation products, as well as prevention of the operation of the temporary power network		
76.	Prevention of the use of electric heating devices in the absence or malfunction of temperature regulators provided for by the design		
77.	Prevention of the use of electric irons, electric stoves, electric kettles and electric heating devices without special supports (power plinths, heating disks) that exclude the risk of fire, if their presence is provided for by the manufacturer's instructions		
	Prevention of the use of non-standard (homemade)		

78.	electric heating devices, the use of uncalibrated fuses, homemade overload and short circuit protection devices		
79.	Prevention during operation of electrical installations of placement (warehousing) of fire hazardous and (or) explosion and fire hazardous substances and materials near electrical boards, electric motors and start-up equipment, as well as in rooms and corridors of closed switchgears of storage premises, including electrical equipment, spare parts, tanks with combustible liquids and gas cylinders		
80.	Prevention of the use of electrical equipment in explosive and fire hazardous areas that shall not have a designation of the level and type of protection against explosion and/or fire of the manufacturer		
81.	Checking the condition of stationary equipment and wiring of the power and lighting network, testing and measuring the insulation resistance of wires, cables and earthing devices during commissioning, and in the future according to the schedule, but at least once every three years		
82.	Mounting of all current-carrying parts, distribution devices, apparatus and measuring instruments, as well as break-type safety devices, switches, starting devices and electrical installation devices only on non-combustible bases		

83.	Connection, termination and branch of wire and cable cores to avoid fire-hazardous transient resistances by means of pressure testing, welding, soldering or special clamps		
84.	Carrying out the connection and branching of wires and cables, except for wires laid on insulating supports, in junction and branch boxes, insulating housings of junction and branch boxes clamps, special niches of building structures, inside the housings of electrical installation products, devices and machines		
85.	Removal of combustion products from heat generating devices outside buildings and structures through smoke channels specially designed for this purpose. Prevention of use of ventilation system air ducts as smoke ducts		
86.	Presence of process holes in the smoke duct structure for periodic soot removal		
87.	The presence on the floor of combustible materials under the combustion door of heat-generating devices operating on solid fuel of a pre-combustion metal sheet with a size of at least 0.5 x 0.7 meters without holes located in front of the combustion hole along the furnace		
88.	Installation of a liquid fuel device in a metal tray that can hold the entire volume of fuel in the fuel tank in the event of an emergency spill. Filling the tray with sand or another non-flammable adsorbent		

89.	Availability of serviceable doors on heat-generating devices operating on liquid, solid and gaseous fuel and fire-fighting cuts (indents) from combustible structures established by the standards. The presence of at least two valves on the fuel pipeline near each nozzle of heating boilers and heat generating plants: one at the furnace, the other at the tank with fuel		
90.	Heating of furnaces by specially designated persons instructed on fire safety measures during operation of heating devices		
91.	Prevention of operation of faulty furnaces and heating devices		
92.	Avoidance of the following during operation of heat-generating equipment: 1) work on the device with a broken fuel line seal and a faulty shut-off valve on it , loose connections of the nozzle body with the heat-generating device, faulty chimneys, electric motors and protection devices, as well as in the absence of thermal protection of the electric motor and malfunctions; 2) work on the device with open fuel tanks; 3) installation of fencing made of materials of flammability groups G3-G4 around the apparatus and supply tanks; 4) heating fuel lines with an open flame; 5) ignition of the working mixture through the inspection window; 6) regulation of the gaps between the spark plug electrodes when the		

	<p>heat-generating device is operating;</p> <p>7) leaving operating heat-generating equipment unattended or entrusting supervision of them to children.</p>		
<p>93.</p>	<p>Prevention at operation of the central boiler houses intended for heating of the organizations and houses in settlements:</p> <p>1) storages of liquid fuel in the rooms which aren't intended for these purposes ;</p> <p>2) applications as fuel of the combustible substances (firm, liquid, gaseous) which aren't provided by maintenance instructions of the equipment;</p> <p>3) operation of the heat generating installations at dribble of liquid fuel or leak of gas from the systems of fuel feeding;</p> <p>4) drying of combustible materials on coppers and steam lines</p>		
	<p>Prevention during operation of furnace heating:</p> <p>1) leaving burning stoves unattended, as well as instructing children to supervise them;</p> <p>2) placement of fuel prepared for combustion, as well as combustible substances and materials on the pre-furnace sheet;</p> <p>3) use of flammable and combustible liquids for ignition of solid fuel furnaces;</p> <p>4) furnaces with other types of fuel, the use of which shall not be provided for a specific type of furnace;</p>		

94.	<p>5) furnaces in premises during meetings and mass events in them;</p> <p>6) furnace overhanging;</p> <p>7) drying combustible substances and materials at a distance of less than 0.5 m from the surface of the furnace and chimneys;</p> <p>8) use of a gate valve (damper) without holes specified in the design standards;</p> <p>9) use of ventilation and gas channels as chimneys, laying transit chimneys through living quarters.</p> <p>Maintenance of heating devices and systems before the start of the heating season. Cleaning of chimneys, chimneys and elements of heating furnaces and systems from soot immediately before the start, as well as during the heating season.</p>		
95.	Storage of fuel (coal) in specially adapted premises or at specially designated sites located no closer than 8 meters from combustible buildings		
96.	Availability of specially designated places, which exclude the possibility of fire, for ash and slag placement and their spillage with water		
97.	Prevention of placement of combustible substances, materials, products and equipment at a distance of less than 1.25 meters to furnace openings and less than 0.7 meters to other heated parts of furnaces		
98.	The presence of whitewashing in the attics of chimneys and walls, in which smoke channels pass		

99.	Presence of spark arresters on flue pipes of boiler plants		
100.	Compliance with the instructions of manufacturers, as well as the requirements of state standards in the field of architecture, town planning and construction, imposed on heating systems, when installing factory-made furnaces in dormitories, administrative, public and administrative and household buildings of industrial enterprises, in residential buildings		
101.	Compliance with fire safety requirements when installing temporary metal furnaces: 1) metal furnaces shall be provided with legs at least 0.2 meters high; 2) metal furnaces shall be installed at a distance of at least: 1 meter - from wooden structures, furniture, goods, racks, display cases, counters and other equipment; 0.7 meters - from structures protected from fire; 1.25 meters - from furnace holes to wooden structures and other equipment		
102.	Compliance with the requirements when removing heat-generating apparatus metal pipes into the window: 1) when the metal chimney is removed through the window, a replacement sheet of roofing iron with a size of at least three diameters of the chimney is inserted into it; 2) the pipe is brought out beyond the building wall at a distance of at least 0.7 meters and is directed		

	<p>upwards to a height of at least 0.5 meters;</p> <p>3) the branch pipe removed from the window of the upper floor protrudes above the cornice by at least 1 meter. Cap shall be installed on a branch pipe.</p>		
103.	<p>Application of electro heaters with the serviceable alarm system and blocking excluding supply of electricity on heating elements at the idle fan and automatic equipment of control of temperature of the coming-out air and her regulation provided by electric and thermal protection</p>		
104.	<p>Operation of air ducts and ducts of supply and exhaust smoke ventilation systems and transit ducts (including air ducts, headers, shafts) of ventilation systems in accordance with the design documentation</p>		
105.	<p>Prevention of storage of any equipment and materials in ventilation chambers and keeping them closed. Permanent closing of ventilation chambers with lock</p>		
106.	<p>Inspection within the terms established by the technical documentation and maintenance of fire-retardant devices (dampers, valves) in air ducts, devices for blocking ventilation systems with automatic fire alarm or fire extinguishing installations, automatic devices for disconnecting ventilation in case of fire. Cleaning of sensitive elements of the gate valve drive from contamination with combustible dust (low-melting locks, easily</p>		

	combustible inserts, heat-sensitive elements). Cleaning of ventilation chambers, cyclones, filters, air ducts from combustible dust, industrial waste and fat deposits		
107.	Prevention during operation of ventilation and air conditioning systems: 1) leaving the doors of the ventilation chambers open; 2) closing exhaust channels, holes and grids; 3) connection to air ducts of gas heating devices; 4) burning of fat deposits, dust and combustible substances accumulated in the air ducts		
108.	Availability, compliance with design documentation and maintenance in good condition of natural and artificial sources of fire-fighting water supply (including fire-fighting water supply, fire water bodies, water storage tanks for fire-fighting purposes), as well as entrances with platforms (piers) with hard coating with dimensions of at least 12x12 meters for installation of fire-fighting vehicles and water intake at any time of the year		
109.	Availability of certificate and protocol of tests of results of technical inspection and check for water loss and operability of internal fire-fighting water supply systems by starting water of fire-fighting water supply systems equipment (fire hydrants, fire cranes, dry tube systems of water and foam fire-fighting, as well as water sprinkling)		

110.	Winterization and cleaning of fire hydrants in winter from snow and ice		
111.	Sealing of manual start-up devices of fire extinguishing units, fire extinguisher lock-and-release device and doors of fire cabinets		
112.	Provision of fire-fighting valves of the internal fire-fighting water supply system at the height of 1,35 ±0,15 m above the floor of the room, complete with hoses, trunks, and enclosed in fire cabinets. Indication on the cabinet door of the alphabetic index "IIK" and serial number. Keeping fire hoses dry, well rolled or folded in accordion and connected to cranes and trunks		
113.	The presence of fire cabinets in any of the three options (mounted, attached and built-in), with the possibility of placing a set of fire crane equipment and at least two manual fire extinguishers in them, with a mass of fire extinguishing agent charge of at least 5 kilograms, as well as personal protective equipment and rescue of people		
114.	Availability of a general fire water supply diagram and pump piping diagram in the pump station rooms. Indication on each gate valve and fire pump of their purpose		
115.	Provision of uninterruptible power supply to fire pump motors		
	Availability of electrically driven gate valves on bypass lines of water metering devices of		

116.	external and internal fire-fighting water lines. Opening of gate valves from buttons installed in fire cabinets and interlocked with starting of fire water line booster pumps, if any. Performance of functional check of motor-operated gate valves installed on bypass lines of water metering devices - at least twice a year, and fire pumps - monthly		
117.	Provision of pump units for fire protection purposes by manual and remote control, and for buildings with a height of more than 50 meters, cultural and entertainment institutions, conference rooms, assembly rooms and for buildings equipped with sprinkler and drainage black installations - with manual, automatic and remote control		
118.	Providing a signal for opening the electrified gate valve on the bypass line of the water meter at the water supply inlet, simultaneously with the signal of automatic or remote start of pumps for fire protection purposes, opening the fire valve, opening the sprinkler or turning on (manual or automatic) the deluge system		
119.	Adaptability of water towers for water intake by firefighting equipment at any time of the year. Preventing the use of water for fire extinguishing purposes for household and production needs		
	Maintenance of fire automation systems and installations in operable		

120.	condition by timely maintenance, examination and scheduled preventive repair by qualified specialists of the facility or organizations in the field of working with low-current equipment with paperwork		
121.	Availability of technical documentation at the facility equipped with fire-fighting automation systems and installations		
122.	Knowledge of the devices and principles of operation of firefighting systems and installations installed at the facility by the facility maintenance personnel or a qualified specialist of the organization in the field of working with low-current equipment		
123.	Technical examination of systems and installations of fire automatics after the expiration of the service life specified in the documentation for the technical means, as well as in cases of failure of these systems and installations		
124.	Availability of an independent electric network according to the first category of reliability, starting from the input-distribution device to the power consumer, for power supply of fire protection systems, emergency lighting		

Officials _____
position signature

surname, first name, patronymic (if any)
Head of the subject of control and supervision _____
position signature

surname, first name, patronymic (if any)

Annex 4 to the joint order
of the Minister of the Republic of
Kazakhstan
dated October 30, 2018 № 758
and of the Minister of National Economy
of the
Republic of Kazakhstan
dated October 30, 2018 № 31

Check list in the field of state control and supervision in the field of fire safety in relation to industrial enterprises

Footnote. Annex 4 - as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall enter into force dated 01.01.2023).

The state body that appointed the inspection/preventive control with a visit to the subject (object) of control and supervision

Act on appointment of inspection/preventive control with subject visit (object) of control and supervision

(№, date)

Name of the subject (object) of control and supervision

(Individual Identification Number), Business Identification Number subject (object) of control and supervision

Address of the location

№ r/n	The list of requirements	conforms to requirements	Does not meet the requirements
1	Availability at each enterprise of information on fire hazard indicators of substances and materials used in technological processes, and for buildings and premises of explosion and fire hazard category		
	Prevention of joint use, storage and transportation of substances and materials that, when interacting with		

2	each other, cause ignition, explosion or form combustible and toxic gases (mixtures)		
3	Cleaning of the structure of exhaust devices (cabinets, painting, drying chambers), apparatuses and pipelines by fire-safe methods according to the schedule approved by the head of the enterprise		
4	In-service content of spark arresters, spark arresters, fire retardants, dust and metal detectors and explosion-proof devices of the static electricity protection system installed on process equipment, pipelines		
5	Taking samples of flammable and combustible liquids from tanks (tanks) and measuring the level during daylight hours with devices that prevent sparking in case of impacts . Prevention of these sampling operations during thunderstorms, product injection or pumping. Preventing the supply of highly flammable and combustible liquids to tanks (tanks) by a "falling jet," as well as exceeding the speed of filling and emptying the tank with the total throughput of breathing valves (ventilation nozzles) installed on tanks		
6	Keeping doors and hatches of dust collection chambers and cyclones closed during their operation, timely removal of combustible waste collected in chambers and cyclones		
	Prevention of the use of production buildings, warehouses in the		

7	territories of enterprises for living, as well as placement in warehouses of production workshops		
8	Prevention of storage in pedestrian tunnels and transitions of storerooms, the equipment, combustible materials, posting of stands and posters from combustible materials and also laying of power cables , the pipelines transporting gases, acids, flammable and combustible liquids		
9	Designation of borders of drives and passes in shops marking		
10	Prevention of laying through warehouses and production rooms, transit power supply networks and also pipelines for transportation of combustible gases, flammable and combustible liquids, combustible dust		
11	The maintenance of production rooms in purity and prevention of an overload the equipment, raw materials and the finished goods exceeding replaceable requirement – development, and at the round-the-clock process of production – daily. Standard establishment for shop storerooms of the number of single storages of flammable and combustible liquids, admissible within standard daily (replaceable) rate, chemicals. Storage of the combustible and flammable liquids applied in production in the sealed closed metal container and in number of not exceeding standard daily (replaceable) rate		

12	Protection of technological apertures in walls and overlapping by fire blocking devices		
13	Contents in constant working order of protective membranes of explosive safety valves on lines and adsorbers		
14	Existence in hydraulic systems with use of combustible liquid of control of oil level in a tank and prevention of excess of pressure of oil in a system is higher provided in the passport		
15	The equipment of bunkers of the crushed wood particles and the system of the aspiration supporting the discharge, and supply with the sensors signalling about their filling in capacity forming cars		
16	Equipment of the drum dryer and bunkers of dry shaving and dust installations of automatic fire fighting and ant explosive devices		
17	Equipment of a system of transportation of the blocking and dust materials devices preventing spread of fire and hatches for elimination of fire		
18	The capacity equipment for collecting wood and explosive dust from the aspiration and pneumonia transport systems the ant explosive devices which are in working order		
	At least once a day, cleaning of residues of volatile resin emissions and pyrolysis products of wood , dust and waste from heat treatment chambers of slabs. Availability of automatic device for		

19	exhaust pipe gate opening for removal of explosive gases from heat treatment chambers of particle boards for 2-3 minutes every 15 minutes. Prevention of heat treatment of under pressed plates with loose edges		
20	Automatic temperature control in treatment chambers and in oil baths		
21	Equipment of drying drums using flue gases with sparklers		
22	Equipment of impregnating , quenching and other baths with combustible liquid with emergency drain devices to underground tanks located outside the building. Equipment of each bath with local suction of combustible vapours		
23	Equipment of supply and exhaust ducts of steam-air and gas chambers with special dampers (gate valves) closing in case of fire		
24	Equipment of gas drying chambers with serviceable devices, which automatically stop the flow of flue gases in case of ventilation shutdown		
25	Installation of sparklers in front of the gas drying chambers to prevent sparks from entering the drying chambers		
26	Prevention of operation of dryers with cracks on the surface of hogs and with non-operating sparklers		
27	Equipment of furnace-drying compartments with serviceable devices for temperature control of drying agent		

28	Equipment of drying chambers with devices disconnecting fans of heaters in case of fire in the chamber and including stationary fire extinguishing equipment		
29	Equipment of drying chambers (rooms, cabinets) for raw materials, semi-finished products and painted finished products by automatic shutdown of heating when the temperature exceeds the permissible temperature		
30	Storage of quicklime in special rooms not lower than fire resistance grade II , the floor of which provides for a distance above the ground surface of not less than 0.5 meters		
31	Serviceability of lining of blast furnace, steel-smelting furnaces, converters, mixers, ladles and other vessels for molten metal		
32	Protection of entrances to cable tunnels, oil shafts located in the immediate vicinity of spill sites, as well as at molten metal transportation sites, from ingress of molten metal with fire-resistant thresholds at least 300 millimetres high		
33	Protection of cables of electrical mechanisms, electrical equipment and hydraulic drive devices at metal, slag spill sites and in areas of elevated temperatures from mechanical damage, exposure to radiant heat, as well as from ingress of splashes of molten metal and slag on them		

34	Provision of a spikelet area and sites for research work with two exits		
35	Equipment of blast furnaces with enclosure temperature control devices throughout the height and area of the furnace		
36	Prevention of storage of materials and production waste at blast furnace foundations		
37	Equipment for monitoring the burn-out of air tuyeres by signalling devices. Prevention of operation on burnt tuyere devices		
38	Prevention of equipment storage and storage of materials (including combustible materials) in places of possible ingress of molten metal and slag		
39	Prevention of placement of fuel oil service tanks under furnaces, placement of tanks at a distance of at least 5 meters from furnaces and reliable protection with special heat shields		
40	Connection of service tanks with closed drain and overflow pipelines to emergency tanks for fuel oil release in case of fire		
41	Prevention of the converter operation in the presence of a leak of converter gases in the cooler and cooling of hot places with water on the casing of the converter with molten metal		
42	Prevention of the use of flammable liquids for ignition of gas when setting steelmaking furnaces, converters, mixers for drying		
	Prevention of the use of open fire in places of		

43	storage, preparation and preparation of fire and explosion hazardous materials and mixtures based on them		
44	Prevention of joint transportation and storage of aluminium-magnesium, aluminium-barium and aluminium powders with saltpetre, acids, alkalis and oxidizers, as well as combustible materials		
45	Preventing the placement of a bunker with highly flammable charge materials under the trolleys of charge cranes		
46	Provision of furnace transformers with fire extinguishing equipment and emergency oil receivers designed for the full volume of oil in the transformer		
47	Equipment of vacuum chambers of inductive and vacuum-arc furnaces, as well as melting chambers of electron-beam furnaces with explosion safety valves		
48	Prevention of operation of systems for removal of dust and gas emissions from electric smelting and ore recovery furnaces, which are not equipped with devices preventing ignition , explosions of gases and dust		
49	Equipment of silos, liquid aluminium spray chambers with gates preventing hot powder from entering the conveyor belt during spraying		
50	Prevention in order to avoid oxidation, spontaneous combustion and explosion of aluminium powder, the		

	presence of moisture and dampness in the places of its production and storage		
51	In the premises for the production of powders and powders from aluminium, magnesium and alloys based on them, the construction of basements, underground channels and pits shall not be allowed		
52	Prevention of joint storage and transportation of aluminium-barium and aluminium powders with saltpetre, acids, alkalis, oxidizing agents and combustible substances		
53	Storage of highly flammable materials or materials that contribute to rapid ignition (magnesium and magnesium alloy chips , saltpetre, Bertolt salt, thermite mixture) in specially designated areas of the melting casing of metal thermal shops in closed metal containers (cans, barrels) in an amount not exceeding two-day demand		
54	Equipment of silos for storing self-combustible materials with devices for monitoring the temperature of these materials, the operation of which shall be interlocked with the launch of fire extinguishing equipment		
55	Equipment of hydraulic drive systems with a device for automatic shut-off of pressure gate valves in case of oil pipeline break		
56	Prevention of the use of an open fire source, sparking in oil basins and near oil-filled equipment during operation of the oil facility		

57	Maintenance of closed oil shafts and cable tunnels to prevent scale, sparks and ignition sources from entering them from work sites		
58	Provision, in case of fire, of automatic disconnection of ventilation devices of tunnels and oil shafts		
59	Provision in case of fire of tanks for preservation of bearing assemblies, as well as fuel oil supply tanks with emergency tanks for discharge of combustible liquids, which are located outside the shop building		
60	In-service content of process automatics preventing the creation of explosive concentrations in areas using protective explosive gases		
61	Prevention of use of molten sodium bath without protective gas during metal heat treatment (continuous annealing of tape). Prevent water or wet materials from entering the sodium bath		
62	Prevention of storage of sawdust, chips and wastes of titanium and its alloys at workplaces. Storage of containers with the inscription "Titanium waste" in a specially designated dry room with permanent ventilation		
63	Prevention of use for heating the mixture and dissolution of paraffin, stearin in open fire kerosene, open electric spirals or surfaces with a temperature above 100 ° C		
64	Prevention of works in the areas of kerosene-stearin mixture preparation and use without fire extinguishers		

65	Prevention of kerosene-stearic mixture spill and collection of kerosene-stearic mixture wastes at workplaces during additional pressing of products		
66	Prevention of the use of combustible (explosive) gases as fuel and reducing medium		
67	Provision of paint sections of painting shops (areas) with independent outward access		
68	Floors shall be made of non-combustible materials, which shall not form sparks during impact, in rooms where lacquer-and-paint preparation, painting and gasoline washing shall be performed		
69	Cladding of internal surfaces of walls of premises at the height of at least 2 meters is non-combustible, easily cleaned from contamination with material		
70	Opening all doors of the shop, site, installations opening to the outside or towards the nearest exits from the building		
71	Performance of painting works, parts flushing only with the current supply and exhaust ventilation with local suction from paint cabinets, baths, chambers and cabins. Blocking the operation of plants, as well as systems for supplying painting, washing, varnishing, washing and degreasing to the operation with the use of coatings on nitro base, gasoline and flammable liquids with a ventilation system		

72	Prevention of operation of exhaust ventilation of paint cabinets, chambers and cabins without water sprinklers (hydraulic filters) or other effective devices for catching particles of combustible paints and varnishes		
73	Preventing the use of fire to burn out paint deposits in cabins and air ducts		
74	Use of non-combustible compounds, pastes, solvents and fire-safe technical detergents for washing and degreasing of products and parts		
75	Storage of caustic soda, saltpetre, additives in a specially equipped room		
76	Provision of acid storage areas with ready solutions of chalk, lime or soda for immediate neutralization of accidentally spilled acids		
77	Storage of containers from paints and varnishes tightly closed and at special sites located at a distance of at least 20 meters from buildings and structures		
78	Equipment of racks for laying pipes and products after oiling with devices for oil drainage and removal with its subsequent pumping out		
79	Presence of at least two refrigerant vapor gas analysers, which are blocked with supply and exhaust ventilation and compressor shutdown devices in the rooms of machine and equipment rooms of ammonia refrigeration units		
	Provision of storage of cylinders with cold agents (ammonia) in special warehouses. Prevention of		

80	their storage in engine rooms. Prevention of placement of communications with cold agent in evacuation corridors and passages, staircases, elevator shafts, as well as their transit through fire and explosive premises		
81	Placement of ammonia cylinders at a distance of at least 10 meters from open fire sources and not closer than 5 meters from heating devices		
82	Presence of internal fire valves in ammonia refrigeration unit's premises by spray trunks allowing to obtain sprayed water		
83	Prevention of replacement of non-combustible heat insulation of pipelines with cold agents with combustible		
84	Separation of ventilation systems of machine and hardware rooms from ventilation systems of rooms		
85	Technical serviceability of explosion-proof electrical equipment in machine and equipment rooms of ammonia refrigeration units		
86	Prevention of replacement of easily removable elements (panels, windows, doors) during operation of rooms of machine and equipment compartments of ammonia refrigeration units		
87	Prevention of installation in the rooms of compressor compartments of apparatus or equipment, structurally or technologically unrelated to compressors,		

	as well as the arrangement of workplaces, office and storage rooms		
88	Prevention of changes in the current layout of pipelines with cold agent		

Officials (s)

position signature

surname, first name, patronymic (if any)
Head of the subject of control and supervision

position signature

surname, first name, patronymic (if any)

Annex 5 to the joint order
of the Minister of the Republic of
Kazakhstan
dated October 30, 2018 № 758
and of the Minister of National Economy
of the
Republic of Kazakhstan
dated October 30, 2018 № 31

Check list

in the field of state control and supervision in the field of fire safety in relation to automobile enterprises, transport service facilities, parking lots (parking lots)

Footnote. Annex 5 - as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall enter into force dated 01.01.2023).

The state body that appointed the inspection/preventive control with a visit to the subject (object) of control and supervision

Act on appointment of inspection/preventive control with subject visit (object) of control and supervision

(№, date)

Name of the subject (object) of control and supervision

(Individual Identification Number), Business Identification Number
subject (object) of control and supervision

Address of the location

№ r/n	List of requirements	Conforms the requirements	Does not meet the requirements
1	Compliance with the requirements for carrying out minor repairs and routine maintenance of vehicles in the territory of open parking lots on paved areas		
2	Availability of a fire shield with a set of fire equipment at each site for minor repairs and routine maintenance of vehicles		
3	Prevention of cluttering of premises of garages, parking lots and areas of open storage of vehicles with objects and equipment that may prevent their evacuation in case of fire and emergency situations		
4	Prevention of the use of garages, premises in buildings of parking lots, parking lots and open parking lots for other purposes (storage of combustible materials, gas cylinders, installation of repair shops, paint chambers, premises, rooms for accommodation)		
5	Prevention in buildings of closed parking lots (built-in, attached, underground, free-standing) of conversion or use of separate boxes and parking spaces intended for car storage as premises for repair work and storage of substances and materials		
	Availability of water or air heating combined with		

6	plenum ventilation in car storage rooms		
7	Availability of layout diagrams of motor vehicles and signs of the ways of movement of cars to evacuation exits in garages, boxes, parking lots and open storage areas of vehicles (except for individual)		
8	Prevention of parking of vehicles equipped with gas-cylinder equipment, engines of which operate on compressed natural gas and liquefied petroleum gas in parking lots and closed-type premises and parking lots located below ground level in buildings of other purpose and attached to them		
9	Prevention of arrangement and (or) placement of premises of other functional purpose, not provided for by design documentation in parking lots, in closed-type parking lots. Prevention of storage of combustible, explosive substances and materials, flammable and combustible liquids, oils, cylinders with combustible gases, cylinders under pressure in household storerooms and storerooms for customers' luggage		
10	Accommodation of utility storerooms and storerooms for customers' luggage only on the first (landing) floor of the parking lot, for underground parking lots of cars not lower than the first (upper) underground floor of the structure. Prevention of storage of combustible materials		

	outside household storerooms and storerooms for customers' luggage		
11	Preventing the installation of vehicles in an amount exceeding the standard of the layout plan, reducing the distance between cars, buildings (structures)		
12	Prevention of clogging of exit gates and driveways, blacksmithing, thermal, welding, painting and woodworking, as well as flushing of parts using flammable and combustible liquids		
13	Prevention of leaving vehicles with open fuel tank necks in the presence of leaks from fuel tanks, fuel lines and carburetors, as well as with faulty electrical equipment systems		
14	Preventing refuelling of vehicles with fuel and lubricants, as well as draining them to the drainage system or to the adjacent territory. Collection of spent fuel and lubricants, filters, rags is provided in tanks made of non-combustible materials equipped with closing covers		
15	Prevention of recharging of batteries directly on vehicles, as well as in premises unsuitable for this purpose		
16	Prevention of engines heating by open fire (fires, torches, blowtorches, gas burners), use of open fire sources for lighting		
17	Prevention of installation of vehicles for transportation of flammable and combustible liquids, as well as		

	combustible gases at common parking lots		
18	Prevention of storage of tanks made of flammable and combustible liquids		
19	Prevention of painting of vehicles, washing of parts with flammable and combustible liquids		
20	Prevention of liquefied hydrocarbon gas discharge in premises intended for vehicle storage		
21	Serviceability of systems related to pressure control, gas generation, engine heating, switching to different types of fuel and gas supply to the carburettor-mixer. Operation in good condition of safety valves on cylinders with liquefied hydrocarbon gas, as well as solenoid valves that ensure blocking of fuel supply. Inspection of cylinders at least once per 2 years		
22	Prevention of the use and storage of liquefied hydrocarbon gas in parking lots, closed parking garages and heated rooms where the air temperature exceeds 25 ⁰ C		
23	Equipping parking lots, parking areas and open storage areas for vehicles (except for individual ones) with towing cables and rods, at the rate of 1 cable (rod) per 10 pieces of equipment		
24	Prevention of storage of furniture, household items made of combustible materials, as well as a fuel reserve of more than 20 liters and oil of more than 5 liters in individual garages		

25	Prevention of repair of vehicles with tanks filled with fuel (and gas vehicles with gas-filled cylinders) and crankcases filled with oil in rooms for repair of cars and auxiliary rooms		
26	Prevention of smoking, ignition of fire, use of electric heating devices		
27	Prevention of storage of acids, alkalis or electrolyte in an amount more than a single-shift demand		
28	Prevention of leaving special clothes and foreign objects at workplaces		
29	Prevention of location of flushing and painting shops in basement, basement and first floors of multi-storey buildings		
30	Execution of floors of washing and painting shops , as well as paint-harvesting compartments non-combustible, electrically conductive, resistant to solvents, preventing sparking		
31	Presence of lining with non-combustible material to a height of at least 2 meters of internal surfaces of walls of washing and painting shops		
32	Equipment of premises of washing and painting shops , paint laboratories and paint-collecting departments with independent mechanical supply and exhaust ventilation and local exhaust ventilation from painting chambers, dipping baths, pouring units, manual painting stations, drying chambers, washing and degreasing areas of surfaces. Availability of		

	automatic gas analysers in the specified rooms		
33	Preventing the use of ribbed radiators in flushing and painting workshops		
34	Installation of electrical starters, push-button electromagnetic starters outside flushing and painting rooms		
35	Mobile process equipment of washing, painting and paint shops (ladders, ladders, boards, trolleys) shall be equipped with protective devices.		
36	Preventing workers and employees from wearing clothing made of synthetic materials and silk, as well as rings and bracelets		
37	Providing workers with conductive footwear and antistatic bracelets		
38	Execution of racks at railway transport facilities in the storage rooms of hand luggage and luggage compartments only from non-combustible materials. Prevention of mezzanine arrangement		

Official(s)

position signature

surname, first name, patronymic (if any)
Head of the subject of control and supervision

position signature

surname, first name, patronymic (if any)

Annex 6 to the joint order
of the Minister of the Republic of
Kazakhstan
dated October 30, 2018 № 758
and of the Minister of National Economy
of the

Check list

in the field of state control and supervision in the field of fire safety in relation to administrative buildings (multifunctional complexes), apartment (individual) residential buildings and hostels

Footnote. Appendix 6 - as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall enter into force dated 01.01.2023).

The state body appointed the inspection/preventive control with a visit to the subject (object) of control and supervision

Act on appointment of inspection/preventive control with subject visit (object) of control and supervision

(№, date)

Name of the subject (object) of control and supervision

(Individual Identification Number), Business Identification Number subject (object) of control and supervision

Address of the location

№ r/n	List of requirements	Conforms the requirements	Does not meet the requirements
1	Prevention of site cluttering in buildings with a height of more than 28 meters, designed for installation and turning of ladder or crank lift		
2	Prevention of installation in buildings with a height of more than 28 meters of doorways in blind partitions and walls separating smoke-free staircases from rooms, aisles, basements, as well as openings in load-bearing walls		

3	Prevention of painting, whitening, closing, isolation of automatic fire detectors and sprinklers in buildings with a height of more than 28 meters		
4	Prevention of decoration of balcony fences and loggias with combustibile materials in buildings with a height of more than 28 meters		
5	Prevention in apartments of residential buildings and dormitories of various kinds of workshops and warehouses where explosive and fire-hazardous substances and materials are used and stored		
6	Equipment in dormitories (except for residential premises) of places allocated for smoking, inscriptions "Place for smoking," urns or ashtrays made of non-combustible materials		
7	Prevention in buildings with a height of more than 28 meters of de-energization of electrical control panels of the system after acceptance of the smoke protection system		
8	Prevention in buildings with a height of more than 28 meters of operation of the newly built building until the adjustment of fire protection systems		
9	Prevention of storage on balconies and loggias in apartments and residential rooms of flammable, combustibile liquids, explosives, gas cylinders		

Official(s)

position signature

surname, first name, patronymic (if any)
Head of the subject of control and supervision

position signature

surname, first name, patronymic (if any)

Annex 7 to the joint order
of the Minister of the Republic of
Kazakhstan
dated October 30, 2018 № 758
and of the Minister of National Economy
of the
Republic of Kazakhstan
dated October 30, 2018 № 31

Check list

**in the field of state control and supervision in the field of fire safety
in relation to automobile filling stations and gas filling stations
(stationary and mobile)**

Footnote. Annex 7 - as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall enter into force from 01.01.2023).

The state body that appointed the inspection/preventive control
with a visit to the subject (object) of control and supervision

Act on appointment of inspection/preventive control with subject visit
(object) of control and supervision

(№, date)

Name of the subject (object) of control and supervision

(Individual Identification Number), Business Identification Number
subject (object) of control and supervision

Address of the location

№ r/n	List of requirements	Conforms the requirements	Does not meet the requirements

1	<p>Equipment of buildings of filling stations and automobile filling stations with central heating systems.</p> <p>The use of factory-made oil electric heaters that meet fire safety requirements in the premises of gas stations and gas filling stations, with compliance with the required distances to combustible structures and materials.</p> <p>Prevention of the use of heating installations and devices with the use of open fire in the territory and buildings of gas stations and gas stations</p>		
2	<p>The presence of inscriptions on the doors to all premises of the gas station, automobile gas filling station, as well as on outdoor installations indicating:</p> <ol style="list-style-type: none"> 1) explosion and fire hazard categories of premises; 2) class of explosive or fire hazardous areas; 3) the names and initials of the employee responsible for the fire condition; 4) telephone numbers of calling units of the fire service 		
3	<p>Prevention of the use of heating installations and devices with the use of open fire in the territory and buildings of gas stations and gas stations</p>		
4	<p>The presence of inscriptions on the doors to all premises of the gas station, automobile gas filling station, as well as on outdoor installations indicating:</p>		
	<p>Prevention of greening of the territory of the gas</p>		

5	station, automobile gas filling station with shrubs and trees that emit flakes, fibrous substances or pubescent seeds during flowering		
6	Prevention of filling of domestic gas cylinders at automobile gas filling station		
7	Construction of canopies from non-combustible materials over process equipment and filling columns. Prevention of canopies with non-ventilated volumes (sinuses, pockets)		
8	Prevention of process equipment operation; 1) in case of fuel leaks; 2) in the absence, malfunction, disconnection or with expired inspection periods of control and control devices; 3) in the presence of any malfunctions		
9	Prevention of installation of transit engineering networks in the territory of gas stations, automobile gas filling station		
10	Presence of a shroud with a width of at least 4 meters along the boundaries of the filling station, automobile gas filling station, when placed near crops, forest and steppe areas		
11	Sealing of instrumentation and designation with maximum permissible parameters (pressure, temperature, concentration, loading level) ensuring fire-safe operation of process equipment. Provision of automatic supply of warning (light or		

	sound) signals when one of the parameters deviates from the permissible limits		
12	Availability of protection against static electricity of main and auxiliary process equipment		
13	Availability of non-sparking and resistant to oil products and the environment gaskets of covers and branch pipes of flanges, branch pipes, nozzles and devices separating fuel and its vapours from the atmosphere, in places of contact with valves. Design of the specified covers and plugs, which are provided for opening during operation from non-sparking material		
14	Availability of deaeration lines in fuel storage tanks. Equipping the pipelines of the deaeration line with flame arresters or breathing valves with built-in flame arresters that remain functional at any time of the year		
15	Equipment of tanks for underground fuel storage with leak control systems		
16	Equipping pumps for filling tanks with manual power switches located in the control room		
17	Provision of fuel drain from tank trucks according to the closed scheme		
18	Ensure the removal of all vehicles and unauthorized persons from the territory of the gas station when tank trucks with fuel enter it. Prevention of two or more tank trucks at a gas station at the same time		
	Provision for the operation to drain fuel from the tank		

19	<p>trucks to the tanks of the filling station:</p> <ol style="list-style-type: none"> 1) a mobile powder fire extinguisher with a volume of at least 100 liters; 2) emergency tank for removal of fuel spills, atmospheric precipitation contaminated with petroleum products; 3) grounding devices for each tanker truck 		
20	Prevention of connection of grounding conductors to painted and contaminated metal parts of tank trucks		
21	Prevention of refuelling of vehicles with running engines		
22	Preventing vehicles from passing over underground tanks, unless specified in the agreed and approved technical specifications and technical and operational documentation for the process system used		
23	Prevention of filling of tanks with fuel and delivery of fuel to consumers during thunderstorms and during the danger of atmospheric discharges		
24	Preventing tractors that are not equipped with spark arresters from entering the territory of the gas station, where operations are carried out to receive, store or dispense gasoline		
25	Prevention of repair works not directly related to repair of equipment, buildings and structures of the filling station		
26	Prevention of refueling of vehicles with passengers (except for cars with at least four doors)		
	Prevention of entry of vehicles loaded with		

27	explosives, compressed and liquefied combustible gases, flammable and combustible liquids, flammable materials, poisonous and radioactive substances and other hazardous substances, and materials		
28	Location of mobile petrol stations at designated sites		
29	<p>Execution of measures before the start of operation of mobile gas stations on a specially designated site:</p> <ol style="list-style-type: none"> 1) check of the station tightness by instrumentation and visually; 2) connection of grounding conductors of filling stations to the site grounding device; 3) installation of the tray under the fuel tank of the vehicle; 4) installation of barriers limiting the access of vehicles to the gas station by at least 1 meter; 5) installation of warning sign and information board 		

Official(s)

position signature

surname, first name, patronymic (if any)
Head of the subject of control and supervision

position signature

surname, first name, patronymic (if any)

Annex 8 to the joint order
of the Minister of the Republic of
Kazakhstan
dated October 30, 2018 № 758
and of the Minister of National Economy

Checklist in the field of state control and supervision in the field of fire safety in relation to undergrounds

Footnote. Annex 8 - as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall enter into force dated 01.01.2023).

The state body that appointed the inspection/preventive control with a visit to the subject (object) of control and supervision

Act on appointment of inspection/preventive control with subject visit (object) of control and supervision

(№, date)

Name of the subject (object) of control and supervision

(Individual Identification Number), Business Identification Number subject (object) of control and supervision

Address of the location

№ r/n	List of requirements	Conforms the requirements	Does not meet the requirements
1	Availability of an operational fire extinguishing plan, a passenger evacuation plan, the procedure for the actions of metro workers during the operation of tunnel ventilation shafts in the event of smoke or fire		
2	Prevention of the use of combustible materials for cladding walls, ceilings of escape routes (corridors, staircases, lobbies, halls), as well as for advertising in the decoration of		

	underground premises and station lobbies		
3	Use of pay cabinets installed in underground space of subways, made of non-combustible materials only		
4	Prevention of storage in underground structures of more than two cylinders with gases with a capacity of more than 5 litres each outside a specially designated place		
5	Gas welding and electric welding works in existing tunnels only from special units installed on mobile transport		
6	Preventing the placement of more than 30 metro employees in the classrooms of technical rooms located in the underground space for briefing		
7	Prevention of storage of spare parts and materials in rooms of machine rooms, escalators and in dismantling chambers		
8	Installation of retail stalls only in the ground station lobbies. Making stalls from non-combustible materials. Placing trading stalls in such a way that they do not interfere with the passage of passengers		
9	Use of oil electric radiators or heating panels for heating marketing stalls		
10	Equipment of stalls with primary fire extinguishing equipment and automatic fire alarm with signal output to the room with 24-hour presence of duty personnel		
	Prevention of trade and use of flammable and		

11	combustible liquids, combustible gases, aerosol-packaged goods, pyrotechnic products, flammable materials		
12	Prevention of storage of goods, packaging material, trade equipment in station premises		

Official(s)

position signature

surname, first name, patronymic (if any)
Head of the subject of control and supervision

position signature

surname, first name, patronymic (if any)

Annex 9 to the joint order
of the Minister of the Republic of
Kazakhstan
dated October 30, 2018 № 758
and of the Minister of National Economy
of the
Republic of Kazakhstan
dated October 30, 2018 № 31

Check list

in the field of state control and supervision in the field of fire safety in relation to tourist bases, guest houses, rest houses, boarding houses, health camps, summer recreation places for children

Footnote. Annex 9 - as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall enter into force dated 01.01.2023).

The state body that appointed the inspection/preventive control
with a visit to the subject (object) of control and supervision

Act on appointment of inspection/preventive control with visit of the subject
(object) of control and supervision

(№, date)

Name of the subject (object) of control and supervision

(Individual Identification Number), Business Identification Number
subject (object) of control and supervision

Address of the location

№ r/n	List of requirements	Conforms the requirements	Does not meet the requirements
1	Prevention of placement of children's health camps in wooden buildings above the 1st floor		
2	Availability of non-combustible roof and insulation, as well as plastering of frame and shield buildings of children's health camps		
3	Prevention of covering of the building with combustible materials, including straw, chips, reeds, only		
4	Prevention of the arrangement of kitchens, laundries in wooden buildings occupied by children		
5	Prevention of placement of more than 50 children in buildings and structures of fire resistance degree IV and V		
6	Prevention of furnace, use of kerosene and electric heating devices in premises occupied by children in summer		
7	Placement of laundry and kitchens, in summer recreation areas for children and health camps in separate buildings at a distance of at least 15 meters from wooden buildings where children shall be accommodated		

8	Prevention of placement of children in summer recreation areas, health camps not provided with external fire-fighting water supply		
9	Providing summer recreation areas for children, summer health camps with a fire alarm and primary fire extinguishing equipment. Availability of 24-hour duty of maintenance personnel		
10	Presence of mineralized fire strips with a width of at least 4 meters along the perimeter of the territory of sanatoriums, rest houses and health-improving institutions (including summer children's cottages, children's health-improving camps) located in forests and steppe massifs		
11	Availability in the children's camp of a plan of organizational and technical measures to ensure fire safety and a scheme of the camp (base), which indicates all buildings, places of residence of people (residential buildings, tents), economic places, sources of external fire water supply, parking lots. Arrangement of the scheme at the entrance to the territory of the camp (base)		
12	The construction on the territory of the places of summer holiday of children and health camps of tents (yurts) the area of the territory occupied by one group (1 or 2 rows) shall be taken no more than 800 square meters. Ensuring the distance between groups shall be at least 15 meters,		

and between tents (yurts) - at least 2.5 meters		
--	--	--

Official (s)

position signature

surname, first name, patronymic (if any)
Head of the subject of control and supervision

position signature

surname, first name, patronymic (if any)

Annex 10 to the joint order
of the Minister of the Republic of
Kazakhstan
dated October 30, 2018 № 758
and of the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 № 31

Check list

**in the field of state control and supervision in the field of fire safety
in relation to cultural, entertainment, entertainment and sports institutions**

Footnote. Annex 10 - as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall enter into force dated 01.01.2023).

The state body that appointed the inspection/preventive control
with a visit to the subject (object) of control and supervision

Act on appointment of inspection/preventive control with subject visit
(object) of control and supervision

(№, date)

Name of the subject (object) of control and supervision

(Individual Identification Number), Business Identification Number
subject (object) of control and supervision

Address of the location

№ r/n	List of requirements	Conforms the requirements	Does not meet the requirements
1	<p>Connection to each other and strong attachment to the floor of all chairs and chairs in the auditoriums and in the stands (except for the presence of an independent exit from the box with no more than 12 seats, as well as in the auditoriums used for dance nights with no more than 200 seats when they shall be connected in a row with each other)</p>		
2	<p>Deep impregnation of stage box wooden structures (grates, stage flooring, suspended bridges, working galleries) with flame retardants during construction. Provision of periodic processing of these structures, as well as combustible scenery, stage and exhibition decoration, draperies in auditoriums and exhibition halls, halls, buffets</p>		
3	<p>Prevention within the stage box of theatrical and entertainment institutions of simultaneous finding of scenery and stage equipment for no more than two performances. Designation with signs of places of storage of scenery on the stage. Prevention of storage of decorations, props, wooden machines, slopes, inventory and property in holds, on grates and work platforms (galleries), under staircases and platforms, as well as in basements under auditoriums</p>		
	<p>Provision of a free circular passage stage with a width</p>		

4	of at least 1 meter during the design of productions around the tablet		
5	Prevention of smoking on the scene, use of open fire, arc spotlights, fireworks and fire effects		
6	Prevention of temporary seats for spectators (retractable, removable, collapsible), as well as prevention of seats made of synthetic materials that emit highly dangerous and extremely dangerous combustion products in the stands of indoor and outdoor sports facilities during combustion		
7	Preventing the installation of attached seats on the escape routes		
8	Removable seats designed to accommodate the background in the stands during sports and art holidays, the opening and closing of international competitions or international events, as well as cultural and entertainment events		
9	Preventing the arrangement of seats for spectators in gyms creating oncoming or intersecting streams of spectators from permanent and temporary stands		
10	Maintenance in good condition of devices for fastening temporary structures for seating spectators in indoor sports facilities, as well as fastening platforms, platforms and rings		
	Provision of stacking during free storage of combustible sports equipment, collapsible structures of halls, removable coatings of halls		

11	, materials, in stacks with an area of not more than 100 square meters, a height of 2.5 not more than a meter and below the load-bearing structures of the floor or coating 0.5 meters, with a width of passage between stacks and stacks and walls 0.8 meters (except for passages opposite door openings made along the width of the door)		
12	Prevention of storage of combustible materials in sports halls, as well as arrangement of premises with structures made of combustible materials directly under attachment units of metal and wooden bearing structures		
13	Ensuring the installation of laser generating units at distances not closer than 1 meter from the surfaces of combustible structures and decorations in equipment rooms on non-combustible material bases when laser installations are used for installation or illumination lighting		
14	Provision of laying between the wooden ramp of the platform (stage) and the covers of the electric luminaries of non-combustible material with a thickness of 8-10 millimetres, protection of non-combustible materials from the outside of all portable electric lights (lights) installed on the stage or platform		
15	Providing installation of protective metal mesh at all soffits from the side of the light, which prevents the		

falling out of the glasses of lamps and fragments of ruptured lamp flasks	
---	--

Official (s)

position signature

surname, first name, patronymic (if any)
Head of the subject of control and supervision

position signature

surname, first name, patronymic (if any)

Appendix 11
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist

in the sphere of state control and supervision in the field of fire safety in respect of religious buildings (structures)

Footnote. Appendix 11 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

The state body that assigned the inspection/preventive control with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object) of control and supervision

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
1	Installation of candlesticks, lamps and lighting equipment with open flames on non-combustible bases in a stable position that prevents them from tipping over		
2	Preventing the use of open fire sources for services and rituals at a distance of less than 0.5 meters to room and interior decoration, clothing and items made of combustible materials		
3	Preventing the use of open flame luminaires with damaged glass bulbs, as well as the use of flammable liquids when refueling them		
4	Storage of flammable liquids, for refilling lamps, lamps and similar devices, in closed unbreakable containers in metal cabinets with a capacity not exceeding 2 liters.		

Official (s)

position signature

surname, name, patronymic (if any)

Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 12
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758

Checklist

in the sphere of state control and supervision in the field of fire safety in respect of oil and gas producing and oil and gas processing industry facilities

Footnote. Appendix 12 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

The state body that assigned the inspection/preventive control
with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object)
of control
and supervision

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number
of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
1	Fencing of the territory of oil depots, loading and pumping stations with a ventilation fence made of non-combustible material not less than 2 meters high		
2	Avoiding planting trees and shrubs in the square of the reservoir embankments		
3	Avoiding making fires, burning debris, waste, use torches, kerosene lamps and other sources of open fire on the territory of the object		

4	Clearing areas designated for installation, release from above-ground and underground pipelines, cables, clearing from trees, bushes, grass		
5	Availability of a platform around ground structures for the movement of vehicles and fire equipment with a width of 10-12 meters		
6	Availability of liquid drainage from the mouth and ground structures into special barns (traps). Placement of fuel tanks and installations no closer than 20 meters from surface premises, equipment, pipelines. Equipping fuel installations with pumps, tanks - level gauges, warning and prohibiting signs (marks)		
7	Preventing the use of flexible hoses in explosive process systems		
8	Placement of fire extinguishing equipment near fire hazardous areas (power and pumping unit, fuel unit, power plant)		
9	Availability of access road and embankment at the installation sites based on fuel and lubricants storage volume		
10	Availability of pumps and compressors, pumping combustible products, shut-off, cut-off and safety devices on suction and discharge lines		
11	Preventing of storage of fuels and lubricants and highly flammable materials inside fire and explosive hazardous facilities		
	Output of the exhaust line of internal combustion engines at a distance of at		

12	least 15 meters from the wellhead, 5 meters from the shelter wall (base) and 1.5 meters from the top of the roof (shed)		
13	Availability in the places of passage of the exhaust line through the walls, shelter, roof (shed) of a gap of at least three diameters pipe. Availability of insulating gaskets and incombustible cutting		
14	Equipping of exhaust pipes with spark arrestors		
15	Preventing the use of open fire and smoking in fire-hazardous and explosive rooms, under the bases, gas-hazardous areas, near storage tanks for fuels and lubricants, oil products, combustible substances and reagents		
16	Preventing gas hazardous, fire and welding works in the presence of gas, pollution with fuels and lubricants, oil products		
17	Constant maintenance of power, drilling and oil-field equipment, shelters, mouths and areas of the facility in fireproof condition, regular protection against oil pollution, spills of fuel and lubricants, petroleum products		
18	The use of special technical equipment used in cementation, installation of oil and acid baths, research and emergency works in availability of spark arrestors of exhaust pipes		
19	Installation during well development of a mobile compressor at a distance of at least 25 meters from the well on the windward side		

20	When flushing the well with oil, installation of the unit at a distance of at least 10 meters from the mouth		
21	Preventing the development of gas and gas condensate wells by swabbing, and fountain wells by tartan gelling		
22	Providing during the development of wells with mobile units of attaching possibility to the working manifold the required number of units, both for development and in case of well killing		
23	Elimination of the release of the oil drain device into common barns and traps along open ditches in order to avoid ignition (fire)		
24	Availability on the lines of gas and air distribution booths at wells of check valves installed to prevent the ingress of oil and gas from the well into the compressor		
25	Availability from the outside space of gas distribution boxes of sign " Gas! Flammable!		
26	Equipping of exhaust pipes of internal combustion engines of mobile compressors with silencer with spark arrestor		
27	Availability on the discharge line of the last compression stage of the compressor (outside the building of the compressor) of a safety device that operates at a pressure exceeding the working one by 10%		
	Equipping of compressor with signaling the deviation of parameters from normal operation, as well as automatic		

28	shutdown when the pressure and temperature of the combusted gas (air) increases, the cooling water supply stops and the pressure drops at the intake and in the lubrication system		
29	Preventing the placement in gas compressor rooms of tools and equipment not related to the operation with compressor unit		
30	Preventing the intake of air for air compressors in places where flammable vapors or gases are released, as well as in places where there are possible sources of ignition		
31	Providing the access for inspecting grounding conductors and their welding sites		
32	Preventing application of steel wire for grounding conductor		
33	Preventing installation of a control station, autotransformers, transformers under the wires of power lines of any voltage		
34	Construction of premises or booths for installation of electrical submersible centrifugal pumps from non-combustible material		
35	Availability of a Plan for elimination of possible accidents and fires, taking into account the methods of intensification of production developed and posted in a prominent place		
36	Providing facilities where methods of intensification of production are carried out, with reliable telephone or radio communication with the central dispatch center of the enterprise		

37	Availability of the plates hung out at the means of communication with indication of names and the procedure of giving signals , call of heads and responsible persons, fire department, ambulance, gas rescue service		
38	Preventing the discharge of oil and chemical residues from the tanks of aggregates and tankers into industrial sewage		
39	Preventing the use of fire-fighting instruments and equipment, emergency and gas rescue means for works not related to their direct purpose		
40	Presence of inscription " Flammable" on tanks with foam reagent and other combustible chemicals		
41	Preventing pouring and draining of foam reagent and other combustible chemicals during a thunderstorm		
42	Placement of mobile technological equipment for injection of reagent into the reservoir, taking into account the terrain and wind direction, to ensure, if necessary, its leave from the dangerous zone and evacuation of personnel		
43	Preventing the placement of mobile equipment, pumping installations within the security zone of overhead power lines or above oil and gas pipelines		
44	Equipping furnace with automatic devices that regulate the temperature of the heated oil within the specified limits, as well as shutting off the gas supply to the burners when the gas pressure increases or		

	decreases, provided by the manufacturer		
45	Equipping on the fuel pipe of a regulated reducing device and safety valve in the burner, as well as devices to prevent condensate from entering the control-measuring instruments		
46	Equipping technical vehicles (cars, tractors) with spark arrestors		
47	Installing a tank with hot oil no closer than 10 meters from the mouth on the leeward side		
48	Installing compressors and electrical equipment at a distance no closer than 10 meters, and a compressor with an internal combustion engine - no closer than 25 meters from the well mouth. Equipping the exhaust pipe of an internal combustion engine with spark arrestor		
49	Presence of inscription or sign "Flammable" on tankers or other containers with gas condensate		
50	To drain or fill condensate providing tank trucks with grounding devices		
51	Installing of aggregates and tank trucks no closer than 25 meters from the well mouth and at least 6 meters from each other on the windward side		
52	Providing the territory of the site where the formation treatment is carried out with the method of intra-layer moving combustion front, warning posters and fencing with metal pickets with a red flag		

53	Use of non-combustible materials for heat insulation equipment		
54	Equipping gangways, separators and other apparatuses with ladders and service platforms		
55	Construction of oil and sand traps from non-combustible material. Availability around the open oil trap of a fence not less than 1 meter high		
56	Preventing malfunction of devices intended in case of accident or fire for oil drain . Marking of gate valves of the emergency drain lines with identification marks, release of the approaches to them		
57	Equipping pumping rooms for pumping oil with forced-air ventilation in intrinsically safe design		
58	Preventing start-up of pumps in case of faulty or switched-off ventilation		
59	Separation of premises for the placement of internal combustion engines from the premises for pumps with gas-tight walls		
60	Preventing the use of flat-time gears in rooms where pumps for highly flammable liquids are installed		
61	Preventing accumulation of lubricants under the pumps, spreading and splashing. Keeping the floor in the pump room clean and regular washing with water		
62	Storage of lubricants in pumping in the amount of not more than the daily requirement, in special metal barrels or boxes with lids		

63	Preventing the storage of highly flammable and combustible liquids in the pump room		
64	Preventing passage during blowing down and testing of the pipeline, being within the clutch zone of cars, tractors with running engines, as well as well as using open fire and smoking		
65	Separation of premises for the placement of internal combustion engines from the premises for pumps with gas-tight fireproof walls		
66	Preventing oil products accumulation. Equipping pump rooms with water risers with rubber hoses to remove spilled petroleum products		
67	Maintaining working and evacuation ladders of trestles, winches at the end of railway deadlocks of trestles in good condition		
68	Provision of operational sites of loading devices on trestles with a hard surface and unobstructed drainage of various liquids through a hydraulic gate into the production and storm water drainage system or a special collector		
69	Availability of the allowed number of machines established by the administration of the enterprise, being at the same time on the operational site		
70	Availability of a cable or rod for towing tank trucks in case of fire		
	Availability of signal signs - control posts on both sides of the discharge and filling devices or separately		

71	standing risers on the railroad tracks (at a distance of two two-axle cars or one four-axle car), beyond which diesel locomotives are not allowed to pass		
72	Equipping transition bridges on the railroad loading and unloading rack for flammable petroleum products with wooden pads with countersunk bolts or materials excluding spark formation		
73	Grounding of railroad tracks, trestles, pipelines, telescopic pipes and hose tips. Checking the resistance of grounding devices at least once a year.		
74	Preventing the passage of motor vehicles to the territory of the plant, the technological process of which provides for the accumulation of flammable vapors and gases, with the installation of prohibiting signs		
75	Preventing persons wearing shoes lined with metal nails or horseshoes from entering explosive rooms and gas-hazardous areas		
76	Preventing the operation of transport carts, the wheels of which cause sparks on impact in explosive workshops of category A and B. Maintenance of drainage system manholes with permanently closed lids, which are covered with 10 centimeters of sand		
77	To prevent the spread of fire through the industrial drainage network during a fire, installation of hydraulic gates in special wells (the water layer		

	forming the gate should be at least 0.25 meters high in each hydraulic gate)		
78	Installation of hydraulic valves on all outlets from rooms with technological equipment, platforms for technological installations, groups and separate tanks, valve assemblies, groups of devices, pumping, boiler rooms, loading/discharging racks		
79	Preventing the operation of the wastewater system with or without defective or improperly designed hydraulic gates		
80	Preventing fire-explosive products from draining into drainage systems. Availability of special containers for this purpose		
81	Grounding of metal blowers of ventilation systems installed in explosive production facilities		
82	Preventing equipment from operating when ventilation is not working properly		
83	Provision of round-the-clock operation of ventilation in closed rooms where equipment and communications containing flammable and explosive gases are located		
84	Availability of mechanical emergency ventilation in production areas where sudden intensive release of harmful or explosive gases or vapors is possible		
85	Provision of automatic start of emergency mechanical ventilation under the action of sensors-gas analyzers and availability of remote start of emergency ventilation from the buttons located at the outer		

	door of the production room		
86	Grounding of loading risers of railroad tank car filling racks. Electrical connection of rails of railroad tracks within the discharge and loading front between each other and connection to the grounding device not connected to the grounding of the electric traction network		
87	Connection of tank trucks during draining and filling of flammable gases to the grounding device. Use of flexible (stranded) copper wire with a cross section of at least 6 square millimeters as a grounding conductor.		
88	Prevent operation of apparatus, pipelines and equipment in the event of product leaking through loose flange and split connections		
89	Providing combustible surfaces of apparatus and vessels with proper thermal insulation made of non-combustible materials		
90	Do not use sampling taps without passing hot product through the cooler. Keeping the outlet tubes and refrigerator tubes in good condition		
91	Preventing the use of open-type luminaires in production facilities for work associated with the possibility of sparking		
92	Keeping the devices intended for product discharge in case of an accident or fire in good condition. Marking of gate valves of emergency drain lines with identification signs		

93	Preventing the operation of tube furnaces with defective doublers and their cabinets		
94	Arrangement of sites for heat exchangers with hard surface with drainage into a flume, with outlet to the industrial drainage system through a hydraulic gate. Provision of a site with a device for flushing away combustible products		
95	Painting of pipelines with identification coloring depending on the substance transported through them, availability of numerical designation and direction of product movement		
96	Preventing the operation of pipelines intended for pumping explosion and fire hazardous media in the presence of "clamps"		
97	Fencing of the area around the flare within a radius of at least 50 meters and marking with warning signs, as well as clearing of herbaceous vegetation within the fences		
98	Avoidance of wells, pits and buried areas within the flare area fences		
99	Installation of flame arrestors on gas pipelines before entering the flare pipe, accessible for inspection and repair		
100	Maintenance of blocking and signaling devices to control process parameters of compressors and pumps in good condition		
101	Availability of grounding of pumps pumping fire-explosive products, regardless of the grounding of electric motors located on the same frame with the pumps		

102	Discharging the emitted product outside the room by purging pumps, liquid product - by pipeline to a special container, and vapors and gases - to a flare or candle		
103	Continuous monitoring of lubrication of rubbing parts during pump operation, as well as the temperature of pump bearings and glands. Preventing the spreading and splashing of lubricants		
104	Availability of outdoor lighting of the enterprises' territories, which is to be switched on from places with permanent stay of service personnel		
105	Preventing the operation of electrical equipment in hazardous areas without an explosion protection label		
106	Preventing the operation of explosion-protected electrical equipment with a defective protection system		
107	Preventing changes in the design of explosion-protected electrical equipment		
108	Preventing the laying of power lines over the territory of explosion and fire hazard zones and at a distance of less than 1.5 meters of the height of the power line support from these zones		
109	Prevent the use of hose cables with damaged sheaths (punctures, cuts, joints)		
110	Preventing the use of process pipelines containing flammable gases, liquids, and pipelines covered with insulation for corrosion protection as grounding and grounding wiring		

111	Availability of a common grounding circuit for electrical equipment, lightning protection, static electricity protection		
-----	--	--	--

Official (s)

position signature

surname, name, patronymic (if any)
Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 13
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist

in the sphere of state control and supervision in the field of fire safety in respect of medical organizations

Footnote. Appendix 13 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

The state body that assigned the inspection/preventive control with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object) of control and supervision

№, date)
Name of the subject (object) of control and supervision

(Individual identification number), business identification number
of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
1	Report of data on the number of patients in each building of the institution by the head of organization daily after the end of discharge		
2	Provision of stretchers for patients unable to move on their own one stretcher for every five patients		
3	Avoiding the placement of rooms that are not related to the medical process or rent them out in buildings with wards for the sick		
4	Preventing the use of rubber and plastic hoses for supplying oxygen from cylinders to hospital wards		
5	Preventing the use of defective medical electrical equipment		
6	Preventing the use of irons, electric cookers and other electric heating devices in hospital wards and other rooms occupied by patients		
7	Preventing the installation and storage of oxygen cylinders in rooms not provided for by the project documentation		
8	Prevent installation of boilers, water heaters and titans, sterilization of medical instruments, as well as heating of paraffin and ozokerite outside specially adapted rooms		
	Providing in laboratories, departments, doctors' offices the storage of medicines and reagents (relating to highly flammable and combustible		

9	liquids - alcohol, ether) in special lockable metal cabinets with a total amount of not more than 3 kilograms, taking into account their compatibility		
10	Preventing the joint storage of cylinders with oxygen and combustible gas, as well as storage of these cylinders in the material and pharmaceutical warehouses		
11	Maintaining in good condition all therapeutic electrical equipment in physiotherapy rooms, anesthesiology, resuscitation and intensive care departments, operating rooms, providing reliable grounding, factory electrical diagram and technical passport		
12	Provision with sterilizers, including those with an air gap, used in electrical and light therapy cabinets, only factory-made and on the surface of non-combustible materials		
13	Emissions from local ventilation systems from devices and installations at a height of not less than 2 meters above the highest point of the roof		
14	Production of preventive inspection of equipment in the terms established by the technical passport (instruction) with taking measures to eliminate the detected defects		
15	Keeping logbooks of fire-prevention instruction conducted with the service personnel and noticed defects in the electrical equipment in each		

	electrical and light-treatment department (office)		
16	Avoiding the use of outdoor open staircases for evacuation of patients from hospital buildings		
17	Provision of free transportation of patients on gurneys, through doorways and passages into the operating rooms, preoperative, anesthetic, and rooms of the operating unit		
18	Provision of protective measures to prevent fires and explosions in the operating room to prevent spontaneous ignition of narcotic drugs and preparations		
19	Storage of highly flammable and combustible liquids in working premises in an amount not exceeding the shift requirement, in thick-walled glass or unbreakable containers with dense plugs placed in a metal box lined with a non-combustible material inside, with a lid. Preventing the storage of such liquids in plastic containers		
20	Ensuring the storage of substances and materials in laboratories strictly according to the assortment . Preventing the joint storage of substances, the chemical interaction of which may result in fire or explosion		
	Coating and edging from non-combustible materials of working surfaces of tables, racks, fume cupboards intended for work with fire- and		

21	explosion-hazardous liquids and substances. Tables and cabinets made of corrosion-resistant materials for working with acids, alkalis and other reactive substances		
22	Preventing the use of fume cupboards with broken glass or faulty ventilation. Equipping fume cupboards with a ventilation system with independent ventilation ducts		
23	Avoiding storage of liquid oxygen in the same premise with flammable substances, fats and oils		
24	Arrangement of cylinders with compressed, liquefied and dissolved combustible gases outside the laboratory building in metal cabinets with slots or louvered grilles for ventilation		
25	Do not place flammable and combustible liquids and combustible materials closer than 1 meter from heating devices, burners, fire sources		
26	Preventing the spillage of spent flammable and combustible liquids into the drainage system		
27	Grounding of pipelines supplying flammable and combustible liquids		
28	Making the doors of pressure chamber rooms without glazing, self-closing, with sealed joints, without locks, as well as locking devices, with the width of baroque room doors, allowing to carry patients on a hospital gurney or chair, but not less than 1 meter		
	Wall cladding of pressure chamber rooms, suspended		

29	ceilings of non-combustible materials		
30	Heating of pressure chamber rooms with centralized, water heating with the temperature of the coolant not more than 95°C . Ensuring the distance from heating devices and heat sources to a pressure chamber room is not less than 1 meter		
31	Availability of emergency lighting in rooms in which two or more single pressure chambers or one multi-seat are installed		
32	Availability of only incandescent lamps in the lamps installed directly in the pressure chambers		
33	Availability of automatic gas analyzers in rooms with the presence of pressure chambers to monitor the oxygen content		
34	Preventing patients from being placed in a pressure chamber in synthetic clothing		
35	Preventing the use of pressure devices without grounding pressure aggregates (pressure chamber, air conditioner)		
36	Preventing the use of faulty devices and electrical wiring (with damaged insulation, unreliable sparking contacts), use of electric heating devices, use of furniture made of combustible materials, materials and objects capable of causing sparks, use of open flames, smoking, open-type lamps for lower lighting of workplaces		
	Preventing the storage in a hyperbaric chamber of combustible and highly		

37	flammable liquids, oils as well as combustible materials, including dressing supplies		
38	Avoiding connection of the pressure devices to the mains with voltage exceeding the permissible value		
39	Prevent the operation of pressure devices and hyperbaric chambers without primary fire extinguishing equipment		
40	Avoiding the storage in rooms through which electrical cables pass, as well as in rooms with gas utilities and oil-filled equipment		
41	Avoiding the storage of products in bulk and stacking them close to radiators and heating pipes		
42	Preventing unpacking and packing of materials directly in storage facilities		
43	Ensuring that plastic products are stored in a ventilated, dark, dry room at room temperature, at least 1 meter away from heating systems		
44	Providing storage areas for flammable and explosive medicines with non-combustible and stable shelving and pallets		
45	Storage of flammable and combustible liquids in built-in fireproof cabinets with doors at least 0.7 meters wide and 1.2 meters high		
46	Storage of flammable liquids in quantities exceeding 100 kilograms in a detached building in glass or metal containers isolated		

	from the storage of flammable substances of other groups		
47	Availability of signs near the entrance to each storage room of flammable and explosive substances with the inscription "Responsible for ensuring fire safety (surname, name, patronymic (if any) of the responsible person)"		
48	Preventing the storage of highly flammable and combustible liquid medicines with mineral acids (sulfuric, nitric and other acids), compressed and liquefied gases, flammable substances, as well as with inorganic salts that give explosive mixtures with organic substances (potassium chlorate, potassium permanganate)		
49	Storage of flammable and explosive medicines in thick-walled, tightly closed containers (bottles, jars, drums), pouring paraffin into closures		

Official (s)

position signature

surname, name, patronymic (if any)

Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 14
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist

in the sphere of state control and supervision in the field of fire safety in respect of educational organizations, educational institutions

Footnote. Appendix 14 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

The state body that assigned the inspection/preventive control with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object) of control and supervision

№, date)

Name of the subject (object) of control and supervision _____

(Individual identification number), business identification number of the subject (object) of control and supervision

Registered address _____

Item №	List of requirements	Compliant	Non-compliant
1	Conducting classes with pupils and students on the study of fire safety requirements in everyday life and actions in case of fire. With junior classes, as well as in kindergartens, conducting conversations on fire prevention topics. In general education schools, vocational schools, colleges tertiary colleges, organizations of higher and (or) post-graduate education - instructive lessons on the study of fire safety rules		
2	Preventing the storage of highly flammable and combustible liquids in		

	laboratories in quantities not exceeding the shift requirement		
3	Placement of groups (classes) of children of preschool and primary school age not higher than the third floor in buildings of children's organizations		
4	Ensuring unobstructed evacuation of people and access to firefighting equipment when arranging furniture and equipment in classrooms, offices, workshops, dormitories, canteens and other rooms		
5	Not allowing the number of desks (tables) in classrooms and classrooms to exceed the number established by the project documentation		
6	Availability of round-the-clock duty of service personnel with provision of telephone communication, in educational organizations and preschool organizations with round-the-clock stay of children		

Official (s)

position signature

surname, name, patronymic (if any)

Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 15
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy

Checklist in the sphere of state control and supervision in the field of fire safety in respect of Medical and social institutions (organizations), residential organizations, children's homes (homes for the elderly and persons with disabilities, orphanages, boarding homes, neuropsychiatric centers, hospices)

Footnote. Appendix 15 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

The state body that assigned the inspection/preventive control with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object) of control and supervision

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
1	Preventing the use of furniture and equipment made with the use of polymeric materials capable of releasing highly toxic products during combustion		
2	Ensuring preparation (heating) of food in places specially adapted and equipped for this purpose. Preventing the use of electric heaters for domestic needs without means of automatic shutdown		

3	Preventing the use of irons, electric stoves and other electric heaters in bedrooms, game rooms and other rooms occupied by the serviced ones. Ironing of clothes only in specially equipped rooms for these purposes		
4	Accommodation of bedridden persons with disabilities and the elderly in the premises, taking into account the provision of their evacuation as quickly as possible		
5	Preventing the location of storerooms with flammable and combustible materials directly under or adjacent to living rooms and wards		

Official (s)

position signature

surname, name, patronymic (if any)

Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 16
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist in the sphere of state control and supervision in the field of fire safety in respect of retail outlets

Footnote. Appendix 16 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

The state body that assigned the inspection/preventive control with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object) of control and supervision

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
1	Preventing the temporary storage of flammable materials, waste, packaging and containers in sales areas and on evacuation routes, as well as placement of combustible containers close to the windows of buildings		
2	Preventing the storage of flammable goods or non-flammable goods in flammable packaging in the rooms that do not have window openings or smoke extraction shafts. Placement of storerooms for combustible goods and goods in combustible packaging near exterior walls		
3	Storage of ammunition for weapons and pyrotechnic products in cabinets made of non-combustible materials installed in rooms separated from other rooms by fireproof partitions. Preventing the placement of these cabinets in basements		

4	Preventing performance of hot works while customers are in sales areas		
5	Preventing the trade in flammable and combustible liquids (except for medicines, medical devices , cosmetic and alcoholic products), flammable gases , gunpowder, capsule, pyrotechnic and explosive products when placed in buildings for other purposes other than trade buildings		
6	Preventing the placement of vending, gaming apparatus and equipment, as well as the sale of goods on evacuation routes		
7	Avoiding installation of cylinders with flammable gases for filling balloons and other purposes in sales areas		
8	Construction of canopies made of non-combustible materials over rows of open market stalls		
9	Preventing the covering of rows of open market stalls with fabrics, paper, films		
10	Preventing the placement of markets in parts of or annexes to buildings for other purposes		
11	Execution of kiosks and stalls, pavilions installed in buildings and structures made of non-combustible materials. Making of pavilions and kiosks intended for trade in flammable liquids, deodorants, compressed gases of the I, II, IIIa degree of fire resistance, standing alone or in a group with kiosks selling similar goods		
	Preventing the loading of goods and unloading of		

12	containers during working hours along the paths connected with the evacuation exits of customers		
13	Preventing trade in household goods, varnishes, paints and other flammable and combustible liquids, packaged in glass containers with a capacity of more than 1 liter each, as well as fire hazardous goods without labels with warning signs such as "Flammable", "Do not spray near fire." Carrying out the package of fire-hazardous goods in specially adapted for this purpose premises		
14	Placement of kiosks, as well as one-storey pavilions with the area up to 35 square meters inclusive on the allocated territory in groups. Placement in one group of not more than 20 kiosks and pavilions of I, II, III, IIIa fire resistance degree or 10 kiosks of IIIb, IV, IVa and V fire resistance degree. Separation of a group of 10 containers by fire partitions of the 1st type. Presence of fire protection distance between groups of kiosks and (or) pavilions, between freestanding kiosks and (or) pavilions, as well as from groups and freestanding kiosks and (or) pavilions to other buildings and structures.		
15	Placement of combustible waste collection site at a distance of at least 15 meters from kiosks and pavilions		
16	Making rooms for temporary accommodation of packing materials and		

	inventory with the area not exceeding 5 square meters		
17	Using electric (with the use of oil radiators, heating panels - having a certificate of conformity), steam or water heating in kiosks installed in settlements		
18	Availability in kiosks, pavilions of an automatic fire alarm system with sound and light signal output to the facade of the structure or directly to the protected premises		
19	Preventing the location of entertainment areas for children in shopping and entertainment centers in basements and ground floors		

Official (s)

position signature

surname, name, patronymic (if any)

Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 17
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist

in the sphere of state control and supervision in the field of fire safety in respect of storage facilities

Footnote. Appendix 17 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of

National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

The state body that assigned the inspection/preventive control with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object) of control and supervision

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
1	Avoiding joint storage in the same section with rubber or automobile tire of any other materials and goods, regardless of the homogeneity of fire extinguishing agents used		
2	Ensuring protection of flammable gas cylinders, containers with flammable and combustible liquids, as well as aerosol packaging from solar and other thermal effect		
3	Carrying out the storage of aerosol packaging in multi-storey warehouses in fire compartments only on the top floor, with the number of packages in the compartment not more than 150000 pcs		
4	Carrying out warehousing in an isolated compartment of the warehouse no more than 15000 packages (boxes), with a total warehouse capacity		

	of no more than 900000 packages. Placement of warehouses in atticless buildings, with easy-reset coatings		
5	Carrying out warehousing in common warehouses of aerosol packages in the amount of not more than 5000 pieces		
6	Carrying out the storage of aerosol packages in open areas or under sheds only in non-combustible containers		
7	Carrying out warehousing of materials in piles in warehouses with rackless storage method. Availability of free passages with a width equal to the width of the doors, but not less than 1 meter in front of the doorways of the warehouse rooms. Availability of longitudinal aisles with a width of at least 0.8 meters every 6 meters in warehouses		
8	Carrying out treatment with fire retardant composition of wooden structures inside the warehouses		
9	Avoiding the placement of warehouses in the premises through which transit electric cables, gas and other communications pass		
10	The distance from the lamps to the stored goods is at least 0.5 meters and 0.2 meters from the surface of combustible building structures		
11	Preventing constructing cabins, rooms for meals and other utility services in rooms intended for the storage of inventory		

12	Preventing parking and repairing of loading-unloading and transport means, in warehouses and on landing stages		
13	Carrying out in the warehouse building operations related to opening of containers, checking of serviceability and minor repairs, packing of products, preparation of working mixtures of fire-hazardous liquids (nitropaints, varnishes) in rooms isolated from the storage areas		
14	Placing the devices intended for disconnecting the power supply to the warehouse outside the warehouse, on a wall made of non-combustible materials or on a freestanding support, enclosing them in a cabinet or niche with a device for sealing and locking		
15	Preventing emergency lighting in the premises of warehouses, as well as operation of gas stoves, electric heaters and plug-in socket installation		
16	Storage of materials in an open area with the area of one section (stack) not exceeding 300 square meters, and minimum fire safety separation distance between stacks not less than 6 meters		
17	Preventing accommodation of personnel and other persons in buildings located on the territory of bases and warehouses		
18	Avoiding the entry of locomotives into the warehouses of categories A, B and B1-B4		

19	Preventing storage of flammable and combustible liquids in shop storerooms in quantities exceeding the norm established at the enterprise		
20	Preventing the storage of combustible materials or non-combustible materials in combustible containers in basement and ground floor rooms that do not have windows with smoke vents, as well as when communicating common stairwells of buildings with these floors		
21	Placement of warehouses for storing cylinders with flammable gases in single-storey, atticless buildings with easy-reset coatings		
22	Painting the windows of rooms where gas bottles are stored with white paint or their equipment with non-flammable sun-protection devices.		
23	Preventing the storage of any combustible materials and implementation of hot works at a distance of 10 meters around the storage of cylinders		
24	Making cabinets and booths, where cylinders are placed, from non-combustible materials and their equipment with natural ventilation, excluding the formation of explosive mixtures in them		
25	Carrying out the storage of cylinders with flammable gases separately from cylinders with oxygen, compressed air, chlorine, fluorine and other oxidizing agents, as well as from cylinders with toxic gases		

26	Carrying out the storage of gas in a compressed, liquefied and dissolved state in cylinders. Coloring the outer surface of the cylinders in the color specified for this gas		
27	Avoiding the ingress of oils (fats) and contact of the valve fittings with oiled materials during the storage and transportation of cylinders with oxygen		
28	Equipping gas storage rooms with more than 40 cylinders with serviceable gas analyzers to explosive concentrations		
29	Preventing the presence of persons in shoes, lined with metal nails or horseshoes in a storage room, where cylinders with combustible gases are stored		
30	Storage of cylinders with flammable gases, having skirts, in a vertical position in special sockets, cages or other devices that prevent them from falling		
31	Storage of cylinders not having skirts in a horizontal position on the frames or racks. The use of the height of the stack is not more than 1.5 meters, closing the valves with safety caps, and turning them in one direction		
32	Preventing the storage of any other substances, materials and equipment in gas warehouses		
33	Availability of natural ventilation in the room of warehouses with combustible gases		
	Availability of a layout plan for stacks, with an indication of the maximum amount of stored materials, minimum fire safety		

34	separation distance and passage ways between stacks, as well as between stacks and neighboring facilities in timber warehouses		
35	Preventing the warehousing of timber, equipment in minimum fire safety separation distance between stacks		
36	Purification of areas reserved for stacks to ground from grass, flammable debris and waste, or availability of a layer of sand, soil or gravel with a thickness of at least 0.5 meters		
37	Availability in each warehouse of an operational fire extinguishing plan with the definition of measures for disassembling stacks, heaps of balance, chips, taking into account the possibility of attracting workers and machinery of the enterprise		
38	Availability of points (posts) at the warehouses with a stock of various types of firefighting equipment in quantities determined by operational firefighting plans, except for primary firefighting equipment. Provision of timber stockpiles with necessary water supply for fire extinguishing		
39	Preventing works not related to the storage of timber in warehouses		
40	Arrangement of utility rooms for workers in timber warehouses in separate buildings in compliance with minimum fire safety separation distance		

41	Use of only factory-made electric heaters for domestic space heating in timber yards		
42	Placement of winches with internal combustion engines at a distance of at least 15 meters from roundwood stacks		
43	Preventing the installation of transportation packages in fire breaks, passages, access to fire water sources		
44	Availability in enclosed warehouses of at least 0.8 meters of aisle width between stacks and protruding parts of the building walls. A passageway width equal to the door width, but not less than 1 meter opposite the doorways of the warehouse		
45	Avoidance of partitions and offices in closed warehouses		
46	Making the floors of closed warehouses and areas under sheds made of non-combustible materials		
47	Carrying out the storage of chips in closed warehouses, bunkers and open areas with a base made of non-combustible material		
48	Availability of wells of non-combustible materials for the installation of thermoelectric converters to control the heating temperature of the chips inside the collar		
49	Preventing the storage of freshly mined coal from old coal dumps that have lain for more than one month		
50	Preventing the transportation of burning		

	coal by conveyor belts and shipping them to the railway transport or bunker		
51	Avoiding the placement of coal stacks over heat sources (steam pipelines, hot water pipelines, heated air ducts), as well as over laid electric cables and oil and gas pipelines		
52	Avoiding the ingress of wood, cloth, paper and combustible materials into stacks when stacking and storing coal		
53	Isolation with fire barriers (walls and partitions) of coal storage rooms, arranged in the basement or first floor of industrial buildings		
54	Preventing excess of fiber mass in a stack of more than 300 tons		
55	Ensuring the size of the stack is not more than 22x11 meters, in height not more than 8 meters		
56	There are no more than six stacks or sheds in the nest, the gap between stacks is not less than 15 meters, between sheds - 20 meters in all directions		
57	Presence in a group of no more than four nests (24 stacks or a shed), the gap between the sockets is at least 30 meters in all directions		
58	Presence in the sector of no more than four groups (96 stacks or sheds), the gap between the groups is at least 50 meters in all directions		
59	Avoiding the gaps between storage sectors of combustible fibrous materials of less than 100 meters		

60	Availability of fencing areas occupied by warehouses, sheds and open areas for the storage of fibrous materials		
61	Preventing the storage of industrial waste together with raw materials and ready products		
62	Preventing the access of railway (except for steam locomotives) and motor transport closer than 5 meters, and tractors - 10 meters to the sheds and stacks of fibrous materials without spark arrestors		
63	Ensuring that the volume of tank bunding is equal to the volume of the largest tank in the bund and that it is maintained in good condition at all times. Preventing disturbance of the integrity and height of the bund, as well as passageways along the tank farm boundaries		
64	Prevent the installation of electrical equipment and the laying of electrical lines inside the tank bunds and directly in the tanks, with the exception of lines for control and automation of filling and level measurement devices in explosion-proof version.		
65	Arrangement of pipeline communications in the tank farm to enable pumping of oil and petroleum products from one tank to another in case of a tank accident		
66	During the winter period of the year, timely removal of snow from tank roofs, as well as clearing snow from paths and fire passages on the territory of the tank farm		

67	Availability of gas analyzers with light and sound alarms for continuous monitoring of hydrocarbon concentration in explosion- and fire-hazardous areas in the tank farm territory		
68	Presence of inscriptions on the inadmissibility of violation of the fire safety regime on the entire territory of the tank farm and separate tanks in visible places		
69	Carrying out level measurement and sampling of petroleum products only by stationary systems of measuring devices, except for tanks with overpressure of gas space up to 2.10 Pa, in which the level is measured and samples are taken manually through the measuring hatch.		
70	Availability of sealed covers on hatches used for level measurement and tank sampling, as well as rings made of metal preventing sparking at the measurement opening on the inside of the tank		
71	Preventing the operation of tanks with sludge, leaks and faulty valves, pipe connections, gland packing, gate valves, fire extinguishing and cooling systems		
72	Availability of a schedule of planned works on cleaning of pyrophoric sulfur iron deposits for tanks storing sulfurous petroleum products		
73	The presence of shut-off devices in the form of flapper valves, actuated outside the embankment to remove oil product spilled		

	during an accident, as well as for the release of storm water at the outlets from the embankment		
74	Preventing the reduction of the embankment height established in the design documentation		
75	Preventing the operation of tanks that are warped and cracked, as well as faulty equipment, instrumentation, product pipelines and fixed fire-fighting devices		
76	Preventing the planting of trees, shrubs, grass in the embankment carriages		
77	Avoiding installation of containers on flammable substrates		
78	Preventing overfilling of tanks and cisterns		
79	Inspection of breathing valves and fire barriers in accordance with the requirements of the manufacturer's technical documentation. Cleaning valves and mesh from ice during inspections of breathing valves. Heating them only by fire-safe methods		
80	Preventing joint storage of flammable and combustible liquids in containers in the same room with their total quantity not exceeding 200 cubic meters of flammable liquids or 1000 cubic meters of combustible liquids		
81	Installation of barrels with flammable and combustible liquids in storages with manual stacking on the floor in no more than 2 rows, with mechanized stacking of barrels with flammable liquids - no		

	more than 5, and flammable liquids - no more than 3		
82	Preventing the width of the stack from exceeding 2 barrels. Making the width of the main aisles for transportation of barrels not less than 1.8 meters, and between the stacks - not less than 1 meter		
83	Storing fluid only in serviceable containers		
84	Fencing of open areas for storage of oil products in a container with earthen shaft or non-combustible solid wall with a height of at least 0.5 meters with ramps for passage to the sites		
85	Placement within one bunded area of not more than 4 stacks of barrels with the size of 25×15 meters and height of 5.5 meters with gaps between the stacks of not less than 10 meters, and between the stack and the shaft (wall) - not less than 5 meters. Execution of gaps between stacks of two adjacent sites not less than 20 meters		
86	Preventing the spill of oil products, as well as the storage of packaging material and containers directly in the storage and dumped areas		
87	Availability of required specialized equipment (bulldozer, dump truck, excavator, loader, water washer, water dispenser, water pumps) for fire prevention and maintenance of solid waste landfills		
	Provision of a mineralized strip at least 4 meters wide around the perimeter of the		

88	territory of the landfill for solid domestic waste storage		
89	Availability of a serviceable outdoor firefighting water supply with a capacity designed for the required flow rate of the outdoor firefighting water supply		
90	Subdivision of landfills (sites) into storage areas of no more than 10,000 square meters. Minimum fire safety separation distance of at least 8 meters width between the sites shall be in place		

Official (s)

position signature

surname, name, patronymic (if any)

Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 18
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist

in the sphere of state control and supervision in the field of fire safety in respect of agricultural facilities, livestock farms, poultry farms

Footnote. Appendix 18 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

The state body that assigned the inspection/preventive control

with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object) of control and supervision

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
1	Preventing in premises for animals and poultry construction of workshops, warehouses, parking of motor transport, tractors, agricultural machinery, and also production of works, not connected with service of farms. Preventing the entry of tractors, automobiles and agricultural machinery into these premises, whose exhaust pipes are not equipped with spark arrestors		
2	Preventing the storage of roughage in the attics of farms		
3	When operating electric brooders, the distance from the heating elements to the bedding and combustible objects shall be at least 80 centimeters vertically and 25 centimeters horizontally . Preventing the use of open heating elements		
4	Placement of mobile ultraviolet installations and their electrical equipment at a distance of at least 1		

	meter from combustible materials		
5	Installation of the gasoline engine of the shearing unit on the site cleared of grass and debris at a distance of 15 meters from the buildings. Storage of fuel and lubricants in a closed metal container at a distance of 20 meters from the cutting point and buildings		
6	Avoiding the accumulation of wool on the shearing point over a shift production and blocking the passage and release of bales with wool		
7	Storage of ammonium nitrate in independent I or II degrees of fire resistance atticless single-storey buildings with non-combustible floors. In exceptional situations, the allowance for storing nitrate is in a separate compartment of a common mineral fertilizer warehouse of an agricultural enterprise of I or II degrees of fire resistance. Storage of potent oxidizing agents (chlorates of magnesium and calcium, hydrogen peroxide) in separate compartments of buildings I, II and IIIa degrees of fire resistance		
8	Availability of protective firebreaks at least 4 meters wide when farms and agricultural facilities are located near coniferous forests, between buildings and forest areas for the spring-summer fire-dangerous period		
9	Availability of isolated premises with installation of bagging machine for		

	cleaning bags of flour and their storage		
10	Ensuring bulk storage of liquid fat and vegetable oil in a separate room at the baking enterprises		
11	Preventing the presence in the furnace of the stock of solid fuel for no more than one shift		
12	Availability outside the building of an isolated room from non-combustible structures for installation of consumable tanks of liquid fuel when operating of baking ovens on liquid fuel		
13	Making doors from production facilities with a simultaneous stay of 15 people at grain elevators, flour mills, feed mills and cereal mills open inward (against the evacuation route). Doors from vestibule locks opening in different directions (doors from production facilities to vestibule locks opposite the evacuation route, doors from vestibule locks to stairwells - on the evacuation route).		
14	Availability of automatic fire dampers or devices to close them in case of fire in the openings of fire walls for the passage of belt conveyors		
15	Preventing the passage of air ducts, material pipelines, gravity pipes through domestic, auxiliary and administrative rooms, control rooms, electrical switchgears, ventilation chambers and stairwells		
	Prevent installation of bucket elevators, passage of gravity and aspiration pipes, as well as		

16	installation of conveying and technological equipment in mines for cable laying		
17	Availability of aspiration at feed mills in places of unloading floury raw materials and bran		
18	Ensuring a tight connection of hatches for silos and bunkers, as well as hatches in gravity pipes, air ducts and aspiration covers that prevent dust from entering the premises		
19	Availability in all warehouses of external ladders located at a distance of no more than 100 meters from one another		
20	Availability of automatic braking devices on bucket elevators with a capacity of more than 50 tons/hour to prevent the belt from reversing during stops. Preventing installation of bucket elevators and individual parts made of combustible materials		
21	Preventing the combination of aspiration of containers for collecting and storing dust and operational (production) tanks in one aspiration unit with technological and transport equipment		
22	Availability of blocking technological and transport equipment with aspiration units		
23	Preventing the placement of ventilators and dust collectors of grain dryers in the working buildings of elevators		
24	Prevent collection and storage of aspirations and production dust in bunkers and silos located in the		

	production areas of elevators		
25	Preventing transit air ducts through the premises of raw materials and finished products warehouses, as well as through the premises of categories A, B and B 1-4 in terms of explosion and fire hazard		
26	Preventing the use of containers for gravitational sedimentation of dust (aspiration pits, dust extraction chambers), located after ventilators and blowing machines		
27	Grounding of air ducts and pipelines in at least two places		
28	Additional grounding of dust collectors and blowing machines. Do not use bolt washers made of dielectric materials and painted with non-electrically conductive paints in connections between plant components.		
29	Preventing contact between air ducts of aspiration systems and heating system pipelines		
30	Preventing equipment operation without aspiration systems, explosion dischargers on burrows and crushers provided for by design and technical documentation		
31	Presence of magnetic separators before passing products (raw materials) through rolling machines, crushers, whipping machines and impact machines		
32	Preventing the whips from touching the inner surface of the whip drum to avoid sparking.		

33	Avoidance of operation of chain conveyors (with immersed scrapers) without back-up sensors or ring switches that automatically stop the conveyor when the boxes are full		
34	Preventing auger operation without pressure-opening safety valves installed at the ends of the auger in the direction of product flow		
35	Preventing splicing of conveyor belts and drive belts by means of metal clips, bolts		
36	Preventing operation of the crusher with malfunctions, as well as without locking the electric motor with the device for automatic load regulation		
37	Preventing the use of artisanal safety pins for pelletizers, as well as metal rods with uncertain dimensions and mechanical characteristics		
38	Preventing operation of rollers without proper light signaling, without product loading, with pressed rollers, skewed and displaced rollers along the axis		
39	Preventing the use of elastic and strong connections of bodies of sieves, stone collectors, separators during the operation of sieve machines. Execution of flexible connections of bodies made of materials that do not allow dust to pass through with a strong connection and outlet spigots		
40	Preventing starting the peeling machines with removed heads, defective tensioning devices, poorly		

	fixed abrasive disks or without drying wheels		
41	Preventing operation of peeling and grinding machines with cracks and damage on disks, rollers, decks and unbalance		
42	Avoidance of operation of electromagnetic separators without interlocking them with electromagnets to exclude product feed in the event of a power failure		
43	Preventing operation of duct furnaces without explosive safety valves, with a minimum area of one explosive valve - 0.05 cubic meters, installed in the upper parts of furnaces and gas ducts		
44	Preventing operation of furnaces without ventilation devices for heat and gaseous substance removal		
45	Availability in furnaces operating on gaseous or liquid fuel of a device automatically shutting off the fuel supply in emergency situations: 1) cessation of liquid fuel supply to the furnace and air supply to combustion devices (for furnaces operating on liquid fuel); 2) exceeding the permissible temperature of heating gases in the heating system; 3) stop of the conveyor		
46	Preventing operation of ovens without a backup manual drive mechanism for unloading baked products in case of emergencies		
	Preventing operation of sluice gates or groups of unloader gates from in-plant pneumatic		

47	transport without speed control relays on end rollers (the requirement does not apply to sluice gates of a set of high-performance equipment)		
48	Preventing storage of non-grain products (meal, cake, granulated grass meal) in silos and bunkers of grain elevators		
49	Drying of corn in grain in shaft direct flow dryers installed outside the building		
50	Preventing storage of rice, millet, buckwheat husks in open areas and under sheds outside of bunker-type warehouses with exceeding 2 daily capacity of grits mill operation		
51	Preventing operation of silos with storage of grain, oilcake and meal, without remote daily temperature control installations (by stationary thermometry systems)		
52	Preventing the use of gravity and mechanical transport and pneumatic transport (elevators, chain conveyors, belt and rollerless conveyors) for transportation of industrial waste without closed enclosures.		
53	Breakdown of bread massifs into plots of not more than 50 hectares before grain harvesting. Making swaths with a width of at least 8 meters between the plots. Immediate harvesting of skewed grain from swaths. Availability in the middle of the swath of plowing with a width of at least 4 meters		

54	Location of temporary field mills not closer than 100 meters from grain areas, barnyards. At least 4 meters wide plastering of field mills and Location of temporary field mills not closer than 100 meters from grain areas, barnyard sites		
55	Availability of a tractor with a plough for plowing the combustion zone in case of fire in the immediate vicinity of the harvested grain areas of more than 25 hectares		
56	Prevent storage and refueling of tractor vehicles with oil products in the field outside special areas cleared of dry grass, combustible debris and plowed with a strip not less than 4 meters wide, or on plowing at a distance of 100 meters from barnyards, hay and straw stacks, bread areas and not less than 50 meters from buildings and structures		
57	Preventing storage and transportation of flammable substances in the cab and body of agricultural machinery. Keeping clean the engine compartment, parts of assemblies and units of agricultural machinery		
58	Prohibition during the sowing campaign, harvesting of grain crops and fodder preparation: 1) operation of tractors, self-propelled chassis and vehicles without hoods or with open hoods; 2) use of blowtorches to burn out dust in engine radiators; 3) operation of agricultural machinery (automobiles,		

	combines, tractors and machinery involved) without serviceable spark arrestors		
59	Installation of units for preparation of grass flour under a shed or in premises		
60	Preventing placement of grass meal preparation points at a distance of less than 50 meters to buildings, structures and tanks with fuel and lubricants, and less than 150 meters to open warehouses of roughage		
61	Installation of the fuel tank outside the unit. Equipping the fuel lines with at least two valves (one at the unit and one at the fuel tank).		
62	Preventing storage of flour in bulk, joint storage of flour with other substances and materials, as well as in buildings, structures and premises made of combustible materials. The storage shall be carried out in a separate warehouse or compartment, with the equipment of the room with a ventilation system and the exclusion of moisture in the room		
63	Stacking flour sacks in stacks no more than 2 meters high, two sacks per row. Aisles between rows at least 1 meter wide and along walls 0.8 meters wide.		
64	Ensuring isolation of flax, hemp and industrial crop processing rooms from the engine room		
65	Preventing operation of internal combustion engines in the engine room without spark arrestors on the exhaust pipes, as well as without fireproofing of		

	pipe outlets through combustible structures of engine room walls		
66	Storage of flax raw materials (straw, flax stock) in stacks, shokhs (under sheds), closed warehouses, and fiber and soot - only in closed warehouses		
67	Avoiding during the primary processing of industrial crops of: 1) storage and threshing flax on the territory of farms, repair shops, garages; 2) entry of cars, tractors in industrial premises, warehouses of finished products and shokhi. The stop of cars is provided at a distance of at least 5 meters , and tractors - at least 10 meters from the specified buildings, ricks and shokh; 3) arrangement of stove heating in the swingling shop		
68	Preventing entry of vehicles, tractors and self-propelled machines into the territory of the flax processing facility without defective spark arrestors		
69	Preventing approaching of vehicles to skids ("shokhs") by the side in the direction of exhaust gases exit from the exhaust systems of engines		
70	Preventing placement of smoking places on the territory of the flax processing facility at a distance of less than 30 meters from production buildings and finished product storage areas		
71	Preventing natural drying of flax stock outside of designated areas		

72	Separation of dryers located in production buildings from other premises by fire walls made of non-combustible materials. Plastering on both sides of combustible structures of freestanding buildings of dryers and drying chambers		
73	Preventing exceeding the shift requirement of the amount of trust in the production area. Stacking in stacks no closer than 3 meters from machines		
74	Racks and shelves in tobacco dryers made of non-combustible materials. Metal canopies in fire dryers over the flame pipes to protect them from tobacco ingress		
75	Prevention during cotton harvesting of: 1) smoking and using open fire in a cotton field; 2) leave in the field, refuel the cotton harvesting machine with filled bunker by raw cotton; 3) operate cotton harvesting machines with a defective hydraulic system and electrical equipment; 4) parking cotton harvesting machines on the sites for cotton drying		
76	Preventing parking of tractors, cars, cotton harvesting machines, repair, lubrication and refueling them with fuel at a distance of less than 50 meters from the site for natural drying of raw cotton		
77	Placement of sites for natural drying of raw cotton from residential houses, public buildings, repair shops at a distance of at least 150 meters, and		

	from high-voltage and low-voltage power lines at a distance of at least 1.5 meters of support height		
78	Provision of sites for natural drying of raw cotton with estimated amount of water for outdoor firefighting purposes, but not less than 50 cubic meters		
79	Asphalting or tamping with clay cover with a thickness of at least 5 centimeters the area for natural drying of raw cotton. Preventing cotton drying on the roadway		
80	Prohibition of defective operation of devices that prevent dust emission from process equipment (sealing units, local suction)		
81	Providing elevators with stationary platforms with ladders. Fencing of the platform with a railing at least 0.9 meters high with a continuous lining at the bottom to a height of 0.1 meters		
82	Preventing malfunctioning of the automatic protection of the elevator drive in case of belt breakage as well as preventing the working elements from hitting the elevator box wall.		
83	Equipping the elevator shell with easy-opening hatches with reliable locks and elastic gaskets ensuring tightness (tightness) of the perimeter covering		
84	Preventing operation of conveyors without proper special devices for removal of raw cotton from the lower belt		
	Preventing operation of machines and apparatuses		

85	included in the pneumatic conveying system without proper grounding devices. Prevent mechanized shredding of raw cotton through the fan		
86	Preventing exceeding the number of riots in the group more than two riots, when the size of the site is 65×14 meters, four when the size of the site is 25×14 meters for one riot or six when the size of the site is 25×11 meters for one riot. Execution of the height of the riot not more than 8 meters		
87	Preventing reducing fire separation gaps between bunts in a group to less than 15 meters and between groups of bunts to less than 30 meters		
88	Installation of heat generating units used for drying raw cotton in insulated rooms made of non-combustible structures		
89	Implementation of cotton fiber storage in bales		
90	Making a standard stack of cotton not more than 22 meters long, 11 meters wide and 8 meters high when storing bales of cotton fiber in stacks in open areas		
91	Availability of high-pressure fire-fighting water supply at cotton mills and cotton stations when storing raw cotton more than 2400 tons		
92	The presence of two or more independent gates in the stable's premises, in front of which it is forbidden to build thresholds, steps, or wards. Closing gates with easy-to-open locks		

93	Availability of devices in the stables that allow simultaneous release and removal of horses from the stalls in case of fire		
94	Laying electric wires in stables openly, on insulators, cables, in steel pipes or cables. Installation of switchboards, switches, fuses in the vestibules or on the outer walls of the stables in cabinets made of non-combustible materials		
95	Availability of an animal evacuation plan in case of fire to evacuate horses from stables		
96	Prevention in the operation of electrical networks in stables of: 1) placing electrical wiring above the animal housing; 2) storing hay and straw under the electrical wiring; 3) laying electric wires and cables in transit through the premises of stables; 4) use of lamps with power exceeding the maximum permissible		
97	Preventing construction of workshops, warehouses, parking lots, as well as works not related to the service of animals		
98	Prohibiting the entry of vehicles with internal combustion engines whose exhaust pipes are not equipped with spark arrestors		
99	Preventing installation of springs and automatic closing blocks on the gate		
100	Preventing the use of kerosene lamps, candles and defective electric lanterns for lighting the premises		

101	Avoidance of temporary furnaces		
102	Preventing storage of hay, forage, bedding in vestibules and aisles, in the attics of the stables		
103	Prohibition of smoking and use of open flames in the stables premises		
104	Storage of coarse fodder stock only in annexes (outbuildings), separated from farm buildings by blank non-combustible walls (partitions) and ceilings with fire resistance limit not less than EI-45. Equipment of annexes (extensions) with exits only directly outside		
105	Fencing of the hayloft with an earthen berm and wire fence. Placement of the weighing room outside the hayloft		
106	Location of haystacks (stack), sheds and piles of rough fodder at a distance of at least 15 meters to power lines, at least 20 meters to roads and at least 50 meters to buildings and structures		
107	Provision of distances from the fence of hay storages to nearby forest areas not less than 20 meters and perimeter plastering with a strip not less than 4 meters wide		
108	Location of roughage warehouses on the territory of the production and economic complex on a specially allocated site		
109	Availability of plastering of the site for stacks (stacks), as well as a pair of stacks (stacks) or stacks along the perimeter by a strip not less than 4 meters wide. Ensuring that the distance		

	from the edge of the strip to a stack (stack) located on the site is at least 15 meters, and to a free-standing stack (stack) - at least 5 meters		
110	Preventing exceeding the area of the base of one stack (stack) more than 150 square meters, and stacks of baled hay (straw) - 500 square meters		
111	Provide fire breaks between individual stacks, sheds and stacks (stacks) not less than 20 meters, between stacks and sheds when stacks, sheds and stacks (stacks) are placed in pairs not less than 6 meters, and between their pairs - not less than 30 meters. Provision of minimum fire safety separation distance between blocks (20 stacks or stacks may be placed in a block) not less than 100 meters		
112	Stacking of hay with high humidity into conical stacks (heaps) with gaps between them of at least 20 meters		
113	Availability of water reserve in case of fire at least 50 meters cubic meters in rough fodder warehouses		
114	Location of grain warehouses in detached buildings		
115	Ensuring the distance from the top of the embankment to combustible cover structures, as well as to lighting fixtures and electrical wires of at least 0.5 meters when storing grain in bulk. Availability of fire retarding devices in places		

	of grain transportation through openings in fire barriers		
116	Preventing storage of materials and equipment together with grain		
117	Preventing the use of grain cleaning and other machines with internal combustion engines inside storage facilities		
118	Preventing work on mobile machinery when the gates on both sides of the warehouse are closed		
119	Preventing ignition of solid fuel-fired dryers with flammable and combustible liquids, and of liquid fuel-fired dryers with flares		
120	Preventing work on dryers with or without defective temperature control devices and automatic fuel shut-off devices in case of flame extinction in the furnace, electric ignition system		
121	Preventing grain filling above the level of the conveyor belt and allowing the belt to rub against the conveyor structure		
122	Installation of a mobile drying unit at a distance of at least 10 meters from the grain storage building		
123	Installation of fans at a distance of at least 2.5 meters from combustible walls when ventilating grain in grain warehouses. Execution of ducts from non-combustible materials		
124	Preventing the use of machines and equipment with internal combustion engines inside production and storage facilities		
125	Use of standardized wooden breadboards for		

	separating individual batches of grain		
126	The width of at least 0.7 meters when there are aisles between built-in bins and warehouse walls		
127	Preventing the use of electric heaters with open heating elements in all buildings and premises, and of the use of all types of electric heaters in explosion-hazardous premises		
128	Arrangement at bakery and pasta enterprises when storing bags of flour aisles and passages with a width not less than: 1) a passage between the stacks, not less than in 12 meters - 0.8 meters; 2) distance from the stacks to the walls - 0.7 meters; 3) passages for electric forklifts - 3.0 meters; 4) passages for carts with a lifting platform - 2.0 meters		
129	Arrangement of aisles inside the warehouse for storage of products in containers of other enterprises of the bakery products industry: 1) a longitudinal aisle in the center of the warehouse with a width that ensures the operation of mechanisms, but not less than 1.25 meters; 2) two transverse aisles - against the warehouse gate, through, with the width not less than the width of the gate; 3) between the stacks and the warehouse walls - at least 0.7 meters wide		
130	Use of heating devices with smooth surfaces and at a height that allows their		

	systematic cleaning from dust		
131	Ensuring free access to heating devices		

Official (s)

position signature

surname, name, patronymic (if any)
Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 19
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist

in the sphere of state control and supervision in the field of fire safety in respect of energy facilities (energy generating and energy transmitting facilities)

Footnote. Appendix 19 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

The state body that assigned the inspection/preventive control with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object) of control and supervision

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number

of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
1	Ensuring cleaning of electrical equipment of closed switchgears according to the schedule approved by the technical manager with mandatory implementation of organizational and technical measures		
2	Making floors in chemistry labs from methlah tile, linoleum and materials depending on process requirements and chemicals handled		
3	Coating of work tables and fume cupboards intended for work with heated or explosion- or fire-hazardous substances with fully non-combustible material, and those intended for work with acids and alkalis with anticorrosive material and edges to prevent spillage of liquid substances		
4	Keeping clean rooms for preparation and pumping of oil products (fuel oil pump, oil pump, oil regeneration)		
5	Regular inspection of the technical condition of permanently installed automatic gas analyzers, as well as sound and light signaling devices on the presence of hazardous concentration of vapors in the air in production facilities, with entering the results of the inspection in the operational logbook		
	Equipment on open switchgears of grounding points of fire fighting		

6	equipment installation with marking of the location (in accordance with the operational plan of firefighting)		
7	Installation of oil cleaning equipment on non-combustible bases		
8	Loading of petroleum products into tank trucks, tanks on specially equipped sites with hard surface. Availability of organized drainage (for removal of spilled liquids) at the site through a water trap into a special collection tank, which is periodically cleaned		
9	Availability of safety signs and a signboard with basic fire safety requirements for loading oil products into tank trucks at the loading site		
10	Availability of a rope or boom for tank truck towing at the loading rack		
11	Availability of schemes and local instructions for equipment operation in the gas supply rooms of gas regulator units, which set out specific fire safety requirements		
12	Location of rooms with control and measuring instruments and control devices separately from gas regulator stations, gas regulator units and separation by a gas-tight wall, in which no through holes and gaps are allowed. Allow the passage of communications through the wall only with the use of special devices (sealing glands)		
13	Version with distinctive coloring of gas pipelines laid openly		

14	Preventing the use of existing gas pipelines for the suspension (support) of devices and scaffolding decking		
15	Cleaning of solid fuel (coal , oil shale, peat) storage site from vegetative debris and materials		
16	Prevent the laying of coal, peat and oil shale on the ground containing organic substances and pyrites		
17	Availability of a special area at the storage site for extinguishing spontaneously ignited fuel and its cooling down after removal from the stack		
18	To perform routine work with the stacks, as well as the passage of mechanisms and fire engines, the distance from the bottom of the stacks to the fence and the foundation of crane tracks shall be at least 3 meters, and to the outer edge of the rail head or the edge of the road - at least 2 meters. Preventing solid fuel backfilling of passages and blocking them with equipment		
19	Ensuring at fuel transfer units the operation of aspiration or dust suppression units using finely atomized water, air-mechanical foam or water-vapor mixture		
20	Operability of dedusting means located in the fuel supply line, as well as of devices for metal, chips and foreign inclusions removal from fuel during fuel supply		
	Keeping the fuel supply path premises clean, regular cleaning with dust		

21	removal from all dust accumulation areas. Availability of an approved cleaning schedule depending on the type of solid fuel, its tendency to oxidation and dustiness of premises		
22	Installation of heating devices, along the fuel supply path, making them with smooth surfaces, easily accessible for cleaning		
23	Making the electrical equipment installed along the fuel supply path in dust-proof version and meeting the requirements of dust hydro-removal		
24	Provision of gaps between cables on cable routes running along the fuel supply path to reduce dust accumulation		
25	Use of dust-proof luminaires in rooms, conveyor galleries and crude fuel bunkers		
26	Maintenance of the transition bridges over conveyors in the galleries of the fuel supply line in good condition		
27	Preventing smoking in the production premises of the fuel supply line: 1) smoking outside the specially designated places; 2) use of electric heating devices for heating; 3) use of open incandescent lamps; 4) supplying fuel with burning (smoldering) centers to conveyors and dumping it into hoppers; 5) accumulation of fuel under the lower strings of conveyor belts;		

	<p>6) stopping of conveyors loaded with fuel, except for emergency cases;</p> <p>7) storage, especially on conveyor galleries, of dismantled equipment, conveyor belts and other combustible materials</p>		
28	<p>Operation of dust preparation facilities, which include mills, separators, and cyclones</p>		
29	<p>Preventing laying of new cable routes opposite the throats of dust system safety devices at a distance closer than 10 meters</p> <p>Availability of protection of existing cable routes, passing at the specified distance, by metal covers (boxes) at least 5 meters long, or by baffle boards at safety valves</p>		
30	<p>Application of non-combustible thermal insulation on fuel oil pipelines.</p> <p>Carrying out periodic, but not less than once a half year, visual inspection of the state of thermal insulation of pipelines, equipment and bunkers. Marking of detected violations in the log of defects and malfunctions with equipment</p>		
31	<p>Preventing tightness failures of oil supply, regulation, gas supply systems, as well as flange and socket joints on liquid fuel pipelines of gas turbine units during operation of power plants</p>		
32	<p>Preventing oil spillage on hot surfaces, in basements and on cable routes during unit operation</p>		
	<p>Storage of oily rags and rags in special metal</p>		

33	lockable boxes with a capacity of not more than 0.5 cubic meters with the inscription "For rags", which are installed at the main service marks		
34	Availability of the inscription "Emergency oil drain" on the shut-off device (gate valve) of the emergency oil drain from the oil tank of power plants , painting of the manual drive in red color		
35	Preventing installation of gas cylinders at generator (synchronous compensator) gas posts to fill their casings with hydrogen or inert gas, except for accidents with centralized systems of supply of these gases or their repairs		
36	Preventing carrying out flammable works (welding, grinding, soldering) directly on the housings of units, apparatus and gas pipelines filled with hydrogen		
37	Availability of safety signs "Do not use open fire", " No smoking", "Caution! Danger of explosion", and on visible areas of the lube gas oil system with hydrogen cooling - a warning sign: "Caution! Flammable substances", unless flame retardant oils are used. On gas turbine housings, the safety sign " Caution! Danger of explosion"		
38	Maintenance personnel of power generating organizations shall undergo on-the-job training, as well as check their knowledge of safety and equipment operation prior to assignment to independent work		

39	<p>Implementation of fire protection measures in places of contact between combustible building structures of the power plant building and exhaust pipes:</p> <ol style="list-style-type: none"> 1) availability in the attic room and walls around the passing exhaust pipe, regardless of the presence of thermal insulation, of a non-combustible partition at a distance of at least 0.5 meters from the wall of the exhaust pipe. Treatment of wooden structures at a distance of up to 1 meter from the pipe with fire retardant compositions; 2) in the roof around the outlet exhaust pipe, making a partition of non-combustible materials at least 0.5 meters wide from the pipe; 3) the height of the exhaust pipe is not less than 2 meters above the roof; 4) the end of the exhaust pipe should be inserted into a concrete or brick muffler (pit) located outside the building when it is horizontal 		
40	Preventing the storage of empty oil product drums in the premises		
41	Preventing the arrangement of storerooms, auxiliary constructions not related to the switchgear, as well as storage of electrical equipment, materials, spare parts, containers with flammable liquids and cylinders with various gases in the rooms and corridors of closed switchgears		
	Regular inspection of cable facilities according to the		

42	<p>schedule approved by the shop manager.</p> <p>Fixing the inspection results and identified defects in the operational log and log (or card index) of defects and malfunctions with equipment</p>		
43	Preventing arrangement of storerooms, workshops, as well as storage of materials and equipment, including unused cable products in closed switchgear premises		
44	Availability of signs of the nearest exit at least 50 meters apart in cable constructions		
45	Making the doors of sectional partitions of cable constructions self-closing, open towards the nearest exit and have a tight seal		
46	Preventing storage of combustible materials not related to the installation in the oil-filled cable feeder rooms		
47	Making toe boards of oil intake devices along the entire perimeter of the gravel backfill without gaps with a height of at least 150 millimeters above the ground		
48	Preventing the use (adaptation) of cable duct walls as a sidewall enclosure of oil receivers of transformers and oil reactors		
49	Preventing the commissioning of transformers and oil reactors at power plants and substations, if the fire extinguishing units provided for by the project are not fully operational		
50	Availability of inscriptions on the doors of the battery rooms, as well as the		

	necessary prohibitive and prescriptive safety signs		
51	Making the glass frosted or coated with white adhesive paint resistant to aggressive environment in natural light of the battery room		
52	Preventing smoking directly in the battery rooms, storing acid and alkali in quantities exceeding the single-shift demand, leaving overalls, foreign objects and combustible materials behind		
53	Provision of free access to warehouse buildings on the territory of energy enterprises. Provision of gaps of at least 5 meters between stacks of materials and equipment of open warehouses and passages for fire engines		
54	Preventing on the territory of the warehouse: 1) cluttering the passages between buildings, stacks of materials and equipment , as well as placing them near buildings, even for a short period of time; 2) burning of packaging, tare and other wastes; 3) storage of cargo and loading mechanisms on unloading areas of warehouses		
55	Compliance at warehouses with the requirements for: 1) storage of flammable and combustible liquids separately from other materials; 2) separate storage of varnishes, paints and solvents; 3) separate storage of gas cylinders and poisonous substances.		

	<p>Grouping of various materials and equipment for storage and storage on the basis of homogeneity of their combustibility (combustible, difficult to burn) and the use of fire extinguishing agents (water, foam)</p>		
56	<p>Availability in storage facilities located in the basement or ground floor, at least two exits or one exit and a window to ensure the evacuation of people directly to the first floor, as well as for the entry of fire extinguishing equipment</p>		
57	<p>Preventing in storage areas:</p> <ol style="list-style-type: none"> 1) smoking and use of open fire; 2) storage of various materials and equipment at a distance of less than 1 meter from heating devices ; 3) laying of transit communications (cables, gas, steam, water pipelines) ; 4) storing, even temporarily, various materials in the aisles between racks, stacks, as well as between racks, stacks and the warehouse wall 		
58	<p>Placement of the disconnecting device for voltage removal (automatic circuit breaker, switch) outside the warehouse premises on a non-combustible wall, and for combustible and hard-to-burn warehouse buildings - on a freestanding support</p>		
	<p>Ensuring storage of varnishes, paints, oil varnishes, solvents (subject to the principle of product</p>		

59	homogeneity) in metal drums, cans, containers with tightly closed lids in separate rooms or compartments of the warehouse (boxes)		
60	Storage of metal powders capable of spontaneous combustion (aluminum powder, magnesium powder) in metal cans with tightly closed lids in dry rooms		
61	Preventing storage of nitro lacquers, nitro paints and solvents in basements		
62	Storage and dispensing of varnishes and paints in a separate room equipped with electric lighting and ventilation in explosion-proof version. Use of special hand pumps, measuring devices or means of small mechanization for pouring (packing) of varnishes, paints and solvents		
63	Preventing operation of warehouses with paint rooms with faulty supply and exhaust ventilation		
64	Carrying out operation, storage and transportation of cylinders at the enterprise according to the instructions approved by the chief engineer of the enterprise. Storage of cylinders in open areas under canopies to protect them from precipitation and sunlight. Fencing of open areas		
65	Preventing storage of materials and equipment in cylinder storage areas, as well as co-location of gas cylinders in common storage areas		
	Preventing the use of combustible materials for		

66	flooring of cylinder storages		
67	Storing filled cylinders in an upright position, for which purpose open and closed warehouses shall be equipped with "nests" or barriers to prevent cylinders from falling. Storing filled and empty cylinders separately		
68	Preventing installation of bituminous boilers, making fires and storage of combustible materials within a radius of 50 meters around the storage areas with cylinders		

Official (s)

position signature

surname, name, patronymic (if any)

Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 20
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist

in the sphere of state control and supervision in the field of fire safety in respect of facilities of the Armed Forces, other troops and military formations, law enforcement agencies

Footnote. Appendix 20 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

The state body that assigned the inspection/preventive control

with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object) of control and supervision

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
1	Availability in the military unit of a fire protection plan, approved by the commander		
2	Availability at the duty of a military unit of an extract from the plan, including fire safety requirements in a military unit, calculation of forces and means involved in extinguishing a fire, the procedure for evacuating personnel, weapons, military and other equipment, property and other real assets		
3	Presence of a non-staff fire department of five to fifteen persons in a military unit that does not have a staff fire department		
4	Carrying out continuous cleaning of debris and dry grass of the territory of a military unit and outer perimeter at a distance of fifty meters		
	Prevention of building up fires closer than fifty meters from buildings, sites with property, military and other equipment, as well as		

5	smoking and using devices with open flames in parks, storage facilities, hangars and similar premises, leaving lights on when leaving the premises		
6	Preventing the repair of equipment and networks of electricity, gas supply and central (autonomous) heating by persons without special training and authorization to perform these works		
7	Preventing the arrangement in the basement of buildings of workshops and warehouses associated with the handling or storage of flammable combustible liquids and combustible materials		
8	Storage of fire extinguishing equipment in warehouses, parks, hangars and production facilities on boards		
9	Availability at telephone sets of inscriptions with indication of phone number of the nearest fire station, and on the territory of military unit of sound alarm means for giving a fire alarm signal		
10	Preventing fueling of machines at parking lots and storage of machines (aircraft) with leaking fuel tanks, fuel lines		
11	Preventing storage of lubricants, empty containers and fuel in machine parking areas		
12	Preventing storage of foreign objects, oily rags, covers, special clothing in machines		
13	Preventing storage of fuel tanks together with other equipment in park storages and hangars		

14	Preventing welding operations in parking areas		
15	Preventing blocking of gates in the premises for parking and storage of vehicles, arrangement of storerooms, workshops and accommodation in these premises		
16	Daily availability of on-duty tractors with special towing devices (devices) and the required number of servicemen to ensure immediate withdrawal of vehicles (aircraft) in case of fire		
17	Timely cutting and cleaning of grass on the territory of warehouses (storage facilities). Preventing dry grass drying and burning on the territory of warehouses (storage facilities)		
18	Storage in warehouses (storage facilities) of only those types of property for which they are designed		
19	Preventing cluttering of aisles and exits in warehouses (storage facilities), as well as upholstering of shelves and darkening of windows with paper, cardboard, plastic film and fabrics not treated with fire retardant		
20	Conducting property stacking in such a way that aisles and exits are kept clear. Preventing stacking close to furnaces, radiators, electrical wiring and lamps		
21	Preventing warehousing of building materials, fuel supplies or any property near warehouses (storages). Arrangement of furnaces and bore holes of furnaces		

outside warehouses (storages), provision of pipes with spark arrestors	
--	--

Official (s)

position signature

surname, name, patronymic (if any)
Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 21
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist

in the sphere of state control and supervision in the field of fire safety in respect of non-state firefighting service facilities

Footnote. Appendix 21 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

The state body that assigned the inspection/preventive control with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object) of control and supervision

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
1	Availability of a certificate for the right to carry out works on prevention and extinguishing fires, ensuring fire safety and conducting rescue operations on the objects at the non-state fire-fighting service		
2	Employment in non-state fire service of citizens of the Republic of Kazakhstan who have reached eighteen years of age and have passed training courses on special training in specialized training centers in the field of fire safety for training, retraining and advanced training of specialists of non-state fire services		
3	Availability of documentation regulating the activities of non-state fire service		
4	Maintenance of non-state fire service in constant (round-the-clock) readiness		
5	Availability in the fire departments of non-state fire-fighting service of fire team on a fire truck, headed by the commander of the fire team		
6	Availability of the guard, headed by the head of the guard (shift supervisor) in the presence of two or more fire trucks in the non-state fire service		
7	Availability of a fire prevention team with instructors in fire departments with mobile equipment		
	Availability of fire instructors (at least 2		

8	full-time employees on duty) for the protection of objects on which a non-state fire service without mobile equipment is established		
9	Availability a communication center in fire departments and stations of non-state fire service		
10	Providing firefighting vehicles with mobile radio stations, the head of the fire extinguishing, workers performing the duty and due to working conditions being outside the places of permanent deployment of fire department or office with portable communications devices		
11	Availability of gas and smoke protection service, created by the decision of the facility manager		
12	Availability of a required number of main fire trucks for non-state fire service		
13	Availability of portable or mobile fire engine pumps in case of repair and / or technical maintenance of the main fire vehicles required to extinguish fires at the sites		
14	Availability of an appropriate number of special fire trucks for non-state fire-fighting service, defined by the object manager, taking into account their specificity		
15	Placement and operation of fire trucks in accordance with the safety requirements of fire equipment for the protection of objects		
	Availability of an appropriate number of employees of non-state		

16	fire-fighting service at the object on duty, according to the number of fire trucks , multiplied by the number of fire teams on a fire truck		
17	Implementation in non-state fire-fighting service of annual special training of employees, including theoretical and practical classes, taking into account the production characteristics of the object		

Official (s)

position signature

surname, name, patronymic (if any)
Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 22
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist in the sphere of state control and supervision in the field of fire safety in respect of rotation shift facilities

Footnote. Appendix 22 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

The state body that assigned the inspection/preventive control with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object) of control and supervision

№, date)

Name of the subject (object) of control and supervision _____

(Individual identification number), business identification number
of the subject (object) of control and supervision

Registered address _____

Item №	List of requirements	Compliant	Non-compliant
1	Provision of a mineralized strip at least 4 meters wide around the perimeter of the rotational facility territory during the spring-summer fire hazardous period		
2	Parking of vehicles and equipment at a distance of at least 15 meters from block-containers, structures, places of open storage of materials and equipment		
3	Preventing the location of fueling equipment parking at a distance of less than 50 meters from block containers, structures, places of open storage of materials and equipment, parking lots of motor transport vehicles		
4	Availability at the entrance to the rotational facility of a scheme indicating: 1) locations of buildings, block-containers, structures, vehicles, machinery, storage of materials and equipment; 2) organization of motor transport vehicles movement; 3) locations of primary fire extinguishing means; 4) locations of the nearest fire-fighting water sources		
5	Grounding of buildings, structures, enclosures of		

	electrical equipment control panels, block-containers		
6	Preventing the use of open fire in premises, structures, block-containers		
7	Provision of protective equipment for each person individually in the premises of shift facilities. Availability of instructions on fire safety measures in the premises of the shift facility in a visible place		
8	Familiarization of persons residing on the territory of rotational facilities with the instruction on fire safety measures against signature or during fire safety briefing at the workplace		
9	The length of the evacuation exit from the most remote point to the location of a person is not more than 20 meters when assembling block-containers, prefabricated modular complexes		
10	Provision of factory-designed heating with closed-type heating elements in block-containers, prefabricated modular complexes		
11	Preventing leaving cylinders with compressed and (or) liquefied gas, containers with flammable and combustible liquids, drying clothes and linen on the surfaces of heating devices, building fires, and using open flames in open areas on the territory of the rotation facility		

Official (s)

position signature

surname, name, patronymic (if any)
Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 23
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist

in the field of fire safety in respect of legal entities certified for the right to carry out fire prevention

and extinguishing, fire safety and rescue operations in organizations, settlements and facilities

Footnote. Appendix 23 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

State body that assigned the inspection

Act on the assignment of the inspection

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number
of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
Non-state fire department with on-site fire machinery certified under permit requirements in effect up to July 31, 2018			
1.	Availability of at least one fire truck		

Presence of fire-fighting equipment and gear on fire-fighting vehicles:

- 1) suction hose, 4 m long, 125 mm in diameter in quantity of 2 pieces;
- 2) suction hose, 4 m long, 75 mm in diameter in quantity of 2 pcs;
- 3) delivery hose for hydrant operation, 4-5 m long, 77 mm in diameter, in quantity of 2 pcs;
- 4) delivery hose, 20 m long, 77 mm diameter, in the amount of 6 pcs;
- 5) delivery hose, 20 m long, diameter 66 mm in the amount of 10 pieces;
- 6) delivery hose, 20 m long, 51 mm in diameter in quantity of 6 pieces;
- 7) suction hose, 4 m long with a diameter of 30 mm in the amount of 1 piece;
- 8) net for suction hose SV-125, with a rope of 12 m length in quantity of 1 piece;
- 9) branching 3-way PT - 70 (PT - 80) in quantity of 2 pieces;
- 10) water collector hose BC - 125 with plugs in quantity of 1 piece;
- 11) end wrench for opening hydrants in quantity of 1 piece;
- 12) guide rope of the gas smoke protection team, 1 piece;
- 13) 66x51 adapter connecting head in quantity of 2 pieces;
- 14) 77x51 transitional connecting head in quantity of 2 pieces;
- 15) 77x66 adapter connection head in quantity of 2 pieces;
- 16) hose delay in quantity of 4 pieces;

2.

- 17) hose clamps in quantity of 4 pieces;
- 18) fire column in quantity of 1 piece;
- 19) keys for connection of suction hoses K-150 in quantity of 2 pieces;
- 20) keys for connecting delivery hoses K-80 in quantity of 2 pieces;
- 21) 1 key for opening hydrant covers;
- 22) hydro-elevator G-600 in quantity of 1 piece;
- 23) RSK-50 nozzle in quantity of 4 pieces;
- 24) RSA nozzle in quantity of 2 pieces;
- 25) RS-70 nozzle in quantity of 2 pieces;
- 26) SVP-4 air-foam nozzle in quantity of 2 pieces;
- 27) portable master stream nozzle in quantity of 1 piece;
- 28) medium foam generator GPS-600 in quantity of 2 pieces;
- 29) three-rope ladder in quantity of 1 piece;
- 30) Assault ladder in quantity of 1 piece;
- 31) a ladder stick in quantity of 1 piece;
- 32) 2.5 m long metal pole in quantity of 1 piece;
- 33) universal scrap in quantity of 1 piece;
- 34) blacksmith's sledgehammer in quantity of 1 piece;
- 35) carpenter's axe in quantity of 1 piece;
- 36) 1 bayonet shovel;
- 37) wood hacksaw in a wooden case;
- 38) scissors for cutting rebars;
- 39) a set of tools for cutting electrical wires, including: scissors with

	<p>dielectric handle; dielectric gloves; dielectric boots; dielectric mat;</p> <p>40) rescue rope, 30 m long, in a tarpaulin cover;</p> <p>41) heat-reflective suit in quantity of 3 pieces;</p> <p>42) rubber boots in quantity of 4 pairs;</p> <p>43) electric individual flashlight in quantity of 5 pieces;</p> <p>44) electric group flashlight in quantity of 1 piece;</p> <p>45) medical kit in quantity of 1 set;</p> <p>46) fire extinguisher OU-5 or OP-5 in quantity of 1 piece;</p> <p>47) shovel in quantity of 1 piece;</p> <p>48) a set of tools for car maintenance in quantity of 1 set;</p> <p>49) car radio station in quantity of 1 piece;</p> <p>50) portable radio station in quantity of 4 pieces;</p> <p>51) signaling and loudspeaking device in quantity of 1 piece;</p> <p>52) jack from 5 to 10 tons in quantity of 1 piece.</p>		
3.	<p>Availability on the right of ownership or other legal right of a building or premises for accommodation of employees, fire-rescue equipment, equipment and gear</p>		
4.	<p>Availability of staff of at least 16 persons, at the rate of 4 employees including the driver for each main fire truck on duty shift</p>		
	<p>Qualification of employees of non-state firefighting services with field equipment:</p>		

5.

- 1) for the head of the service (detachment) and his deputy, the head of the fire station and his deputy the presence of documents confirming - higher technical education or secondary technical education in the field of fire safety, not less than 3 years of work experience in senior positions of management apparatus or firefighting units of state firefighting authorities;
- 2) for the head of the fire station and his deputy, documents confirming - higher technical education or secondary technical education in the field of fire safety, not less than 1 year of work experience in the positions of management apparatus or firefighting units of the firefighting bodies of the state fire department;
- 3) for the chief of guard (shift supervisor) documents confirming - secondary technical education, not less than 1 year of work experience in positions in firefighting units, special training in a specialized training center in the field of fire safety;
- 4) for the master of the gas smoke protection team - availability of documents confirming - secondary education, completion of special training in a specialized training center in the field of fire safety and having admission to work in compressed air devices;
- 5) for the commander of the department the availability of documents confirming - secondary education, at least 1 year of

work experience in positions in firefighting service units, completion of special training in a specialized training center in the field of fire safety;

6) for a senior firefighter, firefighter, availability of documents confirming - secondary education, completion of special training in a specialized training center in the field of fire safety;

7) for a driver (senior driver) of a fire engine the availability of documents confirming - secondary education, driving license of category "C" with experience of not less than 1 year of driving in this category, passing of special training in a specialized training center in the field of fire safety;

8) for radio-telephonist (dispatcher of the communication point) the availability of documents confirming - secondary education, completion of special training in a specialized training center in the field of fire safety.

6.

Availability of special uniforms and firefighting equipment per non-state firefighting service employee:

1) firefighter's combat clothing;

2) woolen helmet;

3) sweater without a neckline of protective color ;

4) canvas gloves with cuffs ;

5) fur gloves with cuffs;

6) fireman's rescue belt with a carabiner;

7) fire helmet (helmet);

8) fireman's boots;

	<p>9) belt holster for fireman's axe;</p> <p>10) rubber boots.</p>		
<p>Non-state fire department with on-site fire -fighting machinery certified under permit requirements established after July 31, 2018</p>			
7.	<p>Availability of at least two fire trucks owned or acquired through leasing as a lessee, confirmed by vehicle registration certificates</p>		
	<p>Availability of fire-fighting equipment and gear on fire-fighting vehicles:</p> <p>1) suction hose, 4 m long with a diameter of 125 mm in quantity of 2 pieces;</p> <p>2) suction hose, 4 m long, 75 mm diameter in quantity of 2 pieces;</p> <p>3) delivery hose, for hydrant operation, length 4 - 5 m, diameter 77 mm in quantity of 2 pieces;</p> <p>4) delivery hose, length 20 m, diameter 77 mm in quantity of 6 pieces;</p> <p>5) delivery hose, 20 m long, diameter 66 mm in quantity of 10 pieces;</p> <p>6) delivery hose, 20 m long with a diameter of 51 mm in quantity of 6 pieces;</p> <p>7) suction hose, 4 m length with a diameter of 30 mm in quantity of 1 pc;</p> <p>8) net for suction hose SV-125, with a rope 12 m long in quantity of 1 piece;</p> <p>9) branching 3-way PT - 70 (PT - 80) in quantity of 2 pieces;</p> <p>10) water collector hose BC - 125 with plugs in quantity of 1 piece;</p> <p>11) end wrench for opening hydrants in quantity of 1 piece;</p> <p>12) guide rope of the gas smoke protection service in quantity of 1 piece;</p>		

8.

- 13) adapter connecting head 66x51 in quantity of 2 pieces;
- 14) adapter connecting head 77x51 in quantity of 2 pieces;
- 15) connecting transitional head 77x66 in quantity of 2 pieces;
- 16) hose strap in quantity of 4 pieces;
- 17) hose clamps in quantity of 4 pieces;
- 18) fire hydrant in quantity of 1 piece;
- 19) keys for connection of suction hoses K-150 in quantity of 2 pieces;
- 20) keys for connecting pressure hoses K-80 in quantity of 2 pieces;
- 21) key for opening hydrant covers in quantity of 1 piece;
- 22) hydro-elevator G-600 in quantity of 1 piece;
- 23) nozzle RSK-50 in quantity of 4 pieces;
- 24) nozzle RSA in quantity of 2 pieces;
- 25) nozzle RS-70 in quantity of 2 pieces;
- 26) air-foam nozzle SVP-4 in quantity of 2 pieces;
- 27) portable master stream nozzle in quantity of 1 piece;
- 28) medium foam generator GPS-600 in quantity of 2 pieces;
- 29) a ladder with three knees in quantity of 1 piece ;
- 30) assault ladder in quantity of 1 piece;
- 31) ladder stick in quantity of 1 piece;
- 32) 2.5 m long metal pole in quantity of 1 piece;
- 33) universal crowbar in quantity of 1 piece;

- 34) blacksmith's sledgehammer in quantity of 1 piece;
- 35) carpenter's axe in quantity of 1 piece;
- 36) bayonet shovel in quantity of 1 piece;
- 37) wood hacksaw in a wooden case;
- 38) scissors for cutting rebar;
- 39) a set of tools for cutting electric wires, including: scissors with dielectric handle; dielectric gloves; dielectric boots; dielectric mat;
- 40) rescue rope, 30 m long, in a tarpaulin cover;
- 41) heat-reflective suit in quantity of 3 pieces;
- 42) rubber boots in quantity of 4 pairs;
- 43) electric individual flashlight in quantity of 5 pieces;
- 44) electric group flashlight in quantity of 1 piece;
- 45) medical kit in quantity of 1 set;
- 46) fire extinguisher OU-5 or OP-5 in quantity of 1 piece;
- 47) shovel in quantity of 1 piece;
- 48) a set of tools for vehicle maintenance in quantity of 1 set;
- 49) car radio in quantity of 1 piece;
- 50) portable radio station in quantity of 4 pieces;
- 51) signaling and loudspeaking device in quantity of 1 piece;
- 52) jack from 5 to 10 tons in quantity of 1 unit.

Availability on the right of ownership or other legal right of a building or premises for

9.	accommodation of employees, fire-rescue equipment, equipment and gear		
10.	Availability of staff of at least 17 persons, at the rate of 1 chief of subdivision, 4 employees including the driver for each main fire truck on duty shift		
	<p>Qualification of employees of non-state firefighting services with field equipment:</p> <p>1) for the head of the service (detachment) and his deputy, the head of the fire department and his deputy the availability of documents confirming - higher technical education or secondary technical education in the field of fire safety, at least 3 years of work experience in senior positions in the management apparatus or firefighting units of the state firefighting service authorities;</p> <p>2) for the head of the fire station and his deputy the availability of documents confirming - higher technical education or secondary technical education in the field of fire safety, not less than 1 year of work experience in the positions of management apparatus or units of the fire department ;</p> <p>3) for the chief of guard (shift supervisor) documents confirming - secondary technical education, not less than 1 year of work experience in positions in the fire department units, special training in a specialized training center in the field of fire safety.;</p>		

11.

4) for the master of the gas smoke protection team - documents confirming - secondary education, completion of special training in a specialized training center in the field of fire safety and having admission to work in compressed air apparatus;

5) for the commander of the department, availability of documents confirming - secondary education, at least 1 year of work experience in positions in fire department units, passing special training in a specialized training center in the field of fire safety;

6) for a senior firefighter, firefighter, availability of documents confirming - secondary education, completion of special training in a specialized training center in the field of fire safety;

7) for the driver (senior driver) of a fire engine the availability of documents confirming - secondary education, driving license of category "C" with experience of not less than 1 year of driving a car in this category, passing special training in a specialized training center in the field of fire safety;

8) for radio telephonist (dispatcher of communication point) availability of documents confirming - secondary education, completion of special training in a specialized training center in the field of fire safety.

Availability of special uniforms and firefighting equipment per non-state firefighting service employee:

12.	1) firefighter's combat clothing; 2) woolen helmet; 3) sweater without a neckline of protective color ; 4) canvas gloves with cuffs ; 5) fur gloves with cuffs; 6) fireman's rescue belt with a carabiner; 7) fire helmet (helmet); 8) fireman's boots; 9) belt holster for fireman's axe; 10) rubber boots.		
-----	---	--	--

Non-state fire department without on-site fire machinery certified under permit requirements in effect up to July 31, 2018

13.	Availability of staff of at least 8 persons, at the rate of 2 employees per duty shift		
-----	--	--	--

14.	Qualification of employees of non-state fire prevention services without field equipment: 1) for a senior fire prevention instructor, availability of documents confirming - secondary technical education, at least 1 year of work experience in positions in fire prevention service units, completion of special training in a specialized training center in the field of fire safety; 2) for fire prevention instructor, documents confirming - secondary education, completion of special training in a specialized training center in the field of fire safety		
-----	---	--	--

Non-state fire department without on-site fire machinery certified under permit requirements established after July 31, 2018

15.	Availability of staff of at least 9 persons, at the rate of 1 head of post and 2 employees on duty shift		
-----	--	--	--

16.	<p>Qualification of employees of non-state fire prevention services without field equipment:</p> <p>1) for a senior fire prevention instructor, availability of documents confirming - secondary technical education, at least 1 year of work experience in positions in fire prevention service units, completion of special training in a specialized training center in the field of fire safety;</p> <p>2) for fire prevention instructor, documents confirming - secondary education, completion of special training in a specialized training center in the field of fire safety.</p>		
-----	---	--	--

Official (s)

position signature

surname, name, patronymic (if any)
 Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 24
 to the joint order
 of the Minister of Internal Affairs
 of the Republic of Kazakhstan
 dated October 30, 2018 №758
 and the Minister of National Economy
 of the Republic of Kazakhstan
 dated October 30, 2018 №31

Checklist in the field of fire safety in relation to accredited expert organizations for auditing in the field of fire safety

Footnote. Appendix 24 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of

National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

State body that assigned the inspection

Act on the assignment of the inspection

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number
of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
1	Availability of at least three specialists who meet one of the following conditions: Availability of documents confirming higher education in the specialty of fire safety; Availability of documents confirming higher education and work experience in state and (or) non-state firefighting services for at least five years		
2	Availability of labor contracts on employment of specialists		
3	Availability of premises belonging to the expert organization on the right of ownership or other legal basis		

Official (s)

position signature

surname, name, patronymic (if any)

Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 25
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist

**in the sphere of state control in the field of civil defense in respect of organizations
classified in the categories of civil defense with the largest working shift**

Footnote. Appendix 25 as amended by the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023); Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication).

The state body that assigned the inspection/preventive control
with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object)
of control and supervision

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number
of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
	Availability of a legal act on the establishment of a structural unit or individual		

1.	employees for the organization and conduct of civil defense		
2.	Availability of a civil defense plan approved by the head of civil defense		
3.	Availability of an action plan for liquidation of facility emergencies and their consequences		
4.	Compliance with the structure and content of the civil defense plan and emergency response plan		
5.	Availability of a legal act on the establishment of an evacuation commission		
6.	Availability of a legal act on approval of the composition and regulations of the evacuation (evacuation and reception) commission		
7.	Availability of civil defence protective structures, maintaining them in readiness for operation		
8.	Availability of a passport of the shelter (radiation shelter)		
9.	Availability of a log of inspection of a civil defense protective structure		
10.	Availability of a log of microclimate indicator and gas composition of the air in the shelter (anti-radiation shelter)		
11.	Availability of a plan for a civil defense protective structure		
12.	Availability of a plan to make the civil defense protective structure ready for use		
13.	Availability of a list of equipment, tools and property of the civil defense protective structure		

14.	Availability in the protective structure of a list of telephone numbers of management bodies		
15.	Availability of a list of the personnel of the protective structure maintenance team		
16.	Availability of an operational diagram of the life support systems of the protective structure (ventilation, water supply and sewerage, power supply of the protective equipment)		
17.	Availability of instructions for maintenance of the diesel power plant, filter-ventilation equipment (if any) of the protective structure		
18.	Availability, maintenance of the diesel power plant of the protective structure in good condition		
19.	Availability, maintenance of emergency lighting of the protective structure in good condition		
20.	Availability, maintenance of filter-ventilation equipment of the protective structure in good condition		
21.	Availability, maintenance in good condition of water supply to the protective structure		
22.	Availability and maintenance of the sewage system of the protective structure in good condition		
23.	Availability, maintenance in good condition of power supply and disconnecting devices (switches, cocks, gate valves) of the protective structure		
24.	Availability, maintenance in serviceable condition of protective and hermetic doors, valves and		

	anti-explosion devices of the protective structure		
25.	Availability in conspicuous places of civil defense notification signals, rules for the use of personal protective equipment, signs of entrances and exits, diesel power plant and filter-ventilation rooms, locations of sanitary units, water distribution points, and sanitary posts of the protective structure.		
26.	Availability of lighting and marking of places of installation of fire-fighting equipment of the protective structure		
27.	Availability of storage facilities for civil defense equipment		
28.	Availability of the required quantity and maintenance of civil defence property in readiness		
29.	Availability of a legal act of the organization on creation of civil defense object formations		
30.	Availability and compliance of the civil defence readiness plan		
31.	Availability of logistical support for civil defence units		
32.	Availability of respiratory protection equipment for each member of civil defense formations		
33.	Availability of certificates of training in the territorial subdivisions of the authorized body for persons who organize and conduct civil defense activities		
34.	Availability of required, serviceable warning system		
	Availability of a set of means for conducting civil		

35.	defense classes and a civil defense corner		
36.	Availability of a multidisciplinary office or one civil defense corner in each administrative and production building		
37.	Availability of a list of training groups, class leaders and a schedule of training sessions approved by the head of the organization		
38.	Availability of a logbook of conducted training in the field of civil defense		
39.	Availability of certificates on civil defense training of the organization's employees		
40.	Availability of information submitted to the territorial subdivisions of the authorized body in the field of civil defense on holding exercises and drills in the field of civil defense with copies of organizational documents attached		
41.	Readiness of the main civil defense formations, including those that are part of the emergency response squad and formations that ensure the conduct of rescue and emergency work		
42.	Availability of a cadastral passport for the real estate object		
43.	Availability of main and auxiliary rooms in shelters and radiation shelters		
44.	Availability of natural ventilation with mechanical inducement in anti-radiation shelters		
	Availability of interior finishing of premises of civil defence protective structures made of		

45.	non-combustible or hardly combustible materials, painting of walls, ceilings, partitions mainly in light colors, without plastering		
-----	---	--	--

Official (s)

position signature

surname, name, patronymic (if any)

Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 26
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist

**in the sphere of state control in the field of civil defense
in relation to organizations classified as civil defense organizations**

Footnote. The joint order was added with Appendix 26 in accordance with the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023); Minister of Emergency Situations of the Republic of Kazakhstan dated 25.2024 No. 244 and acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication).

The state body that assigned the inspection/preventive control
with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object)
of control and supervision

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number
of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
1.	Availability of a legal act on the creation of a structural unit or individual employees for the organization and conduct of civil defense		
2.	Availability of a civil defense plan approved by the head of civil defense		
3.	Availability of an action plan for liquidation of emergency situations of object character and their consequences		
4.	Compliance with the structure and content of the civil defense plan and emergency response plan		
5.	Availability of a legal act on the establishment of an evacuation commission		
6.	Availability of a legal act on approval of the composition and regulations of the evacuation (evacuation and reception) commission		
7.	Availability of a passport of a shelter (anti-radiation shelter)		
8.	Availability of a register of inspection of the civil defense protective shelter		
9.	Availability of a register of microclimate and gas composition of the air in the protective shelter (anti-radiation shelter)		

10.	Availability of a plan of the civil defense protective shelter		
11.	Availability of a plan for bringing the civil defense protective shelter ready for use		
12.	Availability of a list of equipment, tools and property of the civil defense protective shelter		
13.	Availability of the list of telephone numbers of the control bodies in the protective shelter		
14.	Availability of the list of personnel of the protective shelter maintenance team		
15.	Availability of the operational scheme of the life support systems of the protective shelter (ventilation, water supply and sewerage, power supply of the protective equipment)		
16.	Availability of maintenance manual for diesel power station, filter-ventilation equipment (if any) of the protective shelter		
17.	Availability, maintenance of the diesel power plant of the protective shelter		
18.	Presence, maintenance of emergency lighting of the protective shelter		
19.	Availability, maintenance in good condition of filter-ventilation equipment of the protective shelter		
20.	Availability, maintenance in good condition of water supply of the protective shelter		
21.	Availability, maintenance in good condition of the sewerage system of the protective shelter		

22.	Availability, maintenance in good condition of electricity supply and disconnecting devices (switches, cocks, gate valves) of the protective shelter		
23.	Availability, maintenance in good condition of protective and hermetic doors, valves and anti-explosion devices of the protective shelter		
24.	Availability in conspicuous places of civil defense notification signals, rules for use of personal protective equipment, signs of entrances and exits, premises of the diesel power plant and filter-ventilation rooms, locations of sanitary units, water distribution points, sanitary points of the protective shelter		
25.	Availability of lighting and marking of installation of fire-fighting means of the protective shelters		
26.	Availability of warehouse facilities for storage of civil defense equipment		
27.	Availability of the required quantity and maintenance of civil defence property in readiness		
28.	Availability of a legal act of the organization on creation of facility-based civil defense formations		
29.	Availability and compliance of the civil defence readiness plan		
30.	Availability of logistical support for civil defence units		
31.	Availability of respiratory protection equipment for		

	each member of the civil defense formation		
32.	Availability of certificates of training in the territorial subdivisions of the authorized body of persons who organize and conduct civil defense activities		
33.	Availability of required, serviceable warning system		
34.	Availability of a set of means for conducting civil defense classes and a civil defense corner		
35.	Availability of a multi-purpose room or one civil defense corner in each administrative and production building		
36.	Availability of a list of training groups, training leaders and training schedule approved by the head of the organization		
37.	Availability of a register of record of conducted civil defense trainings		
38.	Availability of certificates of training in the field of civil defense of employees of the organization		
39.	Availability of information submitted to the territorial subdivisions of the authorized body in the field of civil defense on conducting exercises and drills in the field of civil defense with attached copies of organizational documents		
40.	Preparedness of the main civil defense formations, including those that are part of the emergency response team and the formations that ensure the conduct of rescue and emergency work		

41.	Availability of a cadastral passport for the real estate object		
42.	Availability of main and auxiliary rooms in shelters and radiation shelters		
43.	Availability of natural ventilation with mechanical inducement in anti-radiation shelters		
44.	Availability of interior finishing of premises of civil defence protective structures made of non-combustible or hardly combustible materials, painting of walls, ceilings, and partitions mainly in light colors, without plastering		

Official (s)

position signature

surname, name, patronymic (if any)

Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 27
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist

**in the sphere of state control in the field of civil defense in respect
of organizations on the basis of which civil defense services have been established**

Footnote. The joint order was added with Appendix 27 in accordance with the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023); Minister of Emergency Situations of

the Republic of Kazakhstan dated 25.2024 No. 244 and acting Minister of National Economy of the Republic of Kazakhstan dated 25.06.2024 No. 40 (shall come into effect upon expiry of ten calendar days after the day of its first official publication).

The state body that assigned the inspection/preventive control with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object) of control and supervision

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
1.	Availability of a civil defense plan approved by the head of civil defense		
2.	Compliance with the structure and content of the civil defense plan and the plan of actions for liquidation of emergency situations of facility-based nature and their consequences		
3.	Availability of an emergency response plan		
4.	Availability of the required quantity and maintenance of civil defence property in readiness		
5.	Availability of devices for radiation and chemical reconnaissance, dosimetric control at the rate of one for radiation and chemical monitoring for each territorial formation of radiation and chemical reconnaissance		

6.	Availability of a legal act of the organization on creation of facility-based civil defense formations		
7.	Availability and compliance of the civil defence readiness plan		
8.	Availability of logistical support for civil defence units		
9.	Availability of respiratory protection equipment for each member of civil defense formations		
10.	Availability of certificates of training in the territorial subdivisions of the authorized body for persons organizing and conducting civil defense activities		
11.	Availability of certificates of training or retraining in educational institutions of the authorized body in the field of civil protection of officials responsible for organization and conduct of civil defense activities		
12.	Availability of a network of observation and laboratory control of civil defense for timely detection and indication of radioactive, chemical, biological contamination (pollution)		
13.	Preparedness of the main civil defense formations, including those that are part of the emergency response squad and formations that ensure the conduct of rescue and emergency work		

Official (s)

position signature

surname, name, patronymic (if any)

Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 28
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist

in the sphere of state control in the field of civil defense in respect of local executive bodies of the Republic of Kazakhstan

Footnote. The joint order was added with Appendix 28 in accordance with the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

The state body that assigned the inspection/preventive control with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object) of control and supervision

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
1.	Availability of a resolution on appointing the administration of collection evacuation centers at the local executive body		

2.	Availability of a legal act on appointing the administration of reception evacuation centers at the local executive body		
3.	Availability of a legal act of the local executive body on approval of regulations on civil defense services		
4.	Availability of a list of personnel of the collection evacuation point at the collection evacuation point, notification procedure (address, telephone number)		
5.	Compliance with the structure and content of the plan of civil defense and the plan of action to eliminate local emergencies and their consequences		
6.	Availability of a plan of civil defense approved by the chief of civil defense		
7.	Availability of an action plan of the local executive body for liquidation of emergency situations of local scale and their consequences, approved by the head of civil defense		
8.	Availability of a legal act on establishment of a structural subdivision or individual employees for organization and conduct of civil defense		
9.	Availability of a legal act on establishment of an evacuation commission		
10.	Availability of a legal act on establishment of an evacuation reception commission at the local executive body		
11.	Availability of a legal act on the establishment of collection evacuation points at the local executive body		

12.	Availability of a legal act on the establishment of intermediate evacuation points at the local executive body		
13.	Availability of a legal act on the establishment of reception evacuation points at the local executive body		
14.	Availability of reserve urban, reserve suburban, auxiliary and mobile control points		
15.	Availability of a legal act on approval of the composition and regulations of the evacuation (evacuation reception) commission		
16.	Availability of a legal act on the establishment of a commission for prevention and elimination of emergencies at the local executive body		
17.	Availability of a legal act on appointing the administration of intermediate evacuation points at the local executive body		
18.	Availability of a legal act on the establishment of civil protection services at the local executive body		
19.	Availability of a legal act on appointing the administration of reception centers for the affected population at the local executive body		
20.	Availability of a relevant legal act on the appointment of the administration of collection evacuation points		
21.	Availability at the collection evacuation point of the duties of the officials of the collection evacuation point		

22.	Availability at the collection evacuation point of an extract from the decision of the local executive bodies on the organization of the collection evacuation point and appointment of personnel		
23.	Availability at the collection evacuation point of a list of organizations with contacts to be sent from the collection evacuation point, a list of evacuation commissions (city, district) with contacts, a list of transport boarding points with contacts		
24.	Availability at the collection evacuation point of the scheme (plan) of the territory of the collection evacuation point and premises for their purpose		
25.	Availability at the collection evacuation point of a list of the nearest protective shelters assigned to the collection evacuation point		
26.	Availability at the collection evacuation point of a schedule of arrival and departure of motor convoys serving the collection evacuation point		
27.	Availability at the collection evacuation point of a sample request for transportation		
28.	Availability at the collection evacuation facility of a sample evacuation certificate and information on its issuance		
29.	Availability of a legal act on approval of the list of dual-use facilities at the local executive body		
	Availability of a legal act on establishment of		

30.	reception centers for the affected population (homeless, sanitary losses, irrecoverable losses) at the local executive body		
31.	Availability of a passport of the shelter (anti-radiation shelter)		
32.	Availability of a register of inspections of the protective shelter of civil defense		
33.	Availability of a register of the microclimate indicator and gas composition of the air in the shelter (radiation shelter)		
34.	Availability of a plan of the protective shelter of civil defense		
35.	Availability of a preparedness plan for the protective shelter of civil defense		
36.	Availability of a list of equipment, tools and property of the protective shelter of civil defense		
37.	Availability in the protective shelter of a list of telephone numbers of the management bodies		
38.	Availability of a list of the personnel of the maintenance team of the protective shelter		
39.	Availability of an operational scheme of the life support systems of the protective shelter (ventilation, water supply and sewerage, power supply of the protective equipment)		
40.	Availability of instructions for maintenance of the diesel power plant, filter-ventilation equipment (if any) of the protective shelter		

41.	Availability, maintenance in good condition of the diesel power plant of the protective shelter		
42.	Availability, maintenance in good condition of the emergency lighting of the protective shelter		
43.	Availability, maintenance in good condition of filter-ventilation equipment of the protective shelter		
44.	Availability, maintenance in good condition of water supply of the protective shelter		
45.	Availability, maintenance in good condition of the sewerage system of the protective shelter		
46.	Availability, maintenance in good condition of electrical supply and disconnecting devices (switches, cocks, gate valves) of the protective shelter		
47.	Availability, maintenance in good condition of protective and hermetic doors, valves and anti-explosion devices of the protective shelter		
48.	Availability in conspicuous places of notification signals of civil defense, rules of use of personal protective equipment, signs of entrances and exits, premises of the diesel power plant and filter-ventilation rooms, locations of sanitary units, water distribution points, sanitary points of the protective shelter		
49.	Availability of lighting and marking of fire-fighting equipment locations of the protective shelter		

50.	Availability of the required quantity and maintenance of civil defense equipment stockpiles, as well as placement in equipped storage facilities		
51.	Availability of storage facilities for civil defense property		
52.	Availability of round-the-clock security guards and security alarms for civil defense storage facilities		
53.	Availability of fencing and nighttime lighting at civil defense storage facilities		
54.	Maintenance of a safe distance of warehouses for storage of civil defense property from enterprises whose activities may adversely affect the condition of civil defense property		
55.	Availability of telephonization system taking into account the provision of external and internal communication, post and fire alarms of storage facilities for the storage of civil defense property		
56.	Availability of means of mechanization of loading and unloading works for operative unloading in warehouses for storage of civil defense property		
57.	Availability of access roads of the warehouses for storage of civil defense property in a state of readiness for unobstructed passage of vehicles at any time of the year		
58.	Availability of a serial number of the storage room for civil defense property		

59.	Availability of devices for measuring temperature and relative humidity (thermometers, hygrometers or psychrometers) in the storage room for civil defense property		
60.	Observance of temperature and air humidity conditions in the storage room for civil defense property		
61.	Availability of a warehouse checkpoint		
62.	Availability in the warehouse of a card on accounting for the existence of civil defense property		
63.	Availability of acts of reconciliation of accounting and warehouse records as of January 1 and July 1 of the year included in the audited period		
64.	Availability of an act of technical (qualitative) condition of civil defense property, a passport, a log confirming the expiration of storage time limits, as well as a laboratory report on the presence of deviations from normative indicators		
65.	Availability of the act on writing-off of civil defense property		
66.	Availability of the act of transfer of civil defense property for disposal		
67.	Availability of personal protective equipment to provide protection in peacetime and wartime for the living and working population in the territories within the boundaries of zones of possible radiation, chemical, bacteriological (biological) pollution (contamination)		

68.	Availability of additional cartridges for personal protective equipment and relevant documents confirming their ownership		
69.	Availability of radiation and chemical reconnaissance and dosimetric monitoring devices at the rate of one for radiation and chemical monitoring for each territorial radiation and chemical reconnaissance formation		
70.	Availability of a legal act on the establishment of territorial civil protection formations at the local executive body		
71.	Availability of a legal act on creation of an emergency response squad with approval of its commander at the local executive body		
72.	Availability of automobile, engineering (special) equipment of civil protection formations		
73.	Availability of equipment, gear, tools and materials of civil protection formations		
74.	Availability of respiratory protection equipment for each member of the civil protection formation		
75.	Availability of certificates of training in the territorial subdivisions of the authorized body for persons organizing and conducting civil defense activities		
76.	Availability of certificates of training or retraining in educational institutions of the authorized body in the field of civil protection of officials who organize and conduct civil defense activities		

77.	Availability of required, serviceable warning system		
78.	Availability of observation and laboratory control network of civil defense for timely detection and indication of radioactive, chemical, biological contamination (pollution)		
79.	Preparedness of the main civil defense formations, including those that are part of the emergency response squad and formations that ensure the conduct of rescue and emergency works		

Official (s)

position signature

surname, name, patronymic (if any)
Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 29
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist

in the sphere of state control in the field of civil defense in relation to organizations, which are assigned places of mass recreation on natural and artificial water bodies

Footnote. The joint order was added with Appendix 29 in accordance with the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

The state body that assigned the inspection/preventive control with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object)
of control and supervision

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number
of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
1.	Availability at the rescue station of set № 1 at the rate of one set № 1 per one squad rescuer		
2.	Availability at the rescue station of serviceable rescue means " Alexandrov's safety rope" in quantity of two units		
3.	Availability at the rescue station of serviceable paddle boats depending on the length of the shoreline of the beach (with the inscription on the sides " rescue")		
4.	Availability at the rescue station of a sanitary bag with medicines (first aid kit)		
5.	Presence at the rescue station of serviceable rescue equipment " Lifebuoys" in quantity of two units		
6.	Availability at the rescue stations of serviceable motorized boats depending on the length of the beach shoreline (with the inscription on the sides " rescue").		

7.	Availability at the rescue station of a safety line at the rate of one safety line per one squad rescuer		
8.	Availability at the rescue station of serviceable portable radios at the rate of one radio station per one squad rescuer		
9.	Availability at the rescue station of the rescue means "sweep with grappling"		
10.	Availability at the rescue station of a shot line not less than 40 meters long		
11.	Availability at the rescue station of serviceable loudspeaking devices "Megaphone" in quantity of two units		
12.	Availability of a rescue station at the organizer of a place of mass recreation, tourism and sports on water bodies and water management facilities, staff composition of the station depending on the length of the beach shoreline (head of the post, squad rescuer)		
13.	Availability at the rescue station of a rescue bib at the rate of one life safety jacket per one squad rescuer		
14.	Availability at the rescue station of a whistle at the rate of one whistle per one squad rescuer		
15.	Availability of binoculars at the rescue station at the rate of one binocular per one rescue tower		
16.	Availability at the rescue station of a pole and a lifeline at the rate of one pole and lifeline per each squad rescuer		
17.	Availability of an observation tower (depending on the coverage		

	of the entire controlled service area)		
18.	Availability at the rescue station of a stand with materials on prevention of accidents on water bodies and assistance to a drowning person		
19.	Availability at the rescue station of a stand with the rules of operation of stationary amusement rides and safety measures for operation of stationary amusement rides		
20.	Availability of a daily schedule at the rescue station		
21.	Availability at the rescue station of the instructions of the person on duty at the station		
22.	Availability at the rescue station of instructions on occupational health and safety		
23.	Availability at the rescue station of a book of acts on accidents on water		
24.	Availability at the rescue station of a map (scheme) of the served area with water area depths		
25.	Availability at the rescue station of the order of behavior on water bodies of citizens and inventory of the property of the rescue station		
26Y.	Availability of telephone communication and video fixation system with coverage of the whole service area		
27.	Availability of a stand with signs indicating air temperature, wind direction and current velocity		
28.	A stand with phone numbers and addresses of law enforcement agencies,		

	rescue services and the nearest water rescue station		
29.	Availability of a stand with the schedule of classes, trainings, competitions with indication of persons responsible for water safety		
30.	Availability of an appropriate sign in the place designated for swimming		
31.	Availability of appropriate buoys marking the boundary of the water area designated for swimming		
32.	Compliance of location of small-sized craft rental points, small-sized craft parking bases for water walks of the population, riding on towed vehicles, riding on water bodies, sailing boards under sail not closer than 50 meters from the borders of beaches and sections (strips) of water areas used for scuba diving		
33.	Availability of areas for teaching swimming to children of preschool and primary school age with a depth of no more than 0.7 meters, for children of senior school age with a depth of no more than 1.2 meters		
34.	Availability on the beach at a distance of 10 meters from the water at an interval of not more than 50 meters of shields with lifebuoys and rescue means "Alexandrov's safety rope"		
35.	Availability of appointed officials responsible for the safety of children at water bodies		
36.	Availability of instructions on actions to be taken in		

case of accidents and emergencies at water bodies		
---	--	--

Official (s)

position signature

surname, name, patronymic (if any)

Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 30
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist in the sphere of state control in the field of civil defense in relation to organizations not classified as civil defense, having protective structures and other property of civil defense

Footnote. The joint order was added with Appendix 30 in accordance with the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

The state body that assigned the inspection/preventive control with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object) of control and supervision

№, date)

Name of the subject (object) of control and supervision

(Individual identification number), business identification number of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant
1.	Availability of the passport of the shelter (radiation shelter)		
2.	Availability of the register of inspection of the protective shelter of civil defense		
3.	Availability of a register of the microclimate indicator and gas composition of the air in the shelter (radiation shelter)		
4.	Availability of a plan of the protective shelter of civil defense		
5.	Availability of a preparedness plan of the protective shelter of civil defense		
6.	Availability of a list of equipment, tools and property of the protective shelter of civil defense		
7.	Availability in the protective shelter of a list of telephone numbers of the management bodies		
8.	Availability of a list of personnel of the maintenance team of the protective shelter		
9.	Availability of the operational scheme of the life support systems of the protective shelter (ventilation, water supply and sewerage, power supply of the protective equipment)		
10.	Availability of instructions for maintenance of the diesel power plant, filter-ventilation equipment (if any) of the protective shelter		
11.	Availability, maintenance in good condition of the		

	diesel power plant of the protective shelter		
12.	Availability, maintenance in good condition of the emergency lighting of the protective shelter		
13.	Availability, maintenance in good condition of the filter-ventilation equipment of the protective shelter		
14.	Availability, maintenance in good condition of the water supply of the protective shelter		
15.	Availability, maintenance in good condition of the sewerage system of the protective shelter		
16.	Availability, maintenance in good condition of electrical supply and disconnecting devices (switches, cocks, gate valves) of the protective shelter		
17.	Availability, maintenance in good condition of protective and hermetic doors, valves and anti-explosion devices of the protective shelter		
18.	Availability in conspicuous places of notification signals of civil defense, rules of use of personal protective equipment, signs of entrances and exits, premises of the diesel power plant and filter-ventilation rooms, locations of sanitary units, water distribution points, sanitary posts of the protective shelter		
19.	Availability of lighting and marking of fire-fighting equipment locations of the protective shelter		

Official (s)

position signature

surname, name, patronymic (if any)
Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)

Appendix 31
to the joint order
of the Minister of Internal Affairs
of the Republic of Kazakhstan
dated October 30, 2018 №758
and the Minister of National Economy
of the Republic of Kazakhstan
dated October 30, 2018 №31

Checklist in the sphere of state control in the field of civil defense in relation to organizations not classified as civil defense, on the basis of which evacuation points have been established

Footnote. The joint order was added with Appendix 31 in accordance with the joint order of the Minister of Emergency Situations of the Republic of Kazakhstan dated 28.11.2022 № 250 and the Acting Minister of National Economy of the Republic of Kazakhstan dated 29.11.2022 № 95 (shall be enforced from 01.01.2023).

The state body that assigned the inspection/preventive control with a visit to the subject (object) of control and supervision

The act on assignment of inspection /preventive control with a visit to the subject (object) of control and supervision

№, date)
Name of the subject (object) of control and supervision

(Individual identification number), business identification number of the subject (object) of control and supervision

Registered address

Item №	List of requirements	Compliant	Non-compliant

Availability of a legal act

1.

	on the establishment of an evacuation commission		
2.	Availability of a legal act on approval of the composition and regulations of the evacuation (evacuation reception) commission		
3.	Availability of a legal act on appointing the administration of collection evacuation points		
4.	Presence at the collection evacuation point of the duties of officials of the collection evacuation point		
5.	Availability at the collection evacuation point of a list of personnel of the collection evacuation point, notification procedure (address, telephone number)		
6.	Availability at the collection evacuation point of an extract from the decision of local executive bodies on the organization of the collection evacuation point and appointment of personnel		
7.	Availability at the collection evacuation point of a list of organizations with contacts to be sent from the collection evacuation point, a list of evacuation commissions (city, district) with contacts, a list of boarding points with contacts		
8.	Availability at the collection evacuation point of a scheme (plan) of the territory of the collection evacuation point and premises for their purpose		
9.	Availability at the collection evacuation point of a list of the nearest protective structures assigned to the collection evacuation point		

10.	The collection evacuation point shall have a schedule of arrival and departure of convoys serving the collection evacuation point		
11.	Availability at the collection evacuation point of a sample transportation request form		
12.	Availability at the collection evacuation point of a sample evacuation certificate and information on its issuance		

Official (s)

position signature

surname, name, patronymic (if any)

Head of the subject of control and supervision

position signature

surname, name, patronymic (if any)